



APR 11 2017

Mr. David Waggoner
Ingomar Packing Company
PO Box 1448
Los Banos, CA 93635

**Re: Notice of Final Action - Title V Permit Renewal
District Facility # N-1276
Project # N-1153485**

Dear Mr. Waggoner:

The District has issued the Final Renewed Title V Permit for Ingomar Packing Company (see enclosure). The preliminary decision for this project was made on February 22, 2017. No comments were received subsequent to the District preliminary decision.

The public notice for issuance of the Final Title V Permit will be published approximately three days from the date of this letter.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Nick Peirce, Permit Services Manager, at (209) 557-6400.

Sincerely,


Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

San Joaquin Valley Air Pollution Control District

FACILITY: N-1276-0-4

EXPIRATION DATE: 09/30/2021

FACILITY-WIDE REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Particulate matter emissions from any combustion source shall not exceed 0.1 grains/dscf (calculated to 12% carbon dioxide). [District Rule 4201 and District Rule 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
3. The facility-wide fuel usage shall not exceed 19,600 MMBtu in any one day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The facility-wide CO emissions shall not exceed 167,538 pounds during any one calendar year. [District Rule 2201] Federally Enforceable Through Title V Permit
5. A record of the daily facility-wide fuel usage, in Btu, shall be kept. [District Rule 2201] Federally Enforceable Through Title V Permit
6. A record of the cumulative annual facility-wide CO emissions shall be kept. The record shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A record of the cumulative annual facility-wide NOx emissions shall be kept. The record shall be updated at least monthly. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
9. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
10. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
11. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: INGOMAR PACKING COMPANY
Location: 9950 S INGOMAR GRADE, LOS BANOS, CA 93835
N-1276-0-4 : Apr 7 2017 3:23PM - KAHLOHJ

12. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.9.1 and 9.13.1] Federally Enforceable Through Title V Permit
13. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
14. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
15. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
16. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
17. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
18. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
19. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
20. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
21. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
22. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
23. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
24. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
26. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
27. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
28. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
29. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
30. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
31. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
32. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
33. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
34. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
35. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
36. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8021 and 8011] Federally Enforceable Through Title V Permit
37. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8031 and 8011] Federally Enforceable Through Title V Permit
38. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8041 and 8011] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

39. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8051 and 8011] Federally Enforceable Through Title V Permit
40. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8061 and 8011] Federally Enforceable Through Title V Permit
41. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8071 and 8011] Federally Enforceable Through Title V Permit
42. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit
43. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
44. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
45. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
46. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
47. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
48. On April 30, 2006, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report are based upon this initial permit issuance date, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1276-1-14

EXPIRATION DATE: 09/30/2021

EQUIPMENT DESCRIPTION:

93 MMBTU/HR NEBRASKA MODEL NS-D-65 BOILER WITH A CSI LOW NOX BURNER, AN INDUCED FLUE GAS RECIRCULATION SYSTEM AND A CRI CATASTAK SELECTIVE CATALYTIC REDUCTION SYSTEM WITH AMMONIA INJECTION

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rules 2201 and 2520] Federally Enforceable Through Title V Permit
2. This boiler shall be equipped with a totalizing fuel flow meter that measures the quantity of natural gas consumed per day (in cubic feet). The meter shall be maintained in proper operating condition at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The unit shall be fired only on PUC-quality natural gas. [District Rules 2201, 2520 and 4320] Federally Enforceable Through Title V Permit
4. The daily fuel usage of this unit shall not exceed 2,160 MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. NOx emissions shall not exceed 5 ppmvd @ 3% O2 or 0.0062 lb/MMBtu referenced as NO2. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
6. CO emissions shall not exceed 100 ppmvd @ 3% O2 or 0.074 lb/MMBtu. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
7. VOC emissions shall not exceed 0.00292 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
8. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
9. PM10 emissions shall not exceed 0.00523 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Ammonia (NH3) emissions from the exhaust stack shall not exceed 10 ppmvd @ 3% O2 over a 15 minute averaging period. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The catalyst temperature shall be maintained at 350 degrees Fahrenheit, or higher, whenever the boiler is operated, except during start-up or shutdown periods. [40 CFR Part 64] Federally Enforceable Through Title V Permit
12. The catalyst temperature shall be monitored at least on a daily basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [40 CFR Part 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: INGOMAR PACKING COMPANY
Location: 9950 S INGOMAR GRADE, LOS BANOS, CA 93835
N-1276-1-14 Apr 7 2017 3:23PM - KAHLDNJ

13. Source testing to determine compliance with the NO_x, CO and ammonia emission limits of this permit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the result of a 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
14. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
15. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
16. Operator shall ensure that all required source testing conforms to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
17. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
18. For NO_x and CO emission source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.3] Federally Enforceable Through Title V Permit
20. Source testing to measure NO_x emissions shall be conducted using EPA Method 7E, EPA Method 19, or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4305 and 4320] Federally Enforceable Through Title V Permit
22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
24. Source testing for ammonia slip shall be conducted utilizing BAAQMD Method ST-1B. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The permittee shall monitor and record the stack concentration of NO_x, CO, NH₃ and O₂ at least once during each month in which source testing is not performed. NO_x, CO and O₂ monitoring shall be conducted utilizing a portable analyzer that meets District specifications. Ammonia monitoring shall be conducted utilizing Draeger tubes or another District approved equivalent method. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless it has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. Ammonia emission readings shall be taken at the time the NO_x, CO and O₂ readings are taken. The readings shall be converted to ppmvd @ 3% O₂. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

27. If the NO_x, CO or NH₃ concentrations, as measured by the portable analyzer or the District approved ammonia monitoring equipment, exceed the permitted levels the permittee shall return the emissions to compliant levels as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer or the ammonia monitoring equipment continue to show emission limit violations after 1 hour of operation following detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation that is subject to enforcement action has occurred. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. NO_x, CO, O₂ and NH₃ emission readings shall be taken with the unit operating at conditions representative of normal operation or under the conditions specified in the Permit to Operate. The NO_x, CO and O₂ analyzer as well as the ammonia emission monitoring equipment shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Analyzer readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. The permittee shall maintain records of: (1) the date and time of NO_x, CO, NH₃ and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x, CO and NH₃ concentrations corrected to 3% O₂, (3) make and model of the portable analyzer, (4) portable analyzer calibration records, (5) the method of determining the ammonia emission concentration, and (6) a description of any corrective action taken to maintain the emissions at or below the acceptable levels. [District Rules 2520, 9.3.2, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. A daily record of the duration of each start-up and shutdown period shall be kept. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
31. A record of the daily fuel usage of this unit, in Btu, shall be kept. [District Rules 2201 and 2520, 9.3.2 and 40 CFR 60.48(c)] Federally Enforceable Through Title V Permit
32. A daily record of the catalyst temperature, shall be kept. [40 CFR Part 64] Federally Enforceable Through Title V Permit
33. Operator shall monitor and record for each unit the HHV and cumulative annual use of natural gas fuel. [District Rules 2201, 2520, 9.3.2 and 4351, 6.1.1] Federally Enforceable Through Title V Permit
34. The HHV of the fuel shall be certified by a third party fuel supplier or shall be determined in accordance with District Rule 4351. [District Rule 2520, 9.3.2 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
35. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081, 2520 and 4320] Federally Enforceable Through Title V Permit
36. All records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rules 1070, 4.0, 2520, 9.3.2, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
37. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Rule 405 (Madera), 408 and 409 (Kern), and 408 (all six remaining counties in the San Joaquin Valley); Rule 404 (Madera) 406 (Fresno), and 407 (all six remaining counties in the San Joaquin Valley); SJVUAPCD Rule 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
38. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rule 4201 and 4301. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed compliance with SJVUAPCD Rule 1081. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

40. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rule 4305, Sec. 4.2, 5.1.1, 5.1.2., 5.4, 6.1.1, 6.2 (excepting 6.2.3), 6.3, 8.1 and Rule 4351 Sec 4.2, 5.2.2.1, 5.2.2.2, 6.1.1, 6.2 (excepting 6.2.3), 8.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. The requirements of 40 CFR 72.6(b) are not applicable because this is not an affected unit under the acid rain provisions. The requirements of 40 CFR 60.40c do not apply to this source because it is not used to produce electricity for sale. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR part 64] Federally Enforceable Through Title V Permit
43. The permittee shall comply with the record keeping and reporting requirements of 40 CFR part 64.9. [40 CFR part 64] Federally Enforceable Through Title V Permit
44. If the District or EPA determine that a Quality improvement plan is required under 40 CFR part 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR Part 64.8. [40 CFR Part 64] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1276-2-15

EXPIRATION DATE: 09/30/2021

EQUIPMENT DESCRIPTION:

93 MMBTU/HR NEBRASKA MODEL NS-D-65 BOILER WITH A CSI LOW NOX BURNER, AN INDUCED FLUE GAS RECIRCULATION SYSTEM AND A CRI CATASTAK SELECTIVE CATALYTIC REDUCTION SYSTEM WITH AMMONIA INJECTION

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rules 2201 and 2520] Federally Enforceable Through Title V Permit
2. This boiler shall be equipped with a totalizing fuel flow meter that measures the quantity of natural gas consumed per day (in cubic feet). The meter shall be maintained in proper operating condition at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
4. This unit shall be fired only on PUC-quality natural gas. [District Rules 2201, 2520 and 4320] Federally Enforceable Through Title V Permit
5. This daily fuel usage of this unit shall not exceed 2,160 MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. NOx emissions shall not exceed 5 ppmvd @ 3% O₂ (referenced as NO₂) or 0.0062 lb/MMBtu. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
7. CO emissions shall not exceed 100 ppmvd @ 3% O₂ or 0.074 lb/MMBtu. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
8. VOC emissions shall not exceed 0.0055 lb/MMBtu (referenced as methane). [District Rule 2201] Federally Enforceable Through Title V Permit
9. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. PM₁₀ emissions shall not exceed 0.0076 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Ammonia (NH₃) emissions from the exhaust stack shall not exceed 10 ppmvd @ 3% O₂ over a 15-minute averaging period. [District Rule 2201] Federally Enforceable Through Title V Permit
12. The catalyst temperature shall be maintained at 350 degrees Fahrenheit, or higher, whenever the boiler is operated, except during start-up or shutdown periods. [40 CFR Part 64] Federally Enforceable Through Title V Permit
13. The catalyst temperature shall be monitored at least on a daily basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [40 CFR Part 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

14. Source testing to determine compliance with the NO_x, CO and ammonia emission limits of this permit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the result of a 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
17. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
18. For NO_x and CO emission source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. Source testing to measure NO_x emissions shall be conducted using EPA Method 7E, EPA Method 19, or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. Source testing to measure CO emissions shall be conducted using EPA Method 10 or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
22. Stack gas oxygen shall be determined using EPA Method 3 or 3A or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
24. Source testing for ammonia slip shall be conducted utilizing BAAQMD Method ST-1B. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The permittee shall monitor and record the stack concentration of NO_x, CO, NH₃, and O₂ at least once during each month in which source testing is not performed. NO_x, CO and O₂ monitoring shall be conducted utilizing a portable analyzer that meets District specifications. Ammonia monitoring shall be conducted utilizing Draeger tubes or another District-approved equivalent method. Monitoring shall not be required if the unit is not in operation (i.e. the unit need not be started solely to perform monitoring). Monitoring shall be performed within five days of restarting the unit unless it has been performed within the last month. [District Rules 2201, 4102, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. Ammonia emission readings shall be taken at the time the NO_x, CO and O₂ readings are taken. The readings shall be converted to ppmvd @ 3% O₂. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

27. If the NO_x, CO, or NH₃ concentration, as measured by the portable analyzer or the District-approved ammonia monitoring equipment, exceed the permitted levels the permittee shall return the emissions to compliant levels as soon as possible, but no longer than one hour of operation after detection. If the portable analyzer or the ammonia monitoring equipment continue to show emission limit violations after one hour of operation following detection, the permittee shall notify the District within the following one hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation that is subject to enforcement action has occurred. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. All NO_x, CO, NH₃, and O₂ emission readings shall be taken with the unit operating at conditions representative of normal operation or under the conditions specified in the Permit to Operate. The NO_x, CO, and O₂ analyzer as well as the NH₃ emission monitoring equipment shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Analyzer readings taken shall be averaged over a 15-consecutive-minute period by either taking a cumulative 15-consecutive-minute sample reading or by taking at least five readings, evenly spaced out over the 15-consecutive-minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. The permittee shall maintain records of: (1) the date and time of NO_x, CO, NH₃, and O₂ measurements; (2) the O₂ concentration in percent by volume and the measured NO_x, CO, and NH₃ concentrations corrected to 3% O₂; (3) make and model of the portable analyzer; (4) portable analyzer calibration records; (5) the method of determining the NH₃ emission concentration; and (6) a description of any corrective action taken to maintain the emissions at or below the acceptable levels. [District Rules 2520, 9.4.2, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. A daily record of the duration of each start-up and shutdown period shall be kept. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
31. A record of the daily fuel usage of this unit, in Btu, shall be kept. [District Rules 2201 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
32. A daily record of the catalyst temperature, shall be kept. [40 CFR Part 64] Federally Enforceable Through Title V Permit
33. Operator shall monitor and record for each unit the HHV and cumulative annual use of natural gas fuel. [District Rules 2201, 2520, 9.3.2 and 4351, 6.1.1] Federally Enforceable Through Title V Permit
34. The HHV of the fuel shall be certified by a third party fuel supplier or shall be determined in accordance with District Rule 4351. [District Rule 2520, 9.3.2 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
35. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081, 2520 and 4320] Federally Enforceable Through Title V Permit
36. All records shall be maintained and retained on-site for a minimum of 5 years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
37. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following subsumed requirements: Rule 405 (Madera), 408 and 409 (Kern), and 408 (all six remaining counties in the San Joaquin Valley); Rule 404 (Madera) 406 (Fresno), and 407 (all six remaining counties in the San Joaquin Valley); SJVUAPCD Rule 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
38. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rule 4201 and 4301. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
39. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rule 1081. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

40. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rule 4305, Sec. 4.2, 5.1.1, 5.1.2,, 5.4, 6.1.1, 6.2 (excepting 6.2.3), 6.3, 8.1 and Rule 4351 Sec 4.2, 5.2.2.1, 5.2.2.2, 6.1.1, 6.2 (excepting 6.2.3), 8.1. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. The requirements of 40 CFR 72.6(b) are not applicable because this is not an affected unit under the acid rain provisions. The requirements of 40 CFR 60.40c do not apply to this source because it is not used to produce electricity for sale. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR part 64] Federally Enforceable Through Title V Permit
43. The permittee shall comply with the record keeping and reporting requirements of 40 CFR part 64.9. [40 CFR part 64] Federally Enforceable Through Title V Permit
44. If the District or EPA determine that a Quality improvement plan is required under 40 CFR part 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR Part 64.8. [40 CFR Part 64] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1276-3-16

EXPIRATION DATE: 09/30/2021

EQUIPMENT DESCRIPTION:

156 MMBTU/HR NEBRASKA MODEL N25-T-84 BOILER WITH A TODD RMB ULTRA-LOW NOX BURNER AND AN INDUCED FLUE GAS RECIRCULATION SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions from any combustion source shall not exceed 0.1 grains/dscf (calculated to 12% carbon dioxide). [District Rule 4201 and District Rule 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
2. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rules 2201 and 2520] Federally Enforceable Through Title V Permit
3. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
4. This boiler shall be equipped with a totalizing mass or volumetric fuel flow meter that measures the quantity of natural gas consumed per day (in cubic feet). The meter shall be maintained in proper operating condition at all times. [District Rule 2201 and 40 CFR 60.49b(d)(1)] Federally Enforceable Through Title V Permit
5. The unit shall only be fired on PUC-quality natural gas with a sulfur content of no greater than 1.0 grains (gr) of sulfur per 100 standard cubic feet (scf) of natural gas. [District Rules 2201, 2520 and 4320, 40 CFR 60.42b(k)(1)(2)] Federally Enforceable Through Title V Permit
6. The fuel usage of this unit shall not exceed 1,023,560 MMBtu during any rolling 12-month period. [District Rule 2201] Federally Enforceable Through Title V Permit
7. NOx emissions shall not exceed 7 ppmvd @ 3% O2 (referenced as NO2) or 0.008 lb/MMBtu. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
8. CO emissions shall not exceed 100 ppmvd @ 3% O2 or 0.074 lb/MMBtu. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
9. VOC emissions shall not exceed 0.0055 lb/MMBtu (referenced as methane). [District Rule 2201] Federally Enforceable Through Title V Permit
10. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. PM10 emissions shall not exceed 0.0024 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Source testing to determine compliance with the NOx and CO emission limits of this permit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the result of a 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: INGOMAR PACKING COMPANY
Location: 9950 S INGOMAR GRADE, LOS BANOS, CA 93635
N-1276-3-16 Apr 7 2017 3:23PM -- KAHLOHJ

13. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
14. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
15. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
16. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. Source testing to measure NOx emissions shall be conducted using EPA Method 7E, EPA Method 19, or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
19. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
20. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
22. The flue gas recirculation valve(s) setting shall be monitored at least on a daily basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 4305, 4306 and 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
23. The acceptable settings for the flue gas recirculation valve(s) shall be established by source testing this unit or other representative units per Rule 4305 and as approved by the District. The normal range/level shall be that for which compliance with applicable NOx and CO emissions rates have been demonstrated through source testing at a similar firing rate. [District Rules 4305, 4306 and 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
24. Normal range or level for the flue gas recirculation valve(s) settings shall be re-established during each source test required by this permit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. If the flue gas recirculation valve(s) setting is less than the normal range/level, the permittee shall return the flue gas recirculation valve(s) setting to the normal range/level as soon as possible, but no longer than 1 hour of operation after detection. If the flue gas recirculation valve(s) setting is not returned to the normal range/level within 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new flue gas recirculation valve(s) setting. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

26. The permittee shall maintain records of the date and time of flue gas recirculation valve(s) settings, the observed setting, and the firing rate at the time of the flue gas recirculation valve(s) setting measurements. The records must also include a description of any corrective action taken to maintain the flue gas recirculation valve(s) setting within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. During the 36-month source-testing interval, the owner/operator shall have unit tuned at least twice during each calendar year it operates. The tune-ups shall be four to eight months apart and shall be conducted by a technician that is qualified, to the satisfaction of the APCO. All tune-ups shall be conducted in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
28. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
29. The records necessary to show the required tune-ups were conducted shall be kept. [District Rule 4320] Federally Enforceable Through Title V Permit
30. A daily record of the duration of each start-up and shutdown period shall be kept. [District Rule 4306 and 4320] Federally Enforceable Through Title V Permit
31. The owner or operator shall maintain records of the amount of fuel combusted during each day in this unit. [40 CFR 60.49b(d)(1)] Federally Enforceable Through Title V Permit
32. A record of the annual fuel usage of this unit, on a rolling 12-month basis, shall be kept. The record shall be in MMBtu and shall be updated at least once during each calendar month that the unit operates. [District Rule 2201] Federally Enforceable Through Title V Permit
33. Operator shall monitor and record for each unit the HHV and cumulative annual use of natural gas fuel. [District Rules 2201, 2520, 9.3.2 and 4351, 6.1.1] Federally Enforceable Through Title V Permit
34. The HHV of the fuel shall be certified by a third party fuel supplier or shall be determined in accordance with District Rule 4351. [District Rule 2520, 9.3.2 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
35. For 40 CFR Part 60 Subpart Db purposes, NO_x emissions shall not exceed 0.1 lb/MMBtu for low heat release units (70,000 Btu/hr-ft³ of furnace volume or less) and 0.2 lb/MMBtu for high heat release units (greater than 70,000 Btu/hr-ft³ of furnace volume) on a 30-day rolling average basis. NO_x standard shall apply at all times including periods of startup, shutdown, or malfunction. The permittee shall maintain record of the furnace volume, which is defined as the volume bounded by the front furnace wall where the burner is located, the furnace side waterfall, and extending to the level just below or in front of the first row of convection pass tubes. [40 CFR 60.44b(a), 60.44b(h), 60.44b(i)] Federally Enforceable Through Title V Permit
36. The owner or operator shall either obtain fuel receipts (such as a valid purchase contract, tariff sheet, or transportation contract) from the fuel supplier that certify that the gaseous fuel meets definition of natural gas (as defined in 40 CFR 60.41b) and the applicable sulfur limit (i.e., 1.0 gr-S/100 scf), or demonstrate that the combusted gas is provided from a PUC or FERC regulated source, or monitor the sulfur content within 60 days of initial startup under this permit and weekly thereafter. If the sulfur content is less than or equal to 1.0 gr/100 dscf for eight consecutive weeks, then the monitoring frequency shall be every six months. If the result of any six month monitoring demonstrates that the fuel does not meet the fuel sulfur content limit, weekly monitoring shall resume until compliance is demonstrated for eight consecutive weeks. [District Rules 1081, 2520 and 4320, 40 CFR 60.45b(j), 60.49b(r)(2)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

37. For 40 CFR Part 60 Subpart Db purpose, the operator shall upon request determine compliance with the NOx standard under 40 CFR 60.44 (0.1 lb/MMBtu for low heat release units (i.e., 70,000 Btu/hr-ft³ of furnace volume, or less), or 0.2 lb/MMBtu for high heat release units (i.e., greater than 70,000 Btu/hr-ft³ of furnace volume)) through the use of a 30-day performance test. During periods when performance tests are not requested, NOx emissions data collected pursuant to §60.48b(g)(1) or §60.48b(g)(2) are used to calculate a 30-day rolling average emission rate on a daily basis and used to prepare excess emission reports, but will not be used to determine compliance with the NOx emission standards. A new 30-day rolling average emission rate is calculated each steam generating unit operating day as the average of all of the hourly NOx emission data for the preceding 30 steam generating unit operating days. [40 CFR 60.46b(e)(4)] Federally Enforceable Through Title V Permit
38. The owner or operator shall monitor steam generating unit operating conditions and predict NOx emission rates as specified in a plan submitted pursuant to §60.49b(c) and approved by the District or the EPA. However, if no such plan exists at this time, the facility shall develop and submit a plan in accordance with 40 CFR 60.49b(c). [40 CFR 60.48b(g)(2)] Federally Enforceable Through Title V Permit
39. The owner or operator shall develop and submit a plan, within 360 days of startup under this permit, to predict the hourly NOx emissions. The plan shall: (1) Identify the specific operating conditions to be monitored and the relationship between these operating conditions and NOx emission rates (i.e., ng/J or lbs/MMBtu heat input). Steam generating unit operating conditions include, but are not limited to, the degree of staged combustion (i.e., the ratio of primary air to secondary and/or tertiary air) and the level of excess air (i.e., flue gas O₂ level); (2) Include the data and information that the owner or operator used to identify the relationship between NOx emission rates and these operating conditions; and (3) Identify how these operating conditions, including steam generating unit load, will be monitored under §60.48b(g) on an hourly basis by the owner or operator during the period of operation of the affected facility; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the owner or operator under §60.49b(g). If the plan is approved, the owner or operator shall maintain records of predicted nitrogen oxide emission rates and the monitored operating conditions, including steam generating unit load, identified in the plan. [40 CFR Part 60.49b(c)] Federally Enforceable Through Title V Permit
40. The owner or operator shall maintain records and submit a written report each calendar quarter to the District containing the following information for each steam generating unit operating day: (1) Calendar date; (2) The average hourly NOx and CO emission rates (expressed as NO₂) (ppmvd @ 3% O₂ and lb/MMBtu heat input) measured or predicted; (3) The 30-day average NOx emission rates (lb/MMBtu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days; (4) Identification of the steam generating unit operating days when the calculated 30-day average NOx emission rates are in excess of the NOx emissions standards under 40 CFR 60.44b (0.1 lb/MMBtu for low heat release units (i.e., 70,000 Btu/hr-ft³ of furnace volume, or less), or 0.2 lb/MMBtu for high heat release units (i.e., greater than 70,000 Btu/hr-ft³ of furnace volume)), with the reasons for such excess emissions as well as a description of corrective actions taken; (5) Identification of the steam generating unit operating days when the average hourly NOx and CO emission rates are in excess of the NOx and CO limits (startup, shutdown and steady state) in this permit, with the reason for such excess emissions as well as a description of corrective actions taken; (6) Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken; (7) Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data; (8) Identification of "F" factor used for calculations, method of determination, and type of fuel combusted; and (11) A negative declaration when no excess emissions occurred. The report is due on the 30th day following the end of the calendar quarter. [40 CFR 60.49b(g), 40 CFR 60.49b(i), and 40 CFR 60.49b(w)] Federally Enforceable Through Title V Permit
41. The owner or operator shall maintain all records of required monitoring data and support information for a period of five years from the date of data entry and shall make such records available to the District upon request. [District Rules 1070, 4305, 4306 and 4320, 40 CFR 60.49b(o)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

42. The owner or operator of an affected facility may submit electronic quarterly reports in lieu of submitting the written reports. The format of each quarterly electronic report shall be coordinated with the District. The electronic report(s) shall be submitted no later than 30 days after the end of the calendar quarter and shall be accompanied by a certification statement from the owner or operator, indicating whether compliance with the applicable emission standards and minimum data requirements of this permit was achieved during the reporting period. Before submitting reports in the electronic format, the owner or operator shall coordinate with the District to obtain their agreement to submit reports in this alternative format. [40 CFR 60.49b(v)] Federally Enforceable Through Title V Permit
43. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR Part 64] Federally Enforceable Through Title V Permit
44. The permittee shall comply with the record keeping and reporting requirements of 40 CFR part 64.9. [40 CFR Part 64] Federally Enforceable Through Title V Permit
45. If the District or EPA determine that a Quality improvement plan is required under 40 CFR part 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR Part 64.8. [40 CFR Part 64] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1276-8-8

EXPIRATION DATE: 09/30/2021

EQUIPMENT DESCRIPTION:

182.5 MMBTU/HR ENGLISH MODEL 150-H-600 WATERTUBE BOILER EQUIPPED WITH A TODD/RADIAN RMB BURNER AND AN INDUCED FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rules 2201 and 2520] Federally Enforceable Through Title V Permit
2. The unit shall only be fired on PUC-quality natural gas with a sulfur content of no greater than 1.0 grains (gr) of sulfur per 100 standard cubic feet (scf) of natural gas. [District Rules 2201, 2520 and 4320, 40 CFR 60.42b(k)(1)(2)] Federally Enforceable Through Title V Permit
3. This boiler shall be equipped with a totalizing mass or volumetric fuel flow meter that measures the quantity of natural gas consumed per day (in cubic feet). The meter shall be maintained in proper operating condition at all times. [District Rule 2201 and 40 CFR 60.49b(d)(1)] Federally Enforceable Through Title V Permit
4. NOx emissions shall not exceed 7 ppmvd @ 3% O2 or 0.008 lb/MMBtu referenced as NO2. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
5. CO emissions shall not exceed 100 ppmvd @ 3% O2 or 0.074 lb/MMBtu. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
6. VOC emissions shall not exceed 0.0004 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
7. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
8. PM10 emissions shall not exceed 0.0033 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Source testing to determine compliance with the NOx and CO emission limits of this permit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the result of a 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
10. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
11. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: INGOMAR PACKING COMPANY
Location: 9950 S INGOMAR GRADE, LOS BANOS, CA 93835
N-1276-8-8: Apr 7 2017 3:24PM - KAHLCNJ

12. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
13. For NO_x and CO emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
14. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.3] Federally Enforceable Through Title V Permit
15. Source testing to measure NO_x emissions shall be conducted using EPA Method 7E, EPA Method 19, or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
16. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
17. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
18. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
19. The flue gas recirculation valve(s) setting shall be monitored at least on a daily basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2520, 9.3.2, 4305, 4306, 4320 and 40 CFR part 64] Federally Enforceable Through Title V Permit
20. The flue gas recirculation valve(s) setting shall not be less than 68% at firing rates greater than 20% and less than 95%. [District Rules 2520, 9.3.2, 4305, 4306, 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
21. Normal range or level for the flue gas recirculation valve(s) settings shall be re-established during each source test required by this permit. [District Rules 4305, 4306 and 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
22. If the flue gas recirculation valve(s) setting is less than the normal range/level, the permittee shall return the flue gas recirculation valve(s) setting to the normal range/level as soon as possible, but no longer than 1 hour of operation after detection. If the flue gas recirculation valve(s) setting is not returned to the normal range/level within 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new flue gas recirculation valve(s) setting. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of the date and time of flue gas recirculation valve(s) settings, the observed setting, and the firing rate at the time of the flue gas recirculation valve(s) setting measurements. The records must also include a description of any corrective action taken to maintain the flue gas recirculation valve(s) setting within the acceptable range. [District Rules 2520, 9.3.2, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
24. During the 36-month source-testing interval, the owner/operator shall have unit tuned at least twice during each calendar year it operates. The tune-ups shall be four to eight months apart and shall be conducted by a technician that is qualified to the satisfaction of the APCO. All tune-ups shall be conducted in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

25. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
26. The records necessary to show the required tune-ups were conducted shall be kept. [District Rule 4320] Federally Enforceable Through Title V Permit
27. A daily record of the duration of each start-up and shutdown period shall be kept. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
28. The owner or operator shall maintain records of the amount of fuel combusted during each day in this unit. [40 CFR 60.49b(d)(1)] Federally Enforceable Through Title V Permit
29. Operator shall monitor and record for each unit the HHV and cumulative annual use of natural gas fuel. [District Rules 2201, 2520, 9.3.2 and 4351, 6.1.1] Federally Enforceable Through Title V Permit
30. The HHV of the fuel shall be certified by a third party fuel supplier or shall be determined in accordance with District Rule 4351. [District Rule 2520, 9.3.2 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
31. For 40 CFR Part 60 Subpart Db purposes, NOx emissions shall not exceed 0.1 lb/MMBtu for low heat release units (70,000 Btu/hr-ft³ of furnace volume or less) and 0.2 lb/MMBtu for high heat release units (greater than 70,000 Btu/hr-ft³ of furnace volume) on a 30-day rolling average basis. NOx standard shall apply at all times including periods of startup, shutdown, or malfunction. The permittee shall maintain record of the furnace volume, which is defined as the volume bounded by the front furnace wall where the burner is located, the furnace side waterfall, and extending to the level just below or in front of the first row of convection pass tubes. [40 CFR 60.44b(a), 60.44b(h), 60.44b(i)] Federally Enforceable Through Title V Permit
32. The owner or operator shall either obtain fuel receipts (such as a valid purchase contract, tariff sheet, or transportation contract) from the fuel supplier that certify that the gaseous fuel meets definition of natural gas (as defined in 40 CFR 60.41b) and the applicable sulfur limit (i.e., 1.0 gr-S/100 scf), or demonstrate that the combusted gas is provided from a PUC or FERC regulated source, or monitor the sulfur content within 60 days of initial startup under this permit and weekly thereafter. If the sulfur content is less than or equal to 1.0 gr/100 dscf for eight consecutive weeks, then the monitoring frequency shall be every six months. If the result of any six month monitoring demonstrates that the fuel does not meet the fuel sulfur content limit, weekly monitoring shall resume until compliance is demonstrated for eight consecutive weeks. [District Rules 1081, 2520 and 4320, 40 CFR 60.45b(j), 60.49b(r)(2)] Federally Enforceable Through Title V Permit
33. For 40 CFR Part 60 Subpart Db purpose, the operator shall upon request determine compliance with the NOx standard under 40 CFR 60.44 (0.1 lb/MMBtu for low heat release units (i.e., 70,000 Btu/hr-ft³ of furnace volume, or less), or 0.2 lb/MMBtu for high heat release units (i.e., greater than 70,000 Btu/hr-ft³ of furnace volume)) through the use of a 30-day performance test. During periods when performance tests are not requested, NOx emissions data collected pursuant to §60.48b(g)(1) or §60.48b(g)(2) are used to calculate a 30-day rolling average emission rate on a daily basis and used to prepare excess emission reports, but will not be used to determine compliance with the NOx emission standards. A new 30-day rolling average emission rate is calculated each steam generating unit operating day as the average of all of the hourly NOx emission data for the preceding 30 steam generating unit operating days. [40 CFR 60.46b(e)(4)] Federally Enforceable Through Title V Permit
34. The owner or operator shall monitor steam generating unit operating conditions and predict NOx emission rates as specified in a plan submitted pursuant to §60.49b(c) and approved by the District or the EPA. However, if no such plan exists at this time, the facility shall develop and submit a plan in accordance with 40 CFR 60.49b(c). [40 CFR 60.48b(g)(2)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

35. The owner or operator shall develop and submit a plan, within 360 days of startup under this permit, to predict the hourly NOx emissions. The plan shall: (1) Identify the specific operating conditions to be monitored and the relationship between these operating conditions and NOx emission rates (i.e., ng/J or lbs/MMBtu heat input). Steam generating unit operating conditions include, but are not limited to, the degree of staged combustion (i.e., the ratio of primary air to secondary and/or tertiary air) and the level of excess air (i.e., flue gas O2 level); (2) Include the data and information that the owner or operator used to identify the relationship between NOx emission rates and these operating conditions; and (3) Identify how these operating conditions, including steam generating unit load, will be monitored under §60.48b(g) on an hourly basis by the owner or operator during the period of operation of the affected facility; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the owner or operator under §60.49b(g). If the plan is approved, the owner or operator shall maintain records of predicted nitrogen oxide emission rates and the monitored operating conditions, including steam generating unit load, identified in the plan. [40 CFR Part 60.49b(c)] Federally Enforceable Through Title V Permit
36. The owner or operator shall maintain all records of required monitoring data and support information for a period of five years from the date of data entry and shall make such records available to the District upon request. [District Rules 1070, 4305, 4306 and 4320, 40 CFR 60.49b(o)] Federally Enforceable Through Title V Permit
37. The owner or operator of an affected facility may submit electronic quarterly reports in lieu of submitting the written reports. The format of each quarterly electronic report shall be coordinated with the District. The electronic report(s) shall be submitted no later than 30 days after the end of the calendar quarter and shall be accompanied by a certification statement from the owner or operator, indicating whether compliance with the applicable emission standards and minimum data requirements of this permit was achieved during the reporting period. Before submitting reports in the electronic format, the owner or operator shall coordinate with the District to obtain their agreement to submit reports in this alternative format. [40 CFR 60.49b(v)] Federally Enforceable Through Title V Permit
38. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR Part 64] Federally Enforceable Through Title V Permit
39. The permittee shall comply with the record keeping and reporting requirements of 40 CFR part 64.9. [40 CFR Part 64] Federally Enforceable Through Title V Permit
40. If the District or EPA determine that a Quality improvement plan is required under 40 CFR part 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR Part 64.8. [40 CFR Part 64] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1276-9-8

EXPIRATION DATE: 09/30/2021

EQUIPMENT DESCRIPTION:

182.5 MMBTU/HR ENGLISH MODEL 150-H-600 WATERTUBE BOILER EQUIPPED WITH A TODD/RADIAN RMB BURNER AND AN INDUCED FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rules 2201 and 2520] Federally Enforceable Through Title V Permit
2. The unit shall only be fired on PUC-quality natural gas with a sulfur content of no greater than 1.0 grains (gr) of sulfur per 100 standard cubic feet (scf) of natural gas. [District Rules 2201, 2520 and 4320, 40 CFR 60.42b(k)(1)(2)] Federally Enforceable Through Title V Permit
3. The heat input into this unit shall not exceed 864,000 MMBtu during any one rolling 12-month period. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This boiler shall be equipped with a totalizing mass or volumetric fuel flow meter that measures the quantity of natural gas consumed per day (in cubic feet). The meter shall be maintained in proper operating condition at all times. [District Rule 2201 and 40 CFR 60.49b(d)(1)] Federally Enforceable Through Title V Permit
5. NO_x emissions shall not exceed 7 ppmvd @ 3% O₂ or 0.008 lb/MMBtu referenced as NO₂. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
6. CO emissions shall not exceed 100 ppmvd @ 3% O₂ or 0.074 lb/MMBtu. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
7. VOC emissions shall not exceed 0.0004 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
8. SO_x emissions shall not exceed 0.00285 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
9. PM₁₀ emissions shall not exceed 0.0033 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Source testing to determine compliance with the NO_x and CO emission limits of this permit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the result of a 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 4305, 4306 and 4320]
11. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
12. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

13. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
14. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
15. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.3] Federally Enforceable Through Title V Permit
16. Source testing to measure NOx emissions shall be conducted using EPA Method 7E, EPA Method 19, or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
17. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
18. Stack gas oxygen (O2) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
19. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
20. The flue gas recirculation valve(s) setting shall be monitored at least on a daily basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [District Rules 2520, 9.3.2, 4305, 4306, 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
21. The flue gas recirculation valve(s) setting shall not be less than 73% at firing rates greater than 27% and less than 95%. [District Rules 2520, 9.3.2, 4305, 4306, 4320 and 40 CFR Part 64] Federally Enforceable Through Title V Permit
22. Normal range or level for the flue gas recirculation valve(s) settings shall be re-established during each source test required by this permit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
23. If the flue gas recirculation valve(s) setting is less than the normal range/level, the permittee shall return the flue gas recirculation valve(s) setting to the normal range/level as soon as possible, but no longer than 1 hour of operation after detection. If the flue gas recirculation valve(s) setting is not returned to the normal range/level within 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour, and conduct a source test within 60 days of the first exceedance, to demonstrate compliance with the applicable emission limits at the new flue gas recirculation valve(s) setting. A District-approved portable analyzer may be used in lieu of a source test to demonstrate compliance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of the date and time of flue gas recirculation valve(s) settings, the observed setting, and the firing rate at the time of the flue gas recirculation valve(s) setting measurements. The records must also include a description of any corrective action taken to maintain the flue gas recirculation valve(s) setting within the acceptable range. [District Rules 2520, 9.3.2, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. During the 36-month source-testing interval, the owner/operator shall have unit tuned at least twice during each calendar year it operates. The tune-ups shall be four to eight months apart and shall be conducted by a technician that is qualified, to the satisfaction of the APCO. All tune-ups shall be conducted in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

26. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
27. The records necessary to show the required tune-ups were conducted shall be kept. [District Rule 4320]
28. A daily record of the duration of each start-up and shutdown period shall be kept. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
29. The owner or operator shall maintain records of the amount of fuel combusted during each day in this unit. [40 CFR 60.49b(d)(1)] Federally Enforceable Through Title V Permit
30. A record of the fuel usage of this unit, on a 12 month rolling total basis, shall be kept. The record shall be updated at least once every calendar month. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Operator shall monitor and record for each unit the HHV and cumulative annual use of natural gas fuel. [District Rules 2201, 2520, 9.3.2 and 4351, 6.1.1] Federally Enforceable Through Title V Permit
32. The HHV of the fuel shall be certified by a third party fuel supplier or shall be determined in accordance with District Rule 4351. [District Rule 2520, 9.3.2 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
33. For 40 CFR Part 60 Subpart Db purposes, NO_x emissions shall not exceed 0.1 lb/MMBtu for low heat release units (70,000 Btu/hr-ft³ of furnace volume or less) and 0.2 lb/MMBtu for high heat release units (greater than 70,000 Btu/hr-ft³ of furnace volume) on a 30-day rolling average basis. NO_x standard shall apply at all times including periods of startup, shutdown, or malfunction. The permittee shall maintain record of the furnace volume, which is defined as the volume bounded by the front furnace wall where the burner is located, the furnace side waterfall, and extending to the level just below or in front of the first row of convection pass tubes. [40 CFR 60.44b(a), 60.44b(h), 60.44b(i)] Federally Enforceable Through Title V Permit
34. The owner or operator shall either obtain fuel receipts (such as a valid purchase contract, tariff sheet, or transportation contract) from the fuel supplier that certify that the gaseous fuel meets definition of natural gas (as defined in 40 CFR 60.41b) and the applicable sulfur limit (i.e., 1.0 gr-S/100 scf), or demonstrate that the combusted gas is provided from a PUC or FERC regulated source, or monitor the sulfur content within 60 days of initial startup under this permit and weekly thereafter. If the sulfur content is less than or equal to 1.0 gr/100 dscf for eight consecutive weeks, then the monitoring frequency shall be every six months. If the result of any six month monitoring demonstrates that the fuel does not meet the fuel sulfur content limit, weekly monitoring shall resume until compliance is demonstrated for eight consecutive weeks. [District Rules 1081, 2520 and 4320, 40 CFR 60.45b(j), 60.49b(r)(2)] Federally Enforceable Through Title V Permit
35. For the initial compliance test under 40 CFR Part 60 Subpart Db, NO_x emissions shall be monitored for 30 successive steam generating unit operating days and the 30-day average emission rate shall be used to determine compliance with the NO_x emission standard under 40 CFR 60.44b (0.1 lb/MMBtu for low heat release units (i.e., 70,000 Btu/hr-ft³ of furnace volume, or less), or 0.2 lb/MMBtu for high heat release units (i.e., greater than 70,000 Btu/hr-ft³ of furnace volume)). The 30-day average emission rate is calculated as the average of all hourly emissions data recorded by the monitoring system during the 30-day test period. Previously conducted compliance test in the manner prescribed in this condition may be used to fulfill the requirements of 40 CFR 60.46b(e)(1). [40 CFR 60.46b(e)(1)] Federally Enforceable Through Title V Permit
36. For 40 CFR Part 60 Subpart Db purpose, the operator shall upon request determine compliance with the NO_x standard under 40 CFR 60.44 (0.1 lb/MMBtu for low heat release units (i.e., 70,000 Btu/hr-ft³ of furnace volume, or less), or 0.2 lb/MMBtu for high heat release units (i.e., greater than 70,000 Btu/hr-ft³ of furnace volume)) through the use of a 30-day performance test. During periods when performance tests are not requested, NO_x emissions data collected pursuant to §60.48b(g)(1) or §60.48b(g)(2) are used to calculate a 30-day rolling average emission rate on a daily basis and used to prepare excess emission reports, but will not be used to determine compliance with the NO_x emission standards. A new 30-day rolling average emission rate is calculated each steam generating unit operating day as the average of all of the hourly NO_x emission data for the preceding 30 steam generating unit operating days. [40 CFR 60.46b(e)(4)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

37. The owner or operator shall monitor steam generating unit operating conditions and predict NOx emission rates as specified in a plan submitted pursuant to §60.49b(c) and approved by the District or the EPA. However, if no such plan exists at this time, the facility shall develop and submit a plan in accordance with 40 CFR 60.49b(c). [40 CFR 60.48b(g)(2)] Federally Enforceable Through Title V Permit
38. The owner or operator shall develop and submit a plan, within 360 days of startup under this permit, to predict the hourly NOx emissions. The plan shall: (1) Identify the specific operating conditions to be monitored and the relationship between these operating conditions and NOx emission rates (i.e., ng/J or lbs/MMBtu heat input). Steam generating unit operating conditions include, but are not limited to, the degree of staged combustion (i.e., the ratio of primary air to secondary and/or tertiary air) and the level of excess air (i.e., flue gas O2 level); (2) Include the data and information that the owner or operator used to identify the relationship between NOx emission rates and these operating conditions; and (3) Identify how these operating conditions, including steam generating unit load, will be monitored under §60.48b(g) on an hourly basis by the owner or operator during the period of operation of the affected facility; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the owner or operator under §60.49b(g). If the plan is approved, the owner or operator shall maintain records of predicted nitrogen oxide emission rates and the monitored operating conditions, including steam generating unit load, identified in the plan. [40 CFR Part 60.49b(c)] Federally Enforceable Through Title V Permit
39. The owner or operator shall maintain records and submit a written report each calendar quarter to the District containing the following information for each steam generating unit operating day: (1) Calendar date; (2) The average hourly NOx and CO emission rates (expressed as NO2) (ppmvd @ 3% O2 and lb/MMBtu heat input) measured or predicted; (3) The 30-day average NOx emission rates (lb/MMBtu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days; (4) Identification of the steam generating unit operating days when the calculated 30-day average NOx emission rates are in excess of the NOx emissions standards under 40 CFR 60.44b (0.1 lb/MMBtu for low heat release units (i.e., 70,000 Btu/hr-ft³ of furnace volume, or less), or 0.2 lb/MMBtu for high heat release units (i.e., greater than 70,000 Btu/hr-ft³ of furnace volume)), with the reasons for such excess emissions as well as a description of corrective actions taken; (5) Identification of the steam generating unit operating days when the average hourly NOx and CO emission rates are in excess of the NOx and CO limits (startup, shutdown and steady state) in this permit, with the reason for such excess emissions as well as a description of corrective actions taken; (6) Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken; (7) Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data; (8) Identification of "F" factor used for calculations, method of determination, and type of fuel combusted; and (11) A negative declaration when no excess emissions occurred. The report is due on the 30th day following the end of the calendar quarter. [40 CFR 60.49b(g), 40 CFR 60.49b(i), and 40 CFR 60.49b(w)] Federally Enforceable Through Title V Permit
40. The owner or operator shall maintain all records of required monitoring data and support information for a period of five years from the date of data entry and shall make such records available to the District upon request. [District Rules 1070, 4305, 4306 and 4320, 40 CFR 60.49b(o)] Federally Enforceable Through Title V Permit
41. The owner or operator of an affected facility may submit electronic quarterly reports in lieu of submitting the written reports. The format of each quarterly electronic report shall be coordinated with the District. The electronic report(s) shall be submitted no later than 30 days after the end of the calendar quarter and shall be accompanied by a certification statement from the owner or operator, indicating whether compliance with the applicable emission standards and minimum data requirements of this permit was achieved during the reporting period. Before submitting reports in the electronic format, the owner or operator shall coordinate with the District to obtain their agreement to submit reports in this alternative format. [40 CFR 60.49b(v)] Federally Enforceable Through Title V Permit
42. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR Part 64] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

43. The permittee shall comply with the record keeping and reporting requirements of 40 CFR part 64.9. [40 CFR Part 64] Federally Enforceable Through Title V Permit
44. If the District or EPA determine that a Quality improvement plan is required under 40 CFR part 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR Part 64.8. [40 CFR Part 64] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: INGOMAR PACKING COMPANY
Location: 9950 S INGOMAR GRADE, LOS BANOS, CA 93635
N-1276-9-8: Apr 7 2017 3:24PM - KATHLONJ

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1276-15-6

EXPIRATION DATE: 09/30/2021

EQUIPMENT DESCRIPTION:

98 MMBTU/HR NATURAL GAS-FIRED NEBRASKA MODEL NS-F/S 68 BOILER EQUIPPED WITH A TODD VARI-FLAME MODEL #V8151G0XXX LOW NOX BURNER, AN INDUCED FLUE GAS RECIRCULATION SYSTEM AND A CRI CATASTACK SELECTIVE CATALYTIC REDUCTION SYSTEM WITH AMMONIA INJECTION

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Particulate matter emissions from any combustion source shall not exceed 0.1 grains/dscf (calculated to 12% carbon dioxide). [District Rule 4201 and District Rule 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
3. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
4. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rules 2201 and 2520] Federally Enforceable Through Title V Permit
5. The unit shall be fired only on PUC-quality natural gas. [District Rules 2201, 2520 and 4320] Federally Enforceable Through Title V Permit
6. The heat input into this unit shall not exceed 240,000 MMBtu during any one rolling 12-month period. [District Rule 2201] Federally Enforceable Through Title V Permit
7. This boiler shall be equipped with a totalizing mass or volumetric fuel flow meter that measures the quantity of natural gas consumed per day (in cubic feet). The meter shall be maintained in proper operating condition at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
8. NOx emissions shall not exceed 5 ppmvd @ 3% O2 or 0.0062 lb/MMBtu referenced as NO2. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
9. CO emissions shall not exceed 50 ppmvd @ 3% O2 or 0.037 lb/MMBtu. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
10. VOC emissions shall not exceed 0.0055 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. PM10 emissions shall not exceed 0.0076 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Ammonia (NH3) emissions shall not exceed 10 ppmvd @ 3% O2 over a 15 minute averaging period. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: INGOMAR PACKING COMPANY
Location: 9950 S INGOMAR GRADE, LOS BANOS, CA 93635
N-1276-15-6 Apr 7 2017 3:24PM - KAHLOHJ

14. Source testing to determine compliance with the NO_x, CO and ammonia emission limits of this permit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the result of a 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 4305, 4306 and 4320]
15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
17. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
18. For NO_x and CO emission source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with that limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. Source testing to measure NO_x emissions shall be conducted using EPA Method 7E, EPA Method 19, or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
22. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320]
23. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
24. Source testing for ammonia slip shall be conducted utilizing BAAQMD Method ST-1B. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The permittee shall monitor and record the stack concentration of NO_x, CO, NH₃ and O₂ at least once during each month in which source testing is not performed. NO_x, CO and O₂ monitoring shall be conducted utilizing a portable analyzer that meets District specifications. Ammonia monitoring shall be conducted utilizing Draeger tubes or another District approved equivalent method. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless it has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. Ammonia emission readings shall be taken at the time the NO_x, CO and O₂ readings are taken. The readings shall be converted to ppmvd @ 3% O₂. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

27. If the NO_x, CO or NH₃ concentrations, as measured by the portable analyzer or the District approved ammonia monitoring equipment, exceed the permitted levels the permittee shall return the emissions to compliant levels as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer or the NH₃ monitoring equipment continue to show emission limit violations after 1 hour of operation following detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation that is subject to enforcement action has occurred. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
28. NO_x, CO, O₂ and NH₃ emission readings shall be taken with the unit operating at conditions representative of normal operation or under the conditions specified in the Permit to Operate. The NO_x, CO and O₂ analyzer as well as the NH₃ emission monitoring equipment shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Analyzer readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five readings, evenly spaced out over the 15 consecutive-minute period [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
29. The permittee shall maintain records of: (1) the date and time of NO_x, CO, NH₃ and O₂ measurements, (2) the O₂ concentration in percent by volume and the measured NO_x, CO and NH₃ concentrations corrected to 3% O₂, (3) make and model of the portable analyzer, (4) portable analyzer calibration records, (5) the method of determining the NH₃ emission concentration, and (6) a description of any corrective action taken to maintain the emissions at or below the acceptable levels. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
30. A daily record of the duration of each start-up and shutdown period shall be kept. [District Rule 4306 and 4320] Federally Enforceable Through Title V Permit
31. A record of the fuel usage of this unit, on a 12 month rolling total basis, shall be kept. The record shall be updated at least once every calendar month. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Operator shall monitor and record for each unit the HHV and cumulative annual use of natural gas fuel. [District Rules 2201, 2520, 9.3.2 and 4351, 6.1.1] Federally Enforceable Through Title V Permit
33. The HHV of the fuel shall be certified by a third party fuel supplier or shall be determined in accordance with District Rule 4351. [District Rule 2520, 9.3.2 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
34. Permittee shall determine sulfur content of combusted gas annually or shall demonstrate that the combusted gas is provided from a PUC or FERC regulated source. [District Rules 1081, 2520 and 4320] Federally Enforceable Through Title V Permit
35. All records shall be maintained and retained on-site for a minimum of 5 years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
36. This unit is subject to the requirements of 40 CFR Part 60, Subpart Dc: Standards of Performance for Small Industrial-Commercial-Institutional Steam Generating Units. [40 CFR Part 60, Subpart Dc] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1276-18-3

EXPIRATION DATE: 09/30/2021

EQUIPMENT DESCRIPTION:

180 MMBTU/HR NATURAL GAS FIRED NEBRASKA MODEL 500D-100 BOILER EQUIPPED WITH A JOHN ZINK VARIFLAME BURNER, AN INDUCED FLUE GAS RECIRCULATION SYSTEM AND A HALDOR TOPSOE SELECTIVE CATALYTIC REDUCTION SYSTEM WITH AMMONIA INJECTION.

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rules 2201 and 2520] Federally Enforceable Through Title V Permit
2. The unit shall only be fired on PUC-quality natural gas with a sulfur content of no greater than 1.0 grains (gr) of sulfur per 100 standard cubic feet (scf) of natural gas. [District Rules 2201, 2520 and 4320, 40 CFR 60.42b(k)(1)(2)] Federally Enforceable Through Title V Permit
3. The heat input into this unit shall not exceed 475,000 MMBtu during any one rolling 12-month period. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This boiler shall be equipped with a totalizing mass or volumetric fuel flow meter that measures the quantity of natural gas consumed per day (in cubic feet). The meter shall be maintained in proper operating condition at all times. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The combined start-up duration shall not exceed 2 hours during any one day and shall not exceed 20 hours per calendar year. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
6. NOx emissions during non-start-up periods shall not exceed 5 ppmvd @ 3% O2 or 0.0062 lb/MMBtu referenced as NO2. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
7. NOx emissions during start-up periods shall not exceed 40 ppmvd @ 3% O2 or 0.048 lb/MMBtu referenced as NO2. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
8. The NOx emission control system shall be brought fully online as soon as practical. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
9. CO emissions during non-start-up periods shall not exceed 100 ppmvd @ 3% O2 or 0.074 lb/MMBtu. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
10. CO emissions during start-up periods shall not exceed 400 ppmvd @ 3% O2 or 0.3 lb/MMBtu. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
11. VOC emissions shall not exceed 0.004 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. SOx emissions shall not exceed 0.00285 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. PM10 emissions shall not exceed 0.0076 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Ammonia (NH3) emissions shall not exceed 10 ppmvd @ 3% O2 over a 15 minute averaging period. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

15. The catalyst temperature shall be maintained at 350 degrees Fahrenheit, or higher, whenever the boiler is operated, except during start-up or shutdown periods. [40 CFR Part 64] Federally Enforceable Through Title V Permit
16. The catalyst temperature shall be monitored at least on a daily basis. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last week. Records must be maintained of the dates of non-operation to validate extended monitoring frequencies. [40 CFR Part 64] Federally Enforceable Through Title V Permit
17. Source testing to determine compliance with the NO_x, CO and ammonia emission limits of this permit shall be conducted at least once every twelve months. After demonstrating compliance on two consecutive annual source tests, the unit shall be tested not less than once every thirty-six months. If the result of a 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve months. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
18. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081, 7.1] Federally Enforceable Through Title V Permit
19. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
21. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081, 7.3] Federally Enforceable Through Title V Permit
23. Source testing to measure NO_x emissions shall be conducted using EPA Method 7E, EPA Method 19, or CARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
24. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
25. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
26. Stack gas velocities shall be determined using EPA Method 2. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
27. During the 36-month source-testing interval, the owner/operator shall have unit tuned at least twice during each calendar year it operates. The tune-ups shall be four to eight months apart and shall be conducted by a technician that is qualified, to the satisfaction of the APCO. All tune-ups shall be conducted in accordance with the procedure described in Rule 4304 (Equipment Tuning Procedure for Boilers, Steam Generators, and Process Heaters). [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
28. If the unit does not operate throughout a continuous six-month period within a calendar year, only one tune-up is required for that calendar year. No tune-up is required for any unit that is not operated during that calendar year; this unit may be test fired to verify availability of the unit for its intended use, but once the test firing is completed the unit shall be shutdown. [District Rules 4306 and 4320] Federally Enforceable Through Title V Permit
29. The records necessary to show the required tune-ups were conducted shall be kept. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

30. A daily record of the duration of each start-up and shutdown period shall be kept. [District Rules 2201, 4306 and 4320] Federally Enforceable Through Title V Permit
31. The owner or operator shall maintain records of the amount of fuel combusted during each day in this unit. [40 CFR 60.49b(d)(1)] Federally Enforceable Through Title V Permit
32. A record of the fuel usage of this unit, on a 12 month rolling total basis shall be kept. The record shall be updated at least once every calendar month. [District Rule 2201] Federally Enforceable Through Title V Permit
33. A daily record of the catalyst temperature, shall be kept. [40 CFR Part 64] Federally Enforceable Through Title V Permit
34. Operator shall monitor and record for each unit the HHV and cumulative annual use of natural gas fuel. [District Rules 2201, 2520, 9.3.2 and 4351, 6.1.1] Federally Enforceable Through Title V Permit
35. The HHV of the fuel shall be certified by a third party fuel supplier or shall be determined in accordance with District Rule 4351. [District Rule 2520, 9.3.2 and 4351, 6.2.1] Federally Enforceable Through Title V Permit
36. For 40 CFR Part 60 Subpart Db purposes, NOx emissions shall not exceed 0.1 lb/MMBtu for low heat release units (70,000 Btu/hr-ft³ of furnace volume or less) and 0.2 lb/MMBtu for high heat release units (greater than 70,000 Btu/hr-ft³ of furnace volume) on a 30-day rolling average basis. NOx standard shall apply at all times including periods of startup, shutdown, or malfunction. The permittee shall maintain record of the furnace volume, which is defined as the volume bounded by the front furnace wall where the burner is located, the furnace side waterfall, and extending to the level just below or in front of the first row of convection pass tubes. [40 CFR 60.44b(a), 60.44b(h), 60.44b(i)] Federally Enforceable Through Title V Permit
37. The owner or operator shall either obtain fuel receipts (such as a valid purchase contract, tariff sheet, or transportation contract) from the fuel supplier that certify that the gaseous fuel meets definition of natural gas (as defined in 40 CFR 60.41b) and the applicable sulfur limit (i.e., 1.0 gr-S/100 scf), or demonstrate that the combusted gas is provided from a PUC or FERC regulated source, or monitor the sulfur content within 60 days of initial startup under this permit and weekly thereafter. If the sulfur content is less than or equal to 1.0 gr/100 dscf for eight consecutive weeks, then the monitoring frequency shall be every six months. If the result of any six month monitoring demonstrates that the fuel does not meet the fuel sulfur content limit, weekly monitoring shall resume until compliance is demonstrated for eight consecutive weeks. [District Rules 1081, 2520 and 4320, 40 CFR 60.45b(j), 60.49b(r)(2)] Federally Enforceable Through Title V Permit
38. For 40 CFR Part 60 Subpart Db purpose, the operator shall upon request determine compliance with the NOx standard under 40 CFR 60.44 (0.1 lb/MMBtu for low heat release units (i.e., 70,000 Btu/hr-ft³ of furnace volume, or less), or 0.2 lb/MMBtu for high heat release units (i.e., greater than 70,000 Btu/hr-ft³ of furnace volume)) through the use of a 30-day performance test. During periods when performance tests are not requested, NOx emissions data collected pursuant to §60.48b(g)(1) or §60.48b(g)(2) are used to calculate a 30-day rolling average emission rate on a daily basis and used to prepare excess emission reports, but will not be used to determine compliance with the NOx emission standards. A new 30-day rolling average emission rate is calculated each steam generating unit operating day as the average of all of the hourly NOx emission data for the preceding 30 steam generating unit operating days. [40 CFR 60.46b(e)(4)] Federally Enforceable Through Title V Permit
39. The owner or operator shall monitor steam generating unit operating conditions and predict NOx emission rates as specified in a plan submitted pursuant to §60.49b(c) and approved by the District or the EPA. However, if no such plan exists at this time, the facility shall develop and submit a plan in accordance with 40 CFR 60.49b(c). [40 CFR 60.48b(g)(2)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

40. The owner or operator shall develop and submit a plan, within 360 days of startup under this permit, to predict the hourly NOx emissions. The plan shall: (1) Identify the specific operating conditions to be monitored and the relationship between these operating conditions and NOx emission rates (i.e., ng/J or lbs/MMBtu heat input). Steam generating unit operating conditions include, but are not limited to, the degree of staged combustion (i.e., the ratio of primary air to secondary and/or tertiary air) and the level of excess air (i.e., flue gas O2 level); (2) Include the data and information that the owner or operator used to identify the relationship between NOx emission rates and these operating conditions; and (3) Identify how these operating conditions, including steam generating unit load, will be monitored under §60.48b(g) on an hourly basis by the owner or operator during the period of operation of the affected facility; the quality assurance procedures or practices that will be employed to ensure that the data generated by monitoring these operating conditions will be representative and accurate; and the type and format of the records of these operating conditions, including steam generating unit load, that will be maintained by the owner or operator under §60.49b(g). If the plan is approved, the owner or operator shall maintain records of predicted nitrogen oxide emission rates and the monitored operating conditions, including steam generating unit load, identified in the plan. [40 CFR Part 60.49b(c)] Federally Enforceable Through Title V Permit
41. The owner or operator shall maintain records and submit a written report each calendar quarter to the District containing the following information for each steam generating unit operating day: (1) Calendar date; (2) The average hourly NOx and CO emission rates (expressed as NO2) (ppmvd @ 3% O2 and lb/MMBtu heat input) measured or predicted; (3) The 30-day average NOx emission rates (lb/MMBtu heat input) calculated at the end of each steam generating unit operating day from the measured or predicted hourly nitrogen oxide emission rates for the preceding 30 steam generating unit operating days; (4) Identification of the steam generating unit operating days when the calculated 30-day average NOx emission rates are in excess of the NOx emissions standards under 40 CFR 60.44b (0.1 lb/MMBtu for low heat release units (i.e., 70,000 Btu/hr-ft³ of furnace volume, or less), or 0.2 lb/MMBtu for high heat release units (i.e., greater than 70,000 Btu/hr-ft³ of furnace volume)), with the reasons for such excess emissions as well as a description of corrective actions taken; (5) Identification of the steam generating unit operating days when the average hourly NOx and CO emission rates are in excess of the NOx and CO limits (startup, shutdown and steady state) in this permit, with the reason for such excess emissions as well as a description of corrective actions taken; (6) Identification of the steam generating unit operating days for which pollutant data have not been obtained, including reasons for not obtaining sufficient data and a description of corrective actions taken; (7) Identification of the times when emission data have been excluded from the calculation of average emission rates and the reasons for excluding data; (8) Identification of "F" factor used for calculations, method of determination, and type of fuel combusted; and (11) A negative declaration when no excess emissions occurred. The report is due on the 30th day following the end of the calendar quarter. [40 CFR 60.49b(g), 40 CFR 60.49b(i), and 40 CFR 60.49b(w)] Federally Enforceable Through Title V Permit
42. The owner or operator shall maintain all records of required monitoring data and support information for a period of five years from the date of data entry and shall make such records available to the District upon request. [District Rules 1070, 4305, 4306 and 4320, 40 CFR 60.49b(o)] Federally Enforceable Through Title V Permit
43. The owner or operator of an affected facility may submit electronic quarterly reports in lieu of submitting the written reports. The format of each quarterly electronic report shall be coordinated with the District. The electronic report(s) shall be submitted no later than 30 days after the end of the calendar quarter and shall be accompanied by a certification statement from the owner or operator, indicating whether compliance with the applicable emission standards and minimum data requirements of this permit was achieved during the reporting period. Before submitting reports in the electronic format, the owner or operator shall coordinate with the District to obtain their agreement to submit reports in this alternative format. [40 CFR 60.49b(v)] Federally Enforceable Through Title V Permit
44. The permittee shall comply with the compliance assurance monitoring operation and maintenance requirements of 40 CFR part 64.7. [40 CFR Part 64] Federally Enforceable Through Title V Permit
45. The permittee shall comply with the record keeping and reporting requirements of 40 CFR part 64.9. [40 CFR Part 64] Federally Enforceable Through Title V Permit
46. If the District or EPA determine that a Quality improvement plan is required under 40 CFR part 64.7(d)(2), the permittee shall develop and implement the Quality Improvement Plan in accordance with 40 CFR Part 64.8. [40 CFR Part 64] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1276-19-1

EXPIRATION DATE: 09/30/2021

EQUIPMENT DESCRIPTION:

20,000 GPM COOLING TOWER SERVED BY A DRIFT ELIMINATOR

PERMIT UNIT REQUIREMENTS

1. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. No hexavalent chromium containing compounds shall be added to cooling tower circulating water. [District Rule 7012] Federally Enforceable Through Title V Permit
4. Drift eliminator drift rate shall not exceed 0.001%. [District Rule 2201] Federally Enforceable Through Title V Permit
5. PM10 emission rate from the cooling tower shall not exceed 1.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Compliance with the PM10 emission limit shall be demonstrated as follows: $PM10 \text{ lb/day} = \text{Circulating Water Recirculation rate (gal/day)} \times 8.34 \text{ lb/gal} \times \text{Total Dissolved Solids Concentration in the blowdown water (ppm)} \times \text{Design Drift Rate (\%)}$. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Compliance with the PM10 emission limit shall be determined by blowdown water sample analysis by independent laboratory at once each calendar year. [District Rule 1081] Federally Enforceable Through Title V Permit
8. Records of the annual water sample analyses shall be kept. [District Rule 2201] Federally Enforceable Through Title V Permit
9. All records shall be retained on site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: N-1276-20-1

EXPIRATION DATE: 09/30/2021

EQUIPMENT DESCRIPTION:

182 BHP CUMMINS MODEL 6 BTA 5.9 F1 DIESEL FIRED (TIER 1 CERTIFIED) EMERGENCY ENGINE POWERING A FIRE PUMP

PERMIT UNIT REQUIREMENTS

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rules 4701 and 4702, 17 CCR 93115, and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
4. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801, 17 CCR 93115 and 40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
5. Emissions from this IC engine shall not exceed any of the following limits: 6.9 g-NOx/bhp-hr, 8.5 g-CO/bhp-hr, or 1.0 g-VOC/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Emissions from this IC engine shall not exceed 0.4 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit
7. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702] Federally Enforceable Through Title V Permit
8. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit
9. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. For testing purposes, the engine shall only be operated the number of hours necessary to comply with the testing requirements of the National Fire Protection Association (NFPA) 25 - "Standard for the Inspection, Testing, and Maintenance of Water-Based Fire Protection Systems", 1998 edition. Total hours of operation for all maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rules 4701 and 4702] Federally Enforceable Through Title V Permit
10. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the type of fuel used, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: INGOMAR PACKING COMPANY
Location: 9950 S INGOMAR GRADE, LOS BANOS, CA 93635
N-1276-20-1: Apr 7 2017 3:24PM - KAHLOHJ

11. The engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
12. The owner or operator has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2d to this subpart. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 business days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 business days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
13. The engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
14. The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
15. The owner or operator shall operate and maintain the engine according to the manufacturer's emission-related written instructions or develop its own maintenance plan which must provide to the extent practicable for the maintenance and operation of the engine in a manner consistent with good air pollution control practice for minimizing emissions. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
16. The owner or operator must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
17. The owner or operator shall keep records of the maintenance conducted on the engine to demonstrate that the engine and the associated emissions control equipment (if any) is being operated and maintained according to the manufacturer's maintenance plan. These records shall include, but are not limited to the date, hour meter reading, action performed (e.g., engine oil and filter change/analysis, air filter inspection, hoses and belt inspection, etc.), name of the individual conducting maintenance and company affiliation. [40 CFR Part 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
18. All records shall be maintained and retained on-site for a minimum of 5 years, and shall be made available for District inspection upon request. [District Rules 4701 and 4702, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.