San Joaquin Valley
AIR POLLUTION CONTROL DISTRICT

HEALTHY AIR LIVING™

JAN 17 2018

Mr. Gregory Pritchett
Chevron USA Inc
PO Box 1392
Bakersfield, CA 93302

Re: Notice of Preliminary Decision – Title V Permit Renewal
Facility Number: S-1131
Project Number: S-1162500

Dear Mr. Pritchett:

Enclosed for your review and comment is the District's analysis of the application to renew the Federally Mandated Operating Permit for Chevron USA Inc in central Kern County, California.

The notice of preliminary decision for this project will be published approximately three days from the date of this letter. After addressing all comments made during the 30-day public notice and the 45-day EPA comment periods, the District intends to issue the renewed Federally Mandated Operating Permit. Please submit your written comments on this project within the 30-day public comment period, as specified in the enclosed public notice.

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,

Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Tung Le, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via email

Seyed Sadredin
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: 661-392-5500 FAX: 661-392-5585

www.valleyair.org www.healthyairliving.com

Printed on recycled paper.

SAN JOAQUIN VALLEY
AIR POLLUTION CONTROL DISTRICT

Proposed Title V Permit Renewal Evaluation
Chevron USA Inc
S-1131

TABLE OF CONTENTS

I. PROPOSAL 2
II. FACILITY LOCATION 3
III. EQUIPMENT LISTING 4
IV. GENERAL PERMIT TEMPLATE USAGE 4
V. SCOPE OF EPA AND PUBLIC REVIEW 4
VI. FEDERALLY ENFORCEABLE REQUIREMENTS 5
VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE 7
VIII. PERMIT REQUIREMENTS 7
IX. PERMIT SHIELD 12
X. PERMIT CONDITIONS 13
XI. ATTACHMENTS 13

A. DRAFT RENEWED TITLE V OPERATING PERMIT
B. PREVIOUS TITLE V OPERATING PERMIT
C. DETAILED FACILITY LIST

TITLE V PERMIT RENEWAL EVALUATION

Heavy Oil Production Operation

Engineer: Richard Edgehill
Date: January 12, 2018

Facility Number: S-1131
Facility Name: Chevron USA Inc
Mailing Address: P O Box 1392
Bakersfield, CA 93302

Contact Name: Greg Pritchett, Kris Rickards, Dan Beck, and Lance Ericksen
Phone: (661) 654-7796 (KR)

Responsible Official: Gary Piron
Title: Aera Manager

Project # : S-1162500
Deemed Complete: September 15, 2016

I. PROPOSAL

Chevron USA Inc (Chevron) was issued a Title V permit which was renewed on January 12, 2012. As required by District Rule 2520, the applicant is requesting a permit renewal. The existing Title V permit shall be reviewed and modified to reflect all applicable District and Federal rules updated, removed, or added since the issuance of the renewed Title V permit (January 12, 2012).

Note that the applicant has also requested that the following conditions from units S-1131-1141 through '-1158 be deleted as they are outdated and redundant with District requirements. Additionally, the District and not EPA is now the PSD contact.

35. *The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII*

of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Y

36. *The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Y*

37. *In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Y*

38. *The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Y*

39. *The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Y*

The purpose of this evaluation is to provide the legal and factual basis for all updated applicable requirements and to determine if the facility will comply with these updated requirements. It also specifically identifies all additions, deletions, and/or changes made to permit conditions or equipment descriptions.

II. FACILITY LOCATION

Chevron USA Inc (Chevron) is located at the Heavy Oil Central Stationary Source in Kern County, CA.

III. EQUIPMENT LISTING

A detailed facility printout listing all permitted equipment at the facility is included as Attachment A.

IV. GENERAL PERMIT TEMPLATE USAGE

The applicant is requesting to use the following model general permit Templates:

A. Template SJV-UM-0-3 Facility Wide Umbrella

The facility wide permit includes the conditions on template No. SJV-UM-0-3, Facility Wide Umbrella in addition to the following specific conditions:

41. *No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102] N*

42. *When applicable to 40 CFR Part 68, a subject facility shall submit to the proper authority a Risk Management Plan when mandated by the regulation. [40 CFR Part 68] Y*

43. *All permits for facilities S-88, S-511 and S-1131 are included in ChevronTexaco Inc.'s Heavy Oil Central stationary source. [District Rule 2201] Y*

44. *On December 31, 2002, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Y*

V. SCOPE OF EPA AND PUBLIC REVIEW

Certain segments of the proposed Renewed Operating Permit are based on model general permit templates that have been previously subject to EPA and public review. The terms and conditions from the model general permit templates are included in the proposed permit and are not subject to further EPA and public review.

For permit applications utilizing model general permit templates, public and agency comments on the District's proposed actions are limited to the applicant's eligibility for model general permit template, applicable requirements not covered

by the model general permit template, and the applicable procedural requirements for issuance of Title V Operating Permits.

The following permit conditions, including their underlying applicable requirements, originate form model general permit template UM-3 and are not subject to further EPA or public review.

The UM-3 requirements are stated in Conditions 1 through 40 of the requirements for permit unit S-1131-0-3.

VI. FEDERALLY ENFORCEABLE REQUIREMENTS

A. Rules Updated

- District Rule 2020, Exemptions (amended December 18, 2014)
- District Rule 2201, New and Modified Stationary Source Review Rule (amended February 18, 2016)
- District Rule 4621, GASOLINE TRANSFER INTO STATIONARY STORAGE CONTAINERS, DELIVERY VESSELS, AND BULK PLANTS, December 19, 2013
- District Rule 4622, GASOLINE TRANSFER INTO MOTOR VEHICLE FUEL TANKS, December 19, 2013
- District Rule 4702, Internal Combustion Engines – Phase 2 (Amended November 14, 2013)
- 40 CFR Part 82, Subpart B Stratospheric Ozone (June 25, 2013)
- 40 CFR Part 82, Subpart F Stratospheric Ozone (June 25, 2013)

B. Rules Removed

None

C. Rules Added

Following rules are that are applicable to operation of this facility has been adopted since issuance of the initial Title V permit.

- District Rule 2410, Prevention of Significant Deterioration (adopted June 16, 2011, effective November 26, 2012)

- 40 CFR Part 60, Subpart OOOO Standards of Performance for Crude Oil and Natural Gas Production, Transmission and Distribution (Adopted 8/16/2012)

D. Rules Not Updated

- District Rule 1070 Inspections (Amended December 17, 1992)
- District Rule 1080, Stack Monitoring (amended December 17, 1992)
- District Rule 1081, Source Sampling (amended December 16, 1993)
- District Rule 1100, Equipment Breakdown (amended December 17,1992)
- District Rule 1160, Emission Statements (adopted November 18, 1992)
- District Rule 2010, Permits Required (amended December 17, 1992)
- District Rule 2031, Transfer of Permits (amended December 17, 1992)
- District Rule 2040, Applications (amended December 17, 1992)
- District Rule 2070, Standards for Granting Applications (amended December 17, 1992)
- District Rule 2080, Conditional Approval (amended December 17, 1992)
- District Rule 2520, Federally Mandated Operating Permits (amended June 21, 2001)
- District Rule 4001 New Source Performance Standards (Amended April 14, 1999)

  40 CFR 60 Subpart IIII –Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (RICE)

- District Rule 4002 National Emissions Standards for Hazardous Air Pollutants (Amended May 20, 2004)

  40 CFR 63 Subpart ZZZZ - – National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines (RICE)

- District Rule 4101, Visible Emissions (amended February 17, 2005)
- District Rule 4201, Particulate Matter Concentration (amended December 17, 1992)
- District Rule 4301, Fuel Burning Equipment (amended December 17, 1992)
- District Rule 4305, Boilers, Steam Generators and Process Heaters - Phase 2 (amended August 21, 2003)
- District Rule 4306, Boilers, Steam Generators and Process Heaters - Phase 3 (amended October 16, 2008)
- District Rule 4311, Flares, (amended June 16, 2009)
- District Rule 4320, Advanced Emission Reduction Options for Boilers, Steam Generators and Process Heaters greater than 5.0 MMBtu/hr (adopted October 16, 2008)

- District Rule 4401, Steam Enhanced Crude Oil Production Wells (Amended June 16, 2011)
- District Rule 4623, Storage of Organic Liquids (Amended 5/19/05)
- District Rule 4601 Architectural Coatings (Amended December 17, 2009)
- District Rule 4701, Internal Combustion Engines, Phase I, August 21, 2003
- District Rule 4703, Stationary Gas Turbines, September 20, 2007
- District Rule 4801, Sulfur Compounds (amended December 17, 1992)
- 40 CFR Part 82, Subpart F, Stratospheric Ozone
- 40 CFR Part 61, Subpart M, National Emission Standard for Asbestos (7/20/04)
- 40 CFR Part 64, Compliance Assurance Monitoring (10/22/97)
- 40 CFR Part 60 Appendix F (7/1/91)

VII. REQUIREMENTS NOT FEDERALLY ENFORCEABLE

For each Title V source, the District issues a single permit that contains the Federally Enforceable requirements, as well as the District-only requirements. The District-only requirements are not a part of the Title V Operating Permits. The terms and conditions that are part of the facility's Title V permit are designated as "Federally Enforceable Through Title V Permit".

For this facility, the following are not federally enforceable and will not be discussed in further detail:

A. Rules Added

None

B. Rules Not Updated

District Rule 4102, Nuisance (as amended December 17, 1992)

Condition 41 of permit unit -0-3 is based on District Rule 4102 and will therefore not be discussed any further.

VIII. PERMIT REQUIREMENTS

The purpose of this evaluation is to review changes to federally enforceable requirements; therefore, this compliance section will only address rules that have been amended or added since the issuance of the initial Title V permit or most recent renewal of the Title V permit.

A. District Rule 2020 - Exemptions

District Rule 2020 lists equipment which are specifically exempt from obtaining permits and specifies recordkeeping requirements to verify such exemptions. The amendments to this rule do not have any effect on current permit requirements and will therefore not be addressed in this evaluation.

B. District Rule 2201 - New and Modified Stationary Source Review Rule

District Rule 2201 has been amended since this facility's initial Title V permit was issued. This Title V permit renewal does not constitute a modification per section 3.26, defined as an action including at least one of the following items:

1) Any change in hours of operation, production rate, or method of operation of an existing emissions unit, which would necessitate a change in permit conditions.
2) Any structural change or addition to an existing emissions unit which would necessitate a change in permit conditions. Routine replacement shall not be considered to be a structural change.
3) An increase in emissions from an emissions unit caused by a modification of the Stationary Source when the emissions unit is not subject to a daily emissions limitation.
4) Addition of any new emissions unit which is subject to District permitting requirements.
5) A change in a permit term or condition proposed by an applicant to obtain an exemption from an applicable requirement to which the source would otherwise be subject.

Therefore, the updated requirements of this rule are not applicable at this time.

The Authorities to Construct listed in the following table were subject to the NSR Rule at the time the applicant applied for the Authority to Construct (ATC).

ATC	Equipment Description	Status
'-598-47	CONNECT THE VAPOR CONTROL SYSTEM TO TANKS S-1131-626, -627, -628, -632, -633 AND -634	Will not be implemented prior to Title V Permit Renewal
'-598-48	CONNECT THE VAPOR CONTROL SYSTEM TO (6) TANKS S-1131-599, -615, -619, -620, -631, -635 AND (10) WEMCOS S-1131-1194, -1195, -1196, -1197, -1198, -1199, -1200, -1201, -1202, AND -1203	Will not be implemented prior to Title V Permit Renewal
'-598-49	DELETE REFERENCES TO CANCELLED PTO S-1131-1127	ATCs are administrative and have been implemented, change included in the draft Title V PTOs
'-716-26	TEOR - COMBINE S-1131-716 WITH S-1131-1127 FOR A NEW COMBINED TOTAL OF 12,607 WELLS, APPROVE ALL WELLS TO OPERATE WITH CLOSE CASING VENTS, REDUCE THE MAXIMUM TEOR GAS VOC CONTENT TO 87% AND THEN CANCEL S-1131-1127	
'-724-8	GDF DISCONNECT THE WEST 87 TANK FROM THE MANIFOLD FOR TESTING	'-724 PTO will be cancelled prior to Title V Permit Renewal, no action taken at this time
'-943-22	REMOVE OPERATION AS REPLACEMENT UNIT LIMITED TO 90 BILLION BTU ANNUAL HEAT INPUT, LOWER NOX TO 7 PPMV AND RESTRICT TO FIRING ON PUC QUALITY NATURAL GAS ONLY	ATC will not be implemented prior to Title V Permit Renewal
'-998-12, '-1000-12, and '-1003-12	Steam piping change to split flow	ATCs have been implemented change included in the draft Title V PTOs
'-1038-12, '-1039-12	remove DEU status of turbine	ATCs will not be implemented prior to Title V PTO renewal
'-1136-0 thru '-1138-0	85 MMBtu/hr steam generators	ATCs will not be implemented prior to Title V PTO renewal
'-1187-0 thru '-1203-0	Construction of several tanks and vessels	Will not be implemented prior to Title V PTO renewal

C. Rule 4621 Gasoline Transfer into Stationary Storage Containers, Delivery Vessels, and Bulk Plants

This rule applies to storage containers located at bulk plants with capacities greater than 250 gallons and less than 19,800 gallons; to other stationary storage containers with capacities greater than 250 gallons; and to those storage containers that are not subject to the control requirements of Rule 4623 (Storage of Organic Liquids) Section 5.0. The rule also applies to gasoline delivery vessels.

This permit was evaluated for compliance with Rule 4621 in project 1163129. Since none of the permit conditions have changed, continued compliance with Rule 4621 is expected.

D. Rule 4622 Transfer of Gasoline into Vehicle Fuel Tanks

This rule applies to any gasoline storage and dispensing operation or mobile fueler from which gasoline is transferred into motor vehicle fuel tanks, except as provided in Section 4.0.

This permit was evaluated for compliance with Rule 4622 in project 1163129. Since none of the permit conditions have changed, continued compliance with Rule 4622 is expected.

E. District Rule 4702 – Internal Combustion Engines – Phase 2

The permit units listed in the following table (except '-1119) authorize emergency standby IC engines subject to the rule. The current permits (including the '-1119 permit) include conditions ensuring compliance with the rule.

Permit	Service	Comment
'-833	Emergency standby	Subpart IIII not applicable, engine installed prior to 2006, not modified, reconstructed after 2006, Subpart ZZZZ conditions added to draft PTO
'-1084	Emergency standby	Subpart IIII not applicable, engine installed prior to 2006, not modified, reconstructed after 2006, Subpart ZZZZ conditions added to draft PTO
'-1117	Emergency standby	Engine installed after 2006, added Subpart IIII condition listed below
'-1119	Transportable	No change to existing Subpart IIII Conditions, added Subpart IIII condition listed below
'-1204	Limited Life	Engine installed after 2006, no change to existing Subpart IIII Conditions added Subpart IIII condition listed below

The following condition was added to the revised Title V PTOs.

U.S. EPA administers the requirements of 40 CFR Part 60 Subpart IIII. The owner or operator shall comply with the emission and operating limitations, testing requirements, initial and continuous compliance requirements as specified in this subpart. The owner or operator shall submit all applicable notifications, reports, and records to the administrator by the required compliance dates. [District Rule 4001] N

D. 40 CFR Part 64 – CAM

40 CFR Part 64 requires Compliance Assurance Monitoring (CAM) for units that meet the following three criteria:

1) the unit must have an emission limit for the pollutant;
2) the unit must have add-on controls for the pollutant; these are devices such as flue gas recirculation (FGR), baghouses, and catalytic oxidizers; and
3) the unit must have a pre-control potential to emit of greater than the major source thresholds.

Major Source Thresholds

Pollutant	lb/year	ton/year
NOx	20,000	10
SOx	140,000	70
PM10	140,000	70
CO	200,000	100
VOC	20,000	10

CAM was addressed in previous Title V Renewal Project S-1131, 1162500 (finalized January 12, 2012). No new permit units have been added to facility S-1131 since January 17, 2012 which are subject to CAM.

E. 40 CFR Part 82, Subpart B Stratospheric Ozone (June 25, 2013)
40 CFR Part 82, Subpart F Stratospheric Ozone (June 25, 2013)

These requirements are included in Draft PTO '-0-5 conditions #27 and #28 reflect the requirements.

F. 40 CFR Part 60, Subpart OOOO Standards of Performance for Crude Oil and Natural Gas Production, Transmission and Distribution

Subpart OOOO could potentially apply to this facility's tanks. However, pursuant to section §60.5365(e), this subpart does not apply since the emissions from each of the tanks are estimated to be less than 6 tons per year. Therefore, the requirements of this subpart are not applicable to this facility.

IX. PERMIT SHIELD

A permit shield legally protects a facility from enforcement of the shielded regulations when a source is in compliance with the terms and conditions of the

Title V permit. Compliance with the terms and conditions of the Operating Permit is considered compliance with all applicable requirements upon which those conditions are based, including those that have been subsumed.

Conditions 39 and 40 on the proposed permit S-1131-0-3 are permit shields for the facility.

X. PERMIT CONDITIONS

See Attachment A - Draft Renewed Title V Operating Permit.

XI. ATTACHMENTS

A. Draft Renewed Title V Operating Permit
B. Previous Title V Operating Permit
C. Detailed Facility List

ATTACHMENT A

Draft Renewed Title V Operating Permit

San Joaquin Valley
Air Pollution Control District

FACILITY: S-1131-0-3 **EXPIRATION DATE:** 02/28/2017

DRAFT

FACILITY-WIDE REQUIREMENTS

1. {4362} The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. {4363} The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. {4364} The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
4. {4365} Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
5. {4366} The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
6. {4367} A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
7. {4368} Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
8. {4369} The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

DRAFT

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

9. {4370} The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

10. {4371} The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

11. {4372} Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

12. {4373} If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

13. {4374} It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

14. {4375} The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

15. {4376} The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

16. {4377} The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

17. {4378} The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

18. {4379} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

19. {4380} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

20. {4381} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

21. {4382} Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

DRAFT

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

22. {4383} No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

23. {4384} No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit

24. {4385} All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit

25. {4386} The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit

26. {4387} With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit

27. {4388} If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit

28. {4389} If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit

29. {4390} Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit

30. {4391} Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit

31. {4392} An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit

32. {4393} Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit

33. {4394} Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit

DRAFT

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

34. {4395} Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit

35. {4396} Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

36. {4397} The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

37. {4398} The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

38. {4399} When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

39. {4400} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

40. {4401} Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

41. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

42. When applicable to 40 CFR Part 68, a subject facility shall submit to the proper authority a Risk Management Plan when mandated by the regulation. [40 CFR Part 68] Federally Enforceable Through Title V Permit

43. All permits for facilities S-88, S-511 and S-1131 are included in ChevronTexaco Inc.'s Heavy Oil Central stationary source. [District Rule 2201] Federally Enforceable Through Title V Permit

44. On December 31, 2002, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-62-34

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS FIRED C.E. NATCO STEAM GENERATOR (60-38; DIS# 20630-79) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.007 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit

22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit

25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit

26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-63-29

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (60-39; DIS# 20631-79) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-64-29 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (60-40; DIS# 20632-79) WITH NORTH AMERICAN GLE LOW-NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-66-28

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (60-42; DIS# 20634-79) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-67-29

EXPIRATION DATE: 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS FIRED C.E. NATCO STEAM GENERATOR (60-43; DIS# 20635-79) WITH NORTH AMERICAN GLE LOW-NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-68-28 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

DRAFT

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS FIRED C.E. NATCO STEAM GENERATOR (60-44; DIS# 20636-79) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-69-28

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (60-45; DIS# 20637-79) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 15,858 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-70-28

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (60-46; DIS# 20638-79) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-73-28 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (60-49; DIS# 20641-79) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit

22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit

25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit

26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-77-28

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: 19 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED C.E. NATCO STEAM GENERATOR (60-67; DIS# 20611-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN, MODEL #5131-HGCR-62.5, BURNER AND NORTH AMERICAN OPTIMIZER (CANFIELD)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
6. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
7. Emission rates shall not exceed the following PM10: 0.108 lb/MMBtu, SOx (as SO2): 1.026 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.006 lb/MMBtu, and CO: 0.029 lb/MMBtu or 39 ppmv @ 3% O2. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
8. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the vapor recovery gas incinerated in this unit. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
9. Permittee shall measure and record the natural gas sulfur content and BTU content at the time of NOx testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
10. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

11. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

12. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

13. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

14. Compliance demonstration (source testing) shall be conducted by independent testing laboratories and shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

17. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 100 and EPA Method 19, fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans, or other test methods approved by the District. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

18. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

19. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

20. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

21. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3 and Kern County Rules 404 and 408] Federally Enforceable Through Title V Permit

22. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

27. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

29. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

36. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-78-30

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NW05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED C.E. NATCO STEAM GENERATOR (60-69; DIS# 20610-79) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (MONTE CRISTO 1)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and vapor recovery gas that has a combined fuel sulfur content not exceeding 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu; or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

12. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

13. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320]

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

28. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. {4194} Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. {4314} Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-82-31

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED C.E. NATCO STEAM GENERATOR (60-88; DIS# 20643-79) WITH NORTH AMERICAN GLE LOW NOX BURNER (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and vapor recovery gas from the vapor control system listed on permit unit PTO S-1131-598 that has a combined fuel sulfur content not exceeding 5 gr S/100 scf unless SOx is reduced by 95% or to an outlet concentration not exceeding 9 ppmv via scrubbing. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu or 1.026 lb-SOx/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 39 ppmvd CO @ 3% O2 or 0.029 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
7. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
8. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
9. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

10. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

14. An analysis of the fuel sulfur content may be submitted for compliance with the SOx requirement in lieu of the source test for SOx. [District Rules 2201and 4320] Federally Enforceable Through Title V Permit

15. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit

16. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Permittee shall submit an analysis showing the fuel's sulfur content or conduct a source test for SOx at least once every 12 months. [District Rule 4320, 5.7] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
27. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
30. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-94-31

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: 29 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STRUTHERS STEAM GENERATOR (70-08; DIS# 20627-81) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN, MODEL #5131-HGCR-62. 5, BURNER AND NORTH AMERICAN OPTIMIZER (CANFIELD)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
6. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
7. Emission rates shall not exceed the following PM10: 0.108 lb/MMBtu, SOx (as SO2): 1.026 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.006 lb/MMBtu, and CO: 0.029 lb/MMBtu or 39 ppmv @ 3% O2. [District Rules 2201, 4305, 4351] Federally Enforceable Through Title V Permit
8. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the vapor recovery gas incinerated in this unit. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
9. Permittee shall measure and record the natural gas sulfur content and BTU content at the time of NOx testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
10. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

11. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2201, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

12. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

13. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

14. Compliance demonstration (source testing) shall be conducted by independent testing laboratories and shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

17. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 100 and EPA Method 19, fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans, or other test methods approved by the District. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

18. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

19. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

20. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

21. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3 and Kern County Rules 404 and 408] Federally Enforceable Through Title V Permit

22. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

27. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

29. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

36. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-95-28

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STRUTHERS STEAM GENERATOR (70-31; DIS# 20642-79) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND, FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and vapor recovery gas from the vapor control system listed on permit unit PTO S-1131-598 that has a combined fuel sulfur content not exceeding 5 gr S/100 scf unless SOx is reduced by 95% or to an outlet concentration not exceeding 9 ppmv via scrubbing. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu or 1.026 lb-SOx/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 39 ppmvd CO @ 3% O2 or 0.029 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 43.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
7. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
8. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

10. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

14. An analysis of the fuel sulfur content may be submitted for compliance with the SOx requirement in lieu of the source test for SOx. [District Rules 2201and 4320] Federally Enforceable Through Title V Permit

15. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit

16. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

22. Permittee shall submit an analysis showing the fuel's sulfur content or conduct a source test for SOx at least once every 12 months. [District Rule 4320, 5.7] Federally Enforceable Through Title V Permit

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit

27. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

28. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-98-34

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (70-44; DIS# 20608-82) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and vapor recovery gas from the vapor control system listed on permit unit PTO S-1131-598 that has a combined fuel sulfur content not exceeding 5 gr S/100 scf unless SOx is reduced by 95% or to an outlet concentration not exceeding 9 ppmv via scrubbing. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu; 1.026 lb-SOx/MMBtu; or 0.006 lb-VOC/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
7. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
8. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

10. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

14. An analysis of the fuel sulfur content may be submitted for compliance with the SOx requirement in lieu of the source test for SOx. [District Rules 2201and 4320] Federally Enforceable Through Title V Permit

15. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit

16. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

22. Permittee shall submit an analysis showing the fuel's sulfur content or conduct a source test for SOx at least once every 12 months. [District Rule 4320, 5.7] Federally Enforceable Through Title V Permit

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit

27. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

28. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-99-34

EXPIRATION DATE: 02/28/2017

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (70-45; DIS# 20609-82) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and vapor recovery gas from the vapor control system listed on permit unit PTO S-1131-598 that has a combined fuel sulfur content not exceeding 5 gr S/100 scf unless SOx is reduced by 95% or to an outlet concentration not exceeding 9 ppmv via scrubbing. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu; 1.026 lb-SOx/MMBtu; or 0.006 lb-VOC/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
7. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
8. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

10. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

14. An analysis of the fuel sulfur content may be submitted for compliance with the SOx requirement in lieu of the source test for SOx. [District Rules 2201and 4320] Federally Enforceable Through Title V Permit

15. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit

16. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

22. Permittee shall submit an analysis showing the fuel's sulfur content or conduct a source test for SOx at least once every 12 months. [District Rule 4320, 5.7] Federally Enforceable Through Title V Permit

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit

27. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

28. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-509-6

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SW32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #TK3-7

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-592-5

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, S. PROCESS WASH TANK

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-594-9 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,530 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, SETTLING #37

DRAFT

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-598-46 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
43,000 BBL FIXED ROOF SURGE TANK #5 (STATION 36) WITH GAS BLANKETING AND VAPOR CONTROL SYSTEM INCLUDING SULFUR REMOVAL SYSTEM AND DISCHARGING TO STATION 36 TVR SYSTEM OR DOGGR APPROVED VAPOR DISPOSAL WELLS

DRAFT

PERMIT UNIT REQUIREMENTS

1. Tank shall only be vented to vapor control system shared with crude oil processing tanks #S-1131-608, '-613, '-629, '-630, '-638, '-641, '-650, '-651 and '-1097; with collected vapors discharging to steam generators S-1131-82, '-95, '-98, '-99, '-859, DOGGR approved disposal well(s),or vapor control system listed on S-1131-885. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Sulfatreat system shall be located downstream of sampling point used for verification that gas processed by tank S-1131-598 contains < 10% VOC by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District NSR Rule] Federally Enforceable Through Title V Permit
4. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
5. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. Permittee shall maintain records of components exempted from counting, and the basis for exemption. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 113.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The fugitive VOC emission rate does not include piping and components handling produced fluids with API gravity less than 30 degrees. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The fugitive VOC emission rate does not include piping and components handling produced fluids having less than 10% VOC by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The fugitive VOC emission rate does not include components in water/oil service (water content of fluids handled greater than 50%). Permittee shall maintain records of annual testing to demonstrate that such fluid streams have at least 50% water by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Operator shall conduct quarterly sampling from the tank vapor control system's emergency gas exhaust header sample point to qualify for exemption from fugitive component counts for components handling fluids with less than 10% VOC by weight. If 8 consecutive quarterly samplings show compliance, then sampling frequency shall only be required annually. Such sampling is deemed representative of tanks S-1131-608, -613, -629, -630, -638, -641, -650, -651, and -1097. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

11. VOC content of vapor shall be determined by ASTM D1945, ASTM D1946, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201] Federally Enforceable Through Title V Permit

12. Permittee shall maintain a written record of the VOC content of the gas sampled. [District Rule 2201] Federally Enforceable Through Title V Permit

13. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit

14. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit

15. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

16. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

17. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

18. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit

19. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit

20. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

21. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit

23. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit

24. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit

25. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit

26. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit

27. When a D.O.G.G.R. disposal well is changed, or a new well is added, permittee shall provide District with a copy of D.O.G.G.R. approval for each vapor disposal well prior to use for vapor injection. [District Rules 1070; and 2520] Federally Enforceable Through Title V Permit

28. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520] Federally Enforceable Through Title V Permit

29. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

30. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

31. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

33. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

34. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

36. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

37. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

38. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

39. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-599-9

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED-ROOF CRUDE OIL WASH TANK #1-A AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-600-5

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,920 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #6600 S OT

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-601-5

EXPIRATION DATE: 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,920 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #6600 N OT

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-602-5

EXPIRATION DATE: 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, N. PROCESS WASH TANK

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-603-9

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,470 BBL FIXED-ROOF CRUDE OIL SETTLING TANK #43 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-606-9 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

DRAFT

EQUIPMENT DESCRIPTION:
4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #42 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-608-24

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
10,000 BBL 55' DIA X 24' HIGH FIXED ROOF CRUDE OIL PRODUCTION TANK, SHIPPING #41 (STATION 36) VENTED TO VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. Tank is authorized to receive fluids from station 36 "Surge" tanks receiving production from steam-enhanced wells with closed well casing vents. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
4. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 6.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Tank roof, tank shell, tank vapor space appurtenances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-610-9

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,530 BBL FIXED ROOF CRUDE OIL SETTLING TANK #20 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-613-22

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
10,000 BBL 55' DIA X 24' HIGH FIXED ROOF CRUDE OIL PRODUCTION TANK, SHIPPING #40 (STATION 36) VENTED TO VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. Tank is authorized to receive fluids from station 36 "Surge" tanks receiving production from steam-enhanced wells with closed well casing vents. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
4. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 5.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Tank roof, tank shell, tank vapor space appurtenances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-615-9 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #2-B AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

DRAFT

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-619-9

EXPIRATION DATE: 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #1-B AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-620-9 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #2 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

DRAFT

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-621-9

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #45 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-622-5

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
52,460 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #60GK2

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-623-9

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #44 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-625-9 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

DRAFT

EQUIPMENT DESCRIPTION:
4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #46 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-626-9

EXPIRATION DATE: 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-2 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-627-9

EXPIRATION DATE: 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-3 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-628-9

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-1 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-629-14 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
37,600 BBL FIXED ROOF CRUDE SURGE TANK #6 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

DRAFT

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 6.6 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Tank roof, tank shell, tank vapor space appurtenances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-630-14 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
1,579,200 GALLON FIXED ROOF CRUDE SURGE TANK #7 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

DRAFT

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 5.9 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Tank roof, tank shell, tank vapor space appurtenances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-631-9

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #1 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-632-9

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-5 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-633-9

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-6 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-634-9

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-4 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-635-9 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #2-A AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

DRAFT

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-636-5

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
10,570 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #10000 SHIP

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-638-14 **EXPIRATION DATE:** 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
37,600 BBL FIXED ROOF CRUDE SURGE TANK #2 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 7.4 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Tank roof, tank shell, tank vapor space appurtenances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-641-14

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
37,600 BBL FIXED ROOF CRUDE SURGE TANK #1 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 6.1 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Tank roof, tank shell, tank vapor space appurtenances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-650-14

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
37,600 BBL FIXED ROOF CRUDE SURGE TANK #4 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 7.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Tank roof, tank shell, tank vapor space appurtenances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-651-14

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
37,600 BBL FIXED ROOF CRUDE SURGE TANK #3 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 7.7 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Tank roof, tank shell, tank vapor space appurtenances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-652-5

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
54,460 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #60GK1

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-663-5

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
250 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #TK2-4

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-716-24 **EXPIRATION DATE:** 02/28/2017

DRAFT

EQUIPMENT DESCRIPTION:
TEOR OPERATION WITH 12607 STEAM ENHANCED OIL PRODUCTION WELLS WITH CLOSED CASING VENTS PRODUCING TO TANKS WITH VAPOR CONTROL

PERMIT UNIT REQUIREMENTS

1. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Steam-enhanced production wells with closed well casing vents shall each have a visible identification number. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Total number of well casing and casing vent leaks from steam-enhanced oil production wells in this TEOR operation shall not exceed one leak detected for each 20 wells tested. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit
4. Permittee shall maintain accurate component count according to EPAs "Protocol for Equipment Leak Emission Estimate," Table 2-4, Oil and Gas Production Operations Average Emission Factors. Permittee shall update such records when new components are approved and installed. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Maximum VOC content of the gas in the wells shall not exceed 87% by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Operator shall test the VOC content of representative well gas no less than annually. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Volatile organic compound (VOC) emission rate shall not exceed 8,142.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Component screening shall be performed using a portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Reference Method 21. [District Rule 4401, 6.3.3] Federally Enforceable Through Title V Permit
9. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
11. The inspection requirements of Section 5.4.1 through Section 5.4.7 of Rule 4401 shall not apply to components exclusively handling gas/vapor or liquid with a VOC content of ten percent by weight (10%) or less, as determined by the test methods in Section 6.3.4 of Rule 4401. [District Rule 4401, 4.7] Federally Enforceable Through Title V Permit
12. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401, 3.20] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: (1)The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or gauge tanks as defined in Rule 4401. The well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. (2) The steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1 and 5.1] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit
15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit
16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
21. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401 5.5] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
29. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

35. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

37. Records of VOC content of gas shall be maintained and made readily available for District inspection upon request for a period of five years. [District Rule 2201] Federally Enforceable Through Title V Permit

38. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401 6.1] Federally Enforceable Through Title V Permit

39. The results of gauge tank TVP testing conducted pursuant to Section 6.2.3 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

40. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

41. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. A process system as defined in Section 3.30 of Rule 4401 is not subject to compliance source testing requirements. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

42. If approved by the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection are controlled by an internal combustion engine subject to Rule 4702, a combustion device subject to Rule 4320, 4307 or 4308, a flare subject to Rule 4311. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

43. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.0 of Rule 4401: Conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.9 of Rule 4401. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

44. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

45. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

46. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

47. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

48. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401, 6.4] Federally Enforceable Through Title V Permit

49. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401, 6.1 and 6.5] Federally Enforceable Through Title V Permit

50. Operator shall keep a list of all gauge tanks, as defined in Section 3.0 of Rule 4401. The list shall contain the size, identification number, the location of each gauge tank and specify whether the gauge tank is upstream of all front line production equipment. [District Rule 4401, 6.1 and 6.6] Federally Enforceable Through Title V Permit

51. By January 30 of each year, an operator shall submit to the APCO for approval, in writing, an annual report indicating any changes to an existing Operator Management Plan. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

52. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 2201 and 4401, 6.1] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-724-7

EXPIRATION DATE: 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
GASOLINE DISPENSING OPERATION WITH TWO 10,000 GALLON UNDERGROUND STORAGE TANKS SERVED BY OPW PHASE I ENHANCED VAPOR RECOVERY SYSTEM (VR-102-A), AND THREE FUELING POINTS WITH THREE GASOLINE DISPENSING NOZZLES SERVED BY HEALY PHASE II ENHANCED VAPOR RECOVERY SYSTEM WITHOUT ISD (VR-201-E) (KERN RIVER)

PERMIT UNIT REQUIREMENTS

1. The permittee shall store or dispose of gasoline in closed, non-leaking containers. The containers shall remain closed at all times except when depositing or removing the contents of the containers or when the container is empty. [District Rule 4621, 5.6] Federally Enforceable Through Title V Permit
2. The vapor recovery systems and their components shall be installed, operated, and maintained in accordance with the State certification requirements. [District Rules 4621, 5.2; and 4622, 5.1] Federally Enforceable Through Title V Permit
3. The Phase I and Phase II vapor recovery systems shall be installed and maintained in accordance with the manufacturer specifications and the ARB Executive Orders specified in this permit, including applicable rules and regulations of the Division of Measurement Standards of the Department of Food and Agriculture, the Office of the State Fire Marshal of the Department of Forestry and Fire Protection, the Division of Occupational Safety and Health of the Department of Industrial Relations, and the Division of Water Quality of the State Water Resources Control Board that have been made conditions of the certification. [District Rules 4621, 5.2; and 4622, 5.1] Federally Enforceable Through Title V Permit
4. Each ARB certified vapor recovery system shall be tested within 60 days of major modification or installation, except as otherwise allowed by this permit. For this condition, a major modification is considered to be replacing, repairing, or upgrading 75% or more of the certified system. [District Rule 4622, 6.4] Federally Enforceable Through Title V Permit
5. The ARB certified vapor recovery system and all of its components shall be maintained in good repair. Any ARB certified gasoline vapor recovery system, which has been installed and has been issued a permit to operate, shall not be removed regardless of the amount of gasoline dispensed or how the gasoline is delivered to the facility. [District Rule 4622, 5.2] Federally Enforceable Through Title V Permit
6. No owner or operator shall tamper with, or permit tampering with, the ARB certified vapor recovery system in a manner that would impair the operation or effectiveness of the system. [District Rule 4622, 5.9] Federally Enforceable Through Title V Permit
7. All nozzles shall be equipped with coaxial hose configurations. [District Rule 4622, 5.1] Federally Enforceable Through Title V Permit
8. Each gasoline storage tank shall be equipped with a permanent submerged fill pipe. [District Rule 4621, 5.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Each storage tank subject to this permit shall be equipped with an ARB certified Phase I vapor recovery system, which shall prevent at least 95% by weight of all gasoline vapors displaced during the filling of storage tanks from entering the atmosphere. The transfer of gasoline from any delivery vessel to any stationary storage container with 250 gallon capacity or more shall not be allowed unless the container is equipped with an ARB certified Phase 1 system and maintained and operated according to manufacturers specifications. [District Rule 4621, 5.2] Federally Enforceable Through Title V Permit

10. Each dispensing system shall be equipped with an ARB certified Phase II vapor recovery system which shall prevent at least 95% by weight of all gasoline vapors displaced during refueling of vehicles from entering the atmosphere. [District Rule 4622, 5.1] Federally Enforceable Through Title V Permit

11. This gasoline storage and dispensing equipment shall not be used in retail sales, where gasoline dispensed by the unit is subject to payment of California sales tax on gasoline sales. [District Rules 4622, 3.25; and 2520, 9.1] Federally Enforceable Through Title V Permit

12. No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo tank which attest to the vapor integrity of the tank. [District Rule 4621, 5.7] Federally Enforceable Through Title V Permit

13. No person shall top off a motor vehicle fuel tank. [District Rule 4622, 5.6] Federally Enforceable Through Title V Permit

14. No gasoline shall be transferred into vehicle fuel tanks if the vapor recovery system contains any defect listed in Section 94006 of Title 17 of the California Code of Regulations or in Section 5.4 of SJVUAPCD Rule 4622 (as amended February 17, 1994) until the defect has been repaired, replaced, or adjusted as necessary to correct the defect, and the District has reinspected the system or has authorized its use pending reinspection. [District Rule 4622, 5.4] Federally Enforceable Through Title V Permit

15. No person shall operate any ARB certified Phase II vapor recovery system or any portion thereof that has a major defect or an equipment defect that is identified in any applicable ARB Executive Order until the following conditions have been met: 1) the defect has been repaired, replaced, or adjusted as necessary to correct the defect; 2) the District has been notified, and the District has reinspected the system or authorized the system for use (such authorization shall not include the authority to operate the equipment prior to the correction of the defective components); and 3) all major defects, after repair, are duly entered into the Operations and Maintenance (O&M) manual. [District Rule 4622, 5.4] Federally Enforceable Through Title V Permit

16. Any defects identified shall be tagged "Out of Order"; the tagged equipment shall be rendered inoperable and the tag(s) shall not be removed until the defect has been repaired, replaced or adjusted. In the case of defects identified by the District, tagged equipment shall be rendered inoperable and the tag shall not be removed until the District has been notified of the repairs, and/or the District has inspected and authorized the tagged equipment for use. A log containing at least the following shall be maintained: date and type of defect identified and date repaired, replaced or corrected. [District Rules 4622, 5.4] Federally Enforceable Through Title V Permit

17. A person performing installation of, or maintenance on, a certified Phase I or Phase II vapor recovery system shall be certified by the ICC for Vapor Recovery System Installation and Repair, or work under the direct and personal supervision of an individual physically present at the work site who is certified. The ICC certification shall be renewed every 24 months. [District Rules 4621, 6.3; and 4622, 5.2] Federally Enforceable Through Title V Permit

18. Proof of the ICC certification and all other certifications required by the Executive Order and installation and operation manual shall be made available onsite. [District Rules 4621, 6.3; and 4622, 5.2] Federally Enforceable Through Title V Permit

19. A person conducting testing of, or repairs to, a certified vapor recovery system shall be in compliance with District Rule 1177 (Gasoline Dispensing Facility Tester Certification). [District Rules 4621, 6.3 and 4622, 6.4] Federally Enforceable Through Title V Permit

20. The permittee shall conduct all periodic vapor recovery system performance tests specified in this permit, no more than 30 days before or after the required compliance testing date, unless otherwise required under the applicable ARB Executive Order. [District Rules 4621, 5.3; and 4622, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

21. The permittee shall notify the District at least 7 days prior to each performance test. The test results shall be submitted to the District no later than 30 days after the completion of each test. [District Rule 4621, 6.2] Federally Enforceable Through Title V Permit

22. The permittee shall perform and pass a Dynamic Back Pressure Test using ARB TP-201.4 at least once every 12 months. [District Rule 4622, 6.4, 6.5] Federally Enforceable Through Title V Permit

23. The permittee shall perform and pass a Static Leak Test for Underground Tanks using ARB TP-201.3 in accordance with the Executive Order specified in this permit for the Phase II Vapor Recovery System at least once every 12 months. [District Rules 4621, 5.3; and 4622, 6.4, 6.5] Federally Enforceable Through Title V Permit

24. The permittee shall perform and pass a Vapor-to-Liquid Volume Ratio Test using the test procedure defined in the Executive Order specified in this permit for the Phase II Vapor Recovery System at least once every six (6) months. [District Rule 4622, 6.4, 6.5] Federally Enforceable Through Title V Permit

25. The permittee shall perform and pass a Static Pressure Test for the Healy Clean Air Separator using the test procedure defined in the Executive Order specified in this permit for the Phase II Vapor Recovery System at least once every 12 months. [District Rule 4622, 6.4, 6.5] Federally Enforceable Through Title V Permit

26. The permittee shall perform and pass a Dispenser vapor Line Tightness test for each dispenser using the test procedure defined in the Installation, Operation and Maintenance manual of the Executive Order specified in this permit for the Phase II Vapor Recovery System at least once every 12 months. [District Rule 4622, 6.4, 6.5] Federally Enforceable Through Title V Permit

27. The permittee shall perform and pass a Pressure Integrity of Drop Tube Drain Valve Assembly Test using ARB TP-201.1C or a Pressure Integrity of Drop Tube Overfill Protection Devices Test using ARB TP-201.1D if an overfill protection device is installed, at least once every 36 months. [District Rule 4621, 5.3] Federally Enforceable Through Title V Permit

28. The permittee shall perform and pass a Static Torque of Rotatable Phase I Adaptors test using ARB procedure TP-201.1B at least once every 36 months. [District Rule 4621, 5.3] Federally Enforceable Through Title V Permit

29. The District shall be notified within 24 hours of the facility's pass/fail status after the performance of each test. [District Rule 1081] Federally Enforceable Through Title V Permit

30. The permittee shall maintain a copy of all test results. The test results shall be dated and shall contain the name, address, and telephone number of the company responsible for system installation and testing. [District Rules 4621, 6.1; and 4622, 6.2] Federally Enforceable Through Title V Permit

31. Vapor recovery systems and gasoline dispensing equipment shall be maintained leak-free as verified using EPA Test Method 21 and visual inspection. Leak testing shall be performed at least annually and within 60 days of all major modifications. For this condition, a major modification is considered to be replacing, repairing, or upgrading 75% or more of the certified system. A leak is defined as the dripping at a rate of more than three (3) drops per minute of liquid containing VOCs or a reading as methane in excess of 10,000 ppm as determined using EPA Method 21. [District Rules 4621, 3.19, 5.1, 5.6; and 4622, 3.17, 5.1, 5.6, 6.5] Federally Enforceable Through Title V Permit

32. Each operator shall maintain a leak inspection log containing, at a minimum, the following: inspector's name, location and description of component type where any leak is found; date of leak detection, emission level (ppm) if applicable, and date leak is repaired. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

33. Operator shall maintain all records of required monitoring data and support information for inspection for a period of five years. [District Rules 4621, 6.1; and 4622, 6.1, 6.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. The operator shall implement a periodic maintenance inspection program for the certified Phase II vapor recovery system consistent with Section 5.4 of Rule 4622. The program shall be documented in an operation and maintenance (O&M) manual and shall at a minimum contain the following information: 1) All applicable ARB Executive Orders, Approval Letters, and District Permits; 2) The manufacturer's specifications and instructions for installation, operation, repair, and maintenance required pursuant to ARB Certification Procedure CP-201, and any additional instruction provided by the manufacturer; 3) System and/or component testing requirements, including test schedules and passing criteria for each of the standard tests. The owner/operator may include any non-ARB required diagnostic and other tests as part of the testing requirements; 4) Protocol for performing periodic maintenance inspections including the components to be inspected and the defects requiring repair; and 5) Additional O&M instructions, if any, that are designed to ensure compliance with the applicable rules, regulations, ARB Executive Orders, and District permit conditions, including replacement schedules for failure or wear prone components. [District Rule 4622, 6.3] Federally Enforceable Through Title V Permit

35. The operator shall conduct periodic maintenance inspections based on the amount of gasoline dispensed by the facility in a calendar month as follows: A) less than 2,500 gallons - one day per month; B) 2,500 to less than 25,000 gallons - one day per week; or C) 25,000 gallons or greater - five days per week. All inspections shall be documented within the O & M Manual. [District Rules 4621, 5.5; and 4622, 5.3] Federally Enforceable Through Title V Permit

36. Periodic maintenance inspections of the Phase I vapor recovery system shall include, at a minimum, verification that 1) the fill caps and vapor caps are not missing, damaged, or loose; 2) the fill cap gasket and vapor cap gaskets are not missing or damaged; 3) the fill adapter and vapor adapter are securely attached to the risers; 4) where applicable, the spring-loaded submerged fill tube seals properly against the coaxial tubing; 5) the dry break (poppet-valve) is not missing or damaged; and 6) the submerged fill tube is not missing or damaged. [District Rule 4621, 5.5] Federally Enforceable Through Title V Permit

37. Periodic maintenance inspections of the Phase II vapor recovery system shall include, at a minimum, verification that 1) the fueling instructions required by this permit are clearly displayed with the appropriate toll-free complaint phone number and toxic warning signs; 2) the following nozzle components are in place and in good condition as specified in ARB Executive Order as applicable: faceplate/facecone, bellows, latching device spring, vapor check valve, spout (proper diameter/vapor collection holes), insertion interlock mechanism, automatic shut-off mechanism, and hold open latch (unless prohibited by law or the local fire control authority); 3) the hoses are not torn, flattened or crimped; 4) the vapor path of the coaxial hoses associated with bellows equipped nozzles does not contain more than 100 ml of liquid if applicable; and 5) the vapor processing unit is functioning properly, for operations that are required to have or possess such a unit. [District Rule 4622, 5.3] Federally Enforceable Through Title V Permit

38. In the event of a separation due to a drive off, the permittee shall, unless otherwise specified in the applicable ARB Executive Order, conduct a visual inspection of the affected equipment and either 1) perform qualified repairs on any damaged components and conduct applicable re-verification tests pursuant to the requirements of this permit, or 2) replace the affected nozzles, coaxial hoses, breakaway couplings, and any other damaged components with new or certified rebuilt components that are ARB certified. The activities shall be documented in accordance with the requirements of this permit before placing the affected equipment back in service. [District Rule 4622, 5.4] Federally Enforceable Through Title V Permit

39. The gasoline throughput for this permit unit shall not exceed 600,000 gallons in any one calendar year. [District Rule 4622, 5.2] Federally Enforceable Through Title V Permit

40. The operator shall maintain monthly and annual gasoline throughput records. [District Rules 4621, 6.1; and 4622, 6.2] Federally Enforceable Through Title V Permit

41. The operator shall maintain on the premises a log of any repairs made to the certified Phase I or Phase II vapor recovery system. The repair log shall include the following: 1) date and time of each repair; 2) the name of the person(s) who performed the repair, and if applicable, the name, address and phone number of the person's employer; 3) description of service performed; 4) each component that was repaired, serviced, or removed; 5) each component that was installed as replacement, if applicable; and 6) receipts or other documents for parts used in the repair and, if applicable, work orders which shall include the name and signature of the person responsible for performing the repairs. [District Rule 4622, 6.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

42. The O&M manual shall be kept at the dispensing operation and made available to any person who operates, inspects, maintains, repairs, or tests the equipment at the operation as well as to District personnel upon request. [District Rule 4622, 6.3] Federally Enforceable Through Title V Permit

43. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4621 (as amended December 20, 2007), and 4622 (as amended December 20, 2007). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

44. This unit is not associated with loading at a bulk gasoline terminal (as defined in 40 CFR 60.501). Therefore, the requirements of 40 CFR 60 Subparts XX do not apply to this permit unit. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-833-4

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NW5 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
240 BHP DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. {2413} No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101, 5.1] Federally Enforceable Through Title V Permit
2. {2414} Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
3. The engine shall be equipped with a positive crankcase ventilation (PCV) system or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 5.7.4 and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702, 5.7.2] Federally Enforceable Through Title V Permit
6. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [17 CCR 93115]
8. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rule 4702, 4.2.1] Federally Enforceable Through Title V Permit
9. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702, 5.7.3] Federally Enforceable Through Title V Permit
10. On and after January 1, 2015, the permittee must collect and submit an annual report including location, dates and times of operation if the engine operates for more than 15 hours and up to 100 hours per year for emergency demand response. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit
11. Permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. The engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

13. The engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

14. The engine's air filter shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

15. The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

16. The permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

17. The permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Base Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Base Number is less than 30 percent of the Total Base Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

18. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.), and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 4702, 5.7 and 2520, 9.4.2 and 17 CCR 93115] Federally Enforceable Through Title V Permit

19. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [District Rule 2520, 9.4.2 and 17 CCR 93115] Federally Enforceable Through Title V Permit

20. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 4702, 2520, 9.4.2, 17 CCR 93115, and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-858-17

EXPIRATION DATE: 02/28/2017

SECTION: SE29 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED NATIONAL STEAM GENERATOR (50-43; DIS# 20628-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN MODEL #5131-HGCR-62.5 BURNER, AND NORTH AMERICAN OPTIMIZER (CANFIELD)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
6. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
7. Emission rates shall not exceed the following PM10: 0.109 lb/MMBtu, SOx (as SO2): 1.026 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.006 lb/MMBtu, and CO: 0.029 lb/MMBtu or 39 ppmv @ 3% O2. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
8. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the vapor recovery gas incinerated in this unit. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
9. Permittee shall measure and record the natural gas sulfur content and BTU content at the time of NOx testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
10. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

11. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

12. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

13. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

14. Compliance demonstration (source testing) shall be conducted by independent testing laboratories and shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

17. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 100 and EPA Method 19, fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans, or other test methods approved by the District. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

18. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

19. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

20. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

21. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3 and Kern County Rules 404 and 408] Federally Enforceable Through Title V Permit

22. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

27. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

29. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

36. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-859-18

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (50-51; DIS# 19161- 75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and vapor recovery gas from the vapor control system listed on permit unit PTO S-1131-598 that has a combined fuel sulfur content not exceeding 5 gr S/100 scf unless SOx is reduced by 95% or to an outlet concentration not exceeding 9 ppmv via scrubbing. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu; 1.026 lb-SOx/MMBtu; or 0.006 lb-VOC/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 39 ppmvd CO @ 3% O2 or 0.029 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 43.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
7. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
8. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
9. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

14. An analysis of the fuel sulfur content may be submitted for compliance with the SOx requirement in lieu of the source test for SOx. [District Rules 2201and 4320] Federally Enforceable Through Title V Permit

15. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit

16. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Permittee shall submit an analysis showing the fuel's sulfur content or conduct a source test for SOx at least once every 12 months. [District Rule 4320, 5.7] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
27. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
30. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-877-24 **EXPIRATION DATE:** 02/28/2017

SECTION: NW05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MM BTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STRUTHERS STEAM GENERATOR (#46) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (MONTE CRISTO 1)

DRAFT

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
7. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-903, S-1131-909 and S-1131-1040. The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
8. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
9. Emission rates shall not exceed any of the following limits: 0.0768 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 28 ppmvd CO @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 31.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

13. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

15. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

16. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

17. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

24. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320] Federally Enforceable Through Title V Permit

25. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

26. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4320] Federally Enforceable Through Title V Permit

30. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

31. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

32. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

33. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

35. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

36. Formerly S-1143-3.

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-879-25

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE13 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (#70) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (CENTRAL PLANT)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.013 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit
12. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit
16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320]

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, and 4320] Federally Enforceable Through Title V Permit

24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

28. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. Formerly S-1143-5.

30. {4194} Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

31. {4314} Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-880-18

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (#140) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (CENTRAL PLANT)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 41 ppmvd CO @ 3% O2 or 0.030 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
4. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 45.0 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Each fuel source shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
8. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

11. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

12. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

13. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit

15. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

18. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320]

19. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

27. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

28. Formerly S-1143-6.

29. {4194} Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

30. {4314} Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-881-19 **EXPIRATION DATE:** 02/28/2017

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (#141) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (CENTRAL PLANT)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
8. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

11. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

12. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

13. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 2201 and 1081] Federally Enforceable Through Title V Permit

15. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

18. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier . [District Rule 4320]

19. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, and 4320] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
26. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
27. Formerly S-1143-6.
28. {4194} Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]
29. {4314} Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-883-19

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: 4 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MM BTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (#143) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (CENTRAL PLANT)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.013 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rules 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 41 ppmvd CO @ 3% O2 or 0.03 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 45.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit
12. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit
16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

28. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. Formerly S-1143-9.

30. {4194} Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

31. {4314} Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-884-21

EXPIRATION DATE: 02/28/2017

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MM BTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (#144) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (CENTRAL PLANT)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.013 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rules 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit
12. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit
16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

28. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. Formerly S-1143-10.

30. {4194} Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

31. {4314} Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-885-31 **EXPIRATION DATE:** 02/28/2017

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK #3K-L75 WITH VAPOR CONTROL SYSTEM

DRAFT

PERMIT UNIT REQUIREMENTS

1. Well vent vapor control systems S-1131-716 and S-1131-598 may discharge vapors into compressor suction of this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. Permittee shall maintain records of components exempted from counting, and the basis for exemption. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rates shall be calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 and the total number of vapor components. [District Rule 2201] Federally Enforceable Through Title V Permit
5. VOC emission rate from components associated with vapor recovery trunk-line up to and including vapor compressors and approved disposal devices shall not exceed 23.9 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. VOC emission rate from vapor service components associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 5.33 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The fugitive VOC emission rate does not include piping and components handling produced fluids with API gravity less than 30 degrees. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The fugitive VOC emission rate does not include piping and components handling produced fluids having less than 10% VOC by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The fugitive VOC emission rate does not include components in water/oil service (water content of fluids handled greater than 50%). Permittee shall maintain records of annual testing to demonstrate that such fluid streams have at least 50% water by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Operator shall conduct quarterly sampling from the tank vapor control system's inlet header to qualify for exemption from fugitive component counts for components handling fluids with less than 10% VOC by weight. If 8 consecutive quarterly samplings show compliance, then sampling frequency shall only be required annually. Such sampling is deemed representative of tanks S-1131-608, -613, -629, -630, -638, -641, -650, -651, and -1097. [District Rule 2201] Federally Enforceable Through Title V Permit
11. VOC content of vapor shall be determined by ASTM D1945, ASTM D1946, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

12. Permittee shall maintain a written record of the VOC content of the gas sampled. [District Rule 2201] Federally Enforceable Through Title V Permit

13. Collected VOC vapors shall be incinerated in steam generators S-1131-82, '-95, '-98, '-99, '-859, '-877, '-879, '-880, '-881, '-883, '-884, and '908 or disposed of in Department of Oil, Gas, and Geothermal Resources (DOGGR) approved vapor disposal well(s). [District Rule 2201] Federally Enforceable Through Title V Permit

14. Fluids stored or handled by tank shall be routed exclusively to the vapor-controlled "Surge" tanks at Station 36 (S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097). [District Rule 2201] Federally Enforceable Through Title V Permit

15. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

16. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 2080] Federally Enforceable Through Title V Permit

17. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 2080] Federally Enforceable Through Title V Permit

18. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 2080] Federally Enforceable Through Title V Permit

19. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 2080] Federally Enforceable Through Title V Permit

20. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

21. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

22. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 2080] Federally Enforceable Through Title V Permit

23. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 2080] Federally Enforceable Through Title V Permit

25. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit

26. Tank roof, tank shell, tank vapor space appurtances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit

27. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

28. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

29. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

30. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit

31. True vapor pressure of any liquid introduced in this permit unit shall be less than 0.5 psia at (or before) tank liquid inlet and at tank storage temperature. [District Rule 4623] Federally Enforceable Through Title V Permit

32. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

33. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit

34. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "Test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

35. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
36. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
37. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
38. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
39. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
40. Permittee shall provide District with a copy of D.O.G.G.R. approval for each vapor disposal well prior to use for vapor injection. [District Rule 1070] Federally Enforceable Through Title V Permit
41. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules1070 and 4623] Federally Enforceable Through Title V Permit
42. Formerly S-1143-21. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-886-23 **EXPIRATION DATE:** 02/28/2017

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK #3K-S76 WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-885

DRAFT

PERMIT UNIT REQUIREMENTS

1. Well vent vapor control system S-1131-716 may discharge vapors into compressor suction of this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. VOC emission rate from vapor service components associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 5.33 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Permittee shall maintain an accurate fugitive component count and resultant emissions calculated using emission factors from U.S. EPA Publication 453/R-95-017, or other District-approved emission factors. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Steam generators authorized to incinerate collected VOC vapors are S-1131-877,'-880, '-881, '-882, '-883, and '-908. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Fluids stored or handled by tank shall be routed exclusively to the vapor-controlled "Surge" tanks at Station 36 (S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097). [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit
8. This tank shall be degassed before commencing interior cleaning by one of the following methods (1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less; or (2) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water. or produced water derived from crude oil having a TVP less than 0.5 psia; or (3) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 2080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 2080] Federally Enforceable Through Title V Permit
10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 2080] Federally Enforceable Through Title V Permit
11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 2080] Federally Enforceable Through Title V Permit
12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit
13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit
14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 2080] Federally Enforceable Through Title V Permit
15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 2080] Federally Enforceable Through Title V Permit
16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rules 2020 and 2080] Federally Enforceable Through Title V Permit
17. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Tank roof, tank shell, tank vapor space appurtances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit
19. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
22. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
23. True vapor pressure of any liquid introduced in this permit unit shall be less than 0.5 psia at (or before) tank liquid inlet and at tank storage temperature. [District Rule 4623] Federally Enforceable Through Title V Permit
24. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit
25. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
26. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
27. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
28. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
29. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
30. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
31. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Permittee shall provide District with a copy of D.O.G.G.R. approval for each vapor disposal well prior to use for vapor injection. [District Rule 1070] Federally Enforceable Through Title V Permit
33. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rules 1070 and 4623] Federally Enforceable Through Title V Permit
34. Formerly S-1143-22. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-891-22

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-885

PERMIT UNIT REQUIREMENTS

1. Well vent vapor control system S-1131-716 may discharge vapors into compressor suction of this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. VOC emission rate from vapor service components associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 5.33 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Permittee shall maintain an accurate fugitive component count and resultant emissions calculated using emission factors from U.S. EPA Publication 453/R-95-017, or other District-approved emission factors. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Steam generators authorized to incinerate collected VOC vapors are S-1131-877,'-880, '-881, '-882, '-883, and '-908. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Fluids stored or handled by tank shall be routed exclusively to the vapor-controlled "Surge" tanks at Station 36 (S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097). [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit
8. This tank shall be degassed before commencing interior cleaning by one of the following methods (1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less; or (2) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water. or produced water derived from crude oil having a TVP less than 0.5 psia; or (3) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 2080] Federally Enforceable Through Title V Permit
10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 2080] Federally Enforceable Through Title V Permit
11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 2080] Federally Enforceable Through Title V Permit
12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit
13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit
14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 2080] Federally Enforceable Through Title V Permit
15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 2080] Federally Enforceable Through Title V Permit
16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rules 2020 and 2080] Federally Enforceable Through Title V Permit
17. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Tank roof, tank shell, tank vapor space appurtances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit
19. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
22. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
23. True vapor pressure of any liquid introduced in this permit unit shall be less than 0.5 psia at (or before) tank liquid inlet and at tank storage temperature. [District Rule 4623] Federally Enforceable Through Title V Permit
24. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit
25. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
26. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
27. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
28. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
29. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
30. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
31. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Permittee shall provide District with a copy of D.O.G.G.R. approval for each vapor disposal well prior to use for vapor injection. [District Rule 1070]
33. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rules 1070 and 4623] Federally Enforceable Through Title V Permit
34. Formerly S-1143-27. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-892-22

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-885

PERMIT UNIT REQUIREMENTS

1. Well vent vapor control system S-1131-716 may discharge vapors into compressor suction of this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. VOC emission rate from vapor service components associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 5.33 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Permittee shall maintain an accurate fugitive component count and resultant emissions calculated using emission factors from U.S. EPA Publication 453/R-95-017, or other District-approved emission factors. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Steam generators authorized to incinerate collected VOC vapors are S-1131-877,'-880, '-881, '-882, '-883, and '-908. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Fluids stored or handled by tank shall be routed exclusively to the vapor-controlled "Surge" tanks at Station 36 (S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097). [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit
8. This tank shall be degassed before commencing interior cleaning by one of the following methods (1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less; or (2) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water. or produced water derived from crude oil having a TVP less than 0.5 psia; or (3) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 2080] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 2080] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 2080] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 2080] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 2080] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rules 2020 and 2080] Federally Enforceable Through Title V Permit

17. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit

18. Tank roof, tank shell, tank vapor space appurtances, vapor control system piping, and vapor control system components shall be inspected and monitored using EPA Method 21 at least monthly. Items found to be not leaking may then be inspected and monitored at least once every 3 months until a leak is detected at which time the inspection and monitoring frequency shall revert to monthly until such time that two consecutive monthly inspections reveal with no leaks at which time the inspection and monitoring frequency shall revert to at least once every 3 months. [District Rule 2201] Federally Enforceable Through Title V Permit

19. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

20. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
22. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
23. True vapor pressure of any liquid introduced in this permit unit shall be less than 0.5 psia at (or before) tank liquid inlet and at tank storage temperature. [District Rule 4623] Federally Enforceable Through Title V Permit
24. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit
25. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
26. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
27. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
28. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
29. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
30. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
31. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Permittee shall provide District with a copy of D.O.G.G.R. approval for each vapor disposal well prior to use for vapor injection. [District Rule 1070] Federally Enforceable Through Title V Permit
33. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rules 1070 and 4623] Federally Enforceable Through Title V Permit
34. Formerly S-1143-28. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-908-22

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: 4 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MM BTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (#71) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (CENTRAL PLANT)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.013 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit
12. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit
16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

28. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. Formerly S-1143-90.

30. {4194} Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

31. {4314} Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-912-10

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (#4) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND A FLUE GAS RECIRCULATION (CENTRAL PLANT)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.014 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
27. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
28. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit
29. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-943-21

EXPIRATION DATE: 02/28/2017

SECTION: 25 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (FEE A 2) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (FEE A)

PERMIT UNIT REQUIREMENTS

1. Annual fuel use shall not exceed 90 billion Btu. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
2. The operator shall fire the unit only on natural gas and vapor recovery gas that has a combined fuel sulfur content not exceeding 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.075 lb-PM10/MMBtu; or 0.007 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit.
5. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 45 ppmvd CO @ 3% O2 or 0.033 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. During start-up and shutdown periods, emissions from the natural gas/vapor recovery gas-fired steam generator shall not exceed either of the following limits: 0.1 lb/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 54.0 lb-NOx/day, 1,620 lb-NOx/year, 49.5 lb-CO/day, and 2,340 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 30 ppmvd NOx @ 3% O2 or 0.036 lb-NOx/MMBtu, and 45 ppmvd CO @ 3% O2 or 0.033 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

11. The shakedown period shall begin upon initial operation of this unit after implementation of the modification authorized by this ATC. The shakedown period shall be concluded within 60 days of initial operation and prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and all monitoring records as required by this permit starting on the date of initial operation. [District Rule 2201] Federally Enforceable Through Title V Permit

12. Each fuel source shall be tested semi-annually for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which semi-annual testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

13. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit

14. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

15. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

19. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

20. A source test to demonstrate compliance with NOx and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

22. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

25. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

30. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

31. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

33. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

34. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

35. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

36. Formerly permit number S-1133-21-11 and S-1109-682-0.

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-966-16

EXPIRATION DATE: 02/28/2017

SECTION: 30 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT EMISSIONS UNIT: 27.5 MMBTU/HR THERMOTICS VAPOR CONTROL/NATURAL GAS-FIRED STEAM GENERATOR #24 WITH FLUE GAS RECIRCULATION AMETEK THERMOX O2 CONTROLLER (FEE C)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. All combustion equipment shall be operated to maintain emission standards. [District Rule 2201] Federally Enforceable Through Title V Permit
5. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401] Federally Enforceable Through Title V Permit
6. Emission rates for this unit shall not exceed any of the following: PM-10: 0.070 lb/MMBTU, SOx (as SO2): 0.184 lb/MMBTU, NOx (as NO2): 0.036 lb/MMBTU or 30 ppmvd @3% O2, VOC: 0.007 lb/MMBTU, or CO: 0.033 lb/MMBTU or 45 ppmvd @3% O2. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
7. Compliance with the sulfur emissions limit (as SO2) may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 4301] Federally Enforceable Through Title V Permit
8. Fuel hhv for source test purposes shall be certified by a third party fuel supplier or determined using ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 1081] Federally Enforceable Through Title V Permit
9. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
10. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

11. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit
12. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit
13. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
14. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
15. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2201 and 4305] Federally Enforceable Through Title V Permit
17. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
18. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
19. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(Last Amended December 19,1993). [District Rule 1081, and Kern County Rule 108.1] Federally Enforceable Through Title V Permit
20. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. {588} Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
22. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

27. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

29. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

30. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

31. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

33. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

35. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

36. Formerly permit number S-1133-3-14 and S-1109-673-0.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-976-13

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE19 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 23 MMBTU/HR STRUTHERS GAS-FIRED STEAM GENERATOR (#13; DIS # 27537-66) WITH FLUE GAS RECIRCULATION AND OXYGEN CONTROLLER/ANALYZER (MCMANUS)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed: PM10; 0.009 lb/MMBtu, SOx (as SO2); 0.005 lb/MMBtu, NOx (as NO2); 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC; 0.003 lb/MMBtu, or CO; 0.002 lb/MMBtu or 2.7 ppmv @ 3% O2. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
5. Except during periods of steam generator startup/shutdown, steam generator shall not be operated unless flue gas recirculation system is operating. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
6. Steam generator may be equipped with a programmable logic controller (PLC). [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
7. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
8. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
9. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
10. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
12. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
13. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
14. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
15. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The permittee shall maintain records of fuel type and quantity for each day of operation, in the format approved by the District. [District Rule 2201] Federally Enforceable Through Title V Permit
19. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1, 5.2.3 and Kern County Rules 404 and 408] Federally Enforceable Through Title V Permit
21. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit
22. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2, 4305, 6.2.1, and 4351, 6.2.1] Federally Enforceable Through Title V Permit

26. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

27. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

29. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

30. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

31. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

33. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

34. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. {1686} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

36. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

37. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

38. Formerly S-1109-2.

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-987-14 **EXPIRATION DATE:** 02/28/2017

SECTION: SE19 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR THERMOTICS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (R-3; DIS# 27474-81) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (RAMBLER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040. The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.044 lb-PM10/MMBtu or 0.005 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 31 ppmvd CO @ 3% O2 or 0.023 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 34.5 lb-CO/day and 12,593 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
7. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
8. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
9. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

14. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

18. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

20. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit

21. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

22. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

23. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit

24. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

27. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

28. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

29. Formerly S-1143-90.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-992-16

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE29 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR THERMOTICS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (ANO 3; DIS# 27472-81) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (ANO)

PERMIT UNIT REQUIREMENTS

1. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. The operator shall fire the unit only on PUC-quality natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.029 lb-PM10/MMBtu or 0.005 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 31 ppmvd CO @ 3% O2 or 0.023 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 34.5 lb-CO/day, and 12,593 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit
14. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
16. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit
18. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. Formerly S-1109-97.

32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-993-15

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE29 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (ANO 4; DIS# 28773-85) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (ANO)

PERMIT UNIT REQUIREMENTS

1. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201,4406, and 4320] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.0063 lb-PM10/MMBtu or 0.0042 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

14. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 2201 and 1081] Federally Enforceable Through Title V Permit

18. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. Formerly S-1109-104.

32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-994-14 **EXPIRATION DATE:** 02/28/2017

SECTION: SE09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (PL-8; DIS# 4322-78) WITH LO-NOX BURNER, OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (MCMANUS)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. Unit shall be exclusively gas/casing gas-fired and have no provisions for oil firing. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Testing for fuel gas and casing gas sulfur and BTU content shall be conducted no less than monthly. [District Rule 1081] Federally Enforceable Through Title V Permit
6. Emission rates shall not exceed: PM10; 0.045 lb/MMBtu, SOx (as SO2); 0.062 lb/MMBtu, NOx (as NO2); 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC; 0.005 lb/MMBtu, or CO; 26.7 ppmv @ 3% O2. [District Rules 2201, 4305 and 4351] Federally Enforceable Through Title V Permit
7. Except during periods of steam generator startup/shutdown, steam generator shall not be operated unless flue gas recirculation system is operating. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
8. Steam generator may be equipped with a programmable logic controller (PLC). [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
9. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
10. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
12. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
13. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
14. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
15. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
16. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 100 and EPA Method 19, fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans, or other test methods approved by the District. [District Rules 1081, 4305 and 4351] Federally Enforceable Through Title V Permit
17. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. Permittee shall maintain daily records of volume of fuel gas and casing gas burned, monthly fuel gas and casing gas sulfur content and BTU content, and source of casing gas. [District Rules 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(Last Amended December 19,1993). [District Rules 1081 and Kern County Rule 108.1] Federally Enforceable Through Title V Permit
22. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. {588} Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
24. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

25. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

27. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2, 4305, 6.2.1 and 4351, 6.2.1] Federally Enforceable Through Title V Permit

29. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

35. Nitrogen oxide (NOx) emission concentrations in ppmv shall be referenced at dry stack gas conditions, and shall be calculated to 3.00 percent by volume stack gas oxygen and averaged over 60 minutes, and lb/MMBtu rates shall be calculated as lb NO2/MMBtu of heat input (hhv). [District Rules 2520, 9.3.2, 4305, 5.0, 8.2 and/or 4351, 8.1] Federally Enforceable Through Title V Permit

36. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

37. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

38. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

39. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

40. Formerly S-1109-108.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-997-14

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE13 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR THERMOTICS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (ANGUS 2; DIS# 4509-81) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (ANGUS)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 gr S/100 scf. [District Rules 2201,4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.045 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 27 ppmvd CO @ 3% O2 or 0.02 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 30.0 lb-CO/day, and 10,950 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6]

12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

13. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 2201 and 1081] Federally Enforceable Through Title V Permit

17. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rules 4320]

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. Formerly S-1109-118.

31. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. {4194} Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

33. {4314} Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-998-15

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE25 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (FEE A 1; DIS# 39454-87) WITH NORTH AMERICAN GLE LOW NOX BURNERS, AND FLUE GAS RECIRCULATION (FEE A)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.007 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

13. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 2201 and 1081] Federally Enforceable Through Title V Permit

17. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320] Federally Enforceable Through Title V Permit

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. Permittee shall submit an analysis showing the fuel sulfur content (as H2S) by either EPA Method 11, 15, or ASTM D6228; total fuel sulfur content by either ASTM D1072, D3246, D6228 or double GC with mercaptans; or conduct a source test for SOx at least once 12 months. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. Formerly S-1109-121.

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-999-12

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE19 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (R-7; DIS# 12466-82) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (RAMBLER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 gr S/100 scf. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.007 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 25 ppmvd CO @ 3% O2 or 0.0185 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
7. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
8. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
9. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

14. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

18. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

20. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit

21. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

22. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

23. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit

24. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

27. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

28. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

29. Formerly S-1109-127.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1000-15 **EXPIRATION DATE:** 02/28/2017

SECTION: SE25 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (FEE A 3; DIS# 12468-82) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (FEE A)

DRAFT

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.0065 lb-PM10/MMBtu or 0.004 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

13. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

17. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. Formerly S-1109-128.

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1001-16

EXPIRATION DATE: 02/28/2017

SECTION: SE09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (ANO 1; DIS# 12467-82) WITH NORTH AMERICAN LOW NOX BURNER, AND FLUE GAS RECIRCULATION (ANO)

PERMIT UNIT REQUIREMENTS

1. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-1040. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.006 lb-PM10/MMBtu or 0.0041 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas and the outlet H2S concentration from Sulfa Check unit of on S-1131-1040 at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

14. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 2201 and 1081] Federally Enforceable Through Title V Permit

18. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. Formerly S-1109-129.

32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1002-16 **EXPIRATION DATE:** 02/28/2017

SECTION: SE31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (ANO 2; DIS# 39456-87) WITH A NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (ANO)

DRAFT

PERMIT UNIT REQUIREMENTS

1. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. The operator shall fire the unit only on natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.005 lb-SOx/MMBtu, 0.006 lb-PM10/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4320, and 4406] Federally Enforceable Through Title V Permit
5. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520 and Rule 4320] Federally Enforceable Through Title V Permit
10. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520 and Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit

12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520 and 4320] Federally Enforceable Through Title V Permit

13. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

17. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

20. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

26. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit

27. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

28. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

29. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

30. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, and 4320] Federally Enforceable Through Title V Permit

31. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

32. Formerly S-1109-135-14

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1003-15 **EXPIRATION DATE:** 02/28/2017

SECTION: SE25 **TOWNSHIP:** 28S **RANGE:** 27E

DRAFT

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (FEE A 4; DIS# 39455-87) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (FEE A)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.007 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.4 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

13. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

17. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. Formerly S-1109-136.

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1004-15

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NE29 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (ANO 5; DIS# 33743-90) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (ANO)

PERMIT UNIT REQUIREMENTS

1. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.007 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.4 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

14. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

18. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. Formerly S-1109-137.

32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1016-16

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SE13 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (ANGUS 1; DIS# 39751-90) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (ANGUS)

PERMIT UNIT REQUIREMENTS

1. {588} Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
2. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.045 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Except during startup and shutdown emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 27 ppmvd CO @ 3% O2 or 0.02 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 30 lb-CO/day, and 10,950 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rules 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

10. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

14. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

18. A source test to demonstrate compliance with NOx and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

19. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320] Federally Enforceable Through Title V Permit

22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC foR H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
32. Formerly S-1109-221-15.
33. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
34. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1036-13

EXPIRATION DATE: 02/28/2017

DRAFT

EQUIPMENT DESCRIPTION:
TEOR OPERATION WITH 885 THERMALLY ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. When the number of wells in operation exceeds 485, before any ground disturbance activities on the project site, a qualified registered biologist shall conduct a focused survey to determine the presence/absence of potential impacts on sensitive species on-site and riparian habitat. The survey shall be conducted in accordance with the standard protocol of California Department of Fish & Game (CDFG) and/or California Department of Fish & Game (CDFG). Chevron U.S.A., Inc will notify CDFG and the US Fish and Wildlife Service (USFWS) in the event a State or Federally listed species is encountered. Results of the survey shall be made available for District inspection upon request. [Public Resources Code 21000-21177: California Environmental Quality Act]
2. When the number of wells in operation exceeds 485, before any ground disturbance activities on the project site, a qualified registered biologist shall conduct a focused survey to determine the presence/absence of potential impacts on the movement of any native resident or migratory fish or wildlife species, corridors, or nursery sites. Chevron U.S.A., Inc will notify California Department of Fish & Game and the US Fish and Wildlife Service in the event a State or Federally listed species is encountered. Results of the survey shall be made available for District inspection upon request. [Public Resources Code 21000-21177: California Environmental Quality Act]
3. When the number of wells in operation exceeds 485, Chevron U.S.A., Inc shall notify the US Fish and Wildlife Service (USFWS) and the California Department of Fish & Game (CDFG) immediately in the event that the Project avoidance measures fail and there is a take of a threatened or endangered species. No activities shall occur until Incidental Take authorization has been obtained from USFWS and CDFG. Documentation demonstrating authorization shall be made available for District inspection upon request. [Public Resources Code 21000-21177: California Environmental Quality Act]

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

4. When the number of wells in operation exceeds 485, for Western Pond Turtle and American Badger: A qualified biological monitor will be present during project implementation. The biological monitor shall be notified immediately should the western pond turtle enter the project area and work shall be halted until there is no longer a potential to adversely impact the species. All vehicles and equipment entering the project area will be in good working condition and free from leaks. In the event that a vehicle or equipment item is found to be leaking fluid, operation of the vehicle or equipment item shall be terminated and it shall be repaired or replaced. If possible, repairs should be conducted in a contained area. All contaminated soil will be collected and properly disposed off the project site. To reduce the potential for direct and indirect impacts to American badger to a less-than-significant level, a qualified biologist will be retained prior to ground disturbing activities to conduct a pre-construction survey of the project area. The pre-construction survey would be conducted within the proposed project boundary and a buffer of 200 feet outside of the project footprint. If the preactivity survey indicates the presence of badger dens, they shall be classified as inactive, potentially active, or definitely active. (a) Inactive dens will be excavated by hand and backfilled to prevent reuse by badgers. (b) Potentially and definitely active dens will be monitored for three consecutive nights using a tracking medium (such as diatomaceous earth or fire clay) at the entrance. If no tracks or other sign are observed in the tracking medium at the conclusion of the three nights, the den will be excavated and backfilled by hand under the direction and supervision of a qualified biologist. If tracks are observed, the den will be progressively blocked with natural materials (dirt, sticks, and vegetation piled in front of the entrance) for the next three to five nights to discourage the badger from continued use. When a qualified biologist has determined that the den is no longer active, the den will be excavated and backfilled by hand to ensure that no badgers are trapped in the den. Results of the survey shall be made available for District inspection upon request. [Public Resources Code 21000-21177: California Environmental Quality Act]
5. When the number of wells in operation exceeds 485, Chevron U.S.A., Inc shall purchase sufficient credit from the Kern Water Bank Authority (KWBA) to mitigate for permanent and temporary habitat impacts. Documentation demonstrating the purchase shall be made available for District inspection upon request. [Public Resources Code 21000-21177: California Environmental Quality Act]
6. Total fugitive emission of volatile organic compounds (VOC) from entire operation shall not exceed 146.6 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts for well vent vapor control systems and resulting emissions calculated using CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c(Feb 1999) Screening Range emission factors. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to tanks vented to a District approved vapor collection and control system, or to permit exempt storage equipment as defined by Rule 2020, Section 6.6 (Amended August 18, 2011). [District Rule 2201] Federally Enforceable Through Title V Permit
9. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District Rule 2201] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
11. The inspection requirements of Section 5.4.1 through Section 5.4.7 of Rule 4401 shall not apply to components exclusively handling gas/vapor or liquid with a VOC content of ten percent by weight (10%) or less, as determined by the test methods in Section 6.3.4 of Rule 4401. [District Rule 4401, 4.7] Federally Enforceable Through Title V Permit
12. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401, 3.20] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1 and 5.1] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit
15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit
16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
21. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401 5.5] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
29. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

35. The operator shall maintain an inspection log that has been signed and dated by the facility operator responsible for the inspection, certifying the accuracy of the information recorded in the log. The inspection log shall contain, at a minimum, all of the following information: 1) The total number of components inspected, and the total number and percentage of leaking components found by component types; 2) The location, type, name or description of each leaking component and the description of any unit where the leaking component is found; 3) Date of the leak detection and method of the leak detection; 4) For gaseous leaks, record the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak; 5) The date of repair, replacement, or removal from operation of the leaking component(s); 6) The identification and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes first; 7) The method(s) used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier; 8) The date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced; 9) The inspector's name, business mailing address, and business telephone number. [District Rule 4401, 6.4] Federally Enforceable Through Title V Permit

36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

37. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401 6.1] Federally Enforceable Through Title V Permit

38. The results of gauge tank TVP testing conducted pursuant to Section 6.2.3 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

39. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

40. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. A process system as defined in Section 3.30 of Rule 4401 is not subject to compliance source testing requirements. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

41. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection are controlled by an internal combustion engine subject to Rule 4702, a combustion device subject to Rule 4320, 4307 or 4308, a flare subject to Rule 4311. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

42. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.0 of Rule 4401: Conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.9 of Rule 4401. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

43. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

44. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

45. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

46. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

47. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401, 6.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. The operator shall maintain an APCO approved Operator Management Plan (OMP). The OMP shall include, at a minimum, a description of all wells and all associated VOC collection and control systems subject to this rule, and all wells and all associated VOC collection and control systems that are exempt; an identification and description of any known hazard that might affect the safety of an inspector; except for pipes, the number of components that are subject to this rule by component type; except for pipes, the number and types of major components, inaccessible components, unsafe-to-monitor components, critical components, and essential components that are subject to this rule and the reason(s) for such designation; except for pipes, the location of components subject to the rule (components may be grouped together functionally by process unit or facility description); except for pipes, components exempt pursuant to Section 4.8 (except for components buried below ground) may be described in the OMP by grouping them functionally by process unit or facility description (the results of any laboratory testing or other pertinent information to demonstrate compliance with the applicable exemption criteria for components for which an exemption is being claimed pursuant to Sections 4.8 shall be submitted with the OMP); a detailed schedule of an operator's inspections of components to be conducted as required by this rule and whether the operator inspections of components required by this rule will be performed by a qualified contractor or by an in-house team; a description of the training standards for personnel that inspect and repair components; and a description of the leak detection training for conducting the test method specified in Section 6.3.3 for new operators, and for experienced operators, as necessary. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit

49. Operator shall keep a list of all gauge tanks, as defined in Section 3.0 of Rule 4401. The list shall contain the size, identification number, the location of each gauge tank and specify whether the gauge tank is upstream of all front line production equipment. [District Rule 4401, 6.1 and 6.6] Federally Enforceable Through Title V Permit

50. By January 30 of each year, an operator shall submit to the APCO for approval, in writing, an annual report indicating any changes to an existing Operator Management Plan. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

51. Records of wells constructed when wells in operation exceed 485 shall be maintained including location, construction start date and documentation required by California Environmental Quality Act conditions listed on this permit for a minimum of 5 years. [Public Resources Code 21000-21177: California Environmental Quality Act]

52. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

53. Formerly permit number S-1109-361-1.

DRAFT

San Joaquin Valley
Air Pollution Control District

EXPIRATION DATE: 02/28/2017

DRAFT

PERMIT UNIT: S-1131-1037-10

SECTION: NW10 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
249.0 MMBTU/HR (NOMINAL RATING), 20 MW GENERAL ELECTRIC GAS-FIRED TURBINE ENGINE COGENERATION SYSTEM WITH SCR, AMMONIA STORAGE AND DISTRIBUTION SYSTEM, CO CATALYTIC CONVERTER AND CEM SYSTEM FOR NOX, CO AND O2

PERMIT UNIT REQUIREMENTS

1. Cogeneration system shall include General Electric model LM-2500PE gas turbine, generator set rated at 22.89 MW, turbine combustor and compressor water injection systems, SCR, CO catalyst, and CEM's for NOx, CO, & O2. [40 CFR 64 and District Rule 2201] Federally Enforceable Through Title V Permit
2. Lube oil cooler/accumulator shall be equipped with device to prevent detectable emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Ammonia injection rate shall be controlled to maintain ammonia breakthrough to less than 20 ppmv. [District Rule 4102]
4. If water injection, SCR, or CO catalyst is inoperative, turbine shall be shut down. [District Rule 2201] Federally Enforceable Through Title V Permit
5. All turbine exhaust shall flow through both catalyst beds. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Gas turbine engine exhaust may be diverted to bypass stack during cold engine startup. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Gas turbine engine exhaust may be diverted to bypass stack under Rule 1100 (Equipment Breakdown), provided all applicable record keeping and reporting requirements of Rule 1100 are fulfilled. [District Rule 1100] Federally Enforceable Through Title V Permit
8. CEM equipment shall be maintained and calibrated according to EPA guidelines specified in CFR Part 60, Appendix B. [40 CFR 60.334 (b); 40 CFR 60; and District Rule 1080] Federally Enforceable Through Title V Permit
9. Except days with periods of startup/shutdown, emission rates shall not exceed any of the following: PM10: 77.7 lb/day, SOx (as SO2): 29.9 lb/day, NOx (as NO2): 110.0 lb/day, VOC: 239.0 lb/day, or CO: 160.8 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
11. Except during periods of startup/shutdown, emission rates shall not exceed any of the following: PM10: 0.013 lb/MMBTU, SOx (as SO2): 0.005 lb/MMBTU, or VOC: 0.040 lb/MMBTU. [40 CFR 60.333(a) and (b) and District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during periods of startup/shutdown, emission rates (3-hour rolling average) shall not exceed any of the following: NOx (as NO2): 0.018 lb/MMBTU or 5 ppmvd @ 15% O2, or CO: 12 ppmvd @ 15% O2. [District Rules 2201; and 4703, 5.1, 5.2, 5.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

13. NOx emission rate (one hour average) shall not exceed the NSPS standard of 150 ppmvd @ 15% O2. [40 CFR 60.332(a)] Federally Enforceable Through Title V Permit

14. Except during periods of gas turbine engine startup/shutdown, water injection rate shall be maintained at water-to-fuel ratio documented to achieve compliance with emission limits. [District Rule 2201] Federally Enforceable Through Title V Permit

15. Except during periods of gas turbine engine startup/shutdown, inlet gas temperature to both catalyst beds shall be maintained within the range as recommended by catalyst manufacturer. [District Rule 2201] Federally Enforceable Through Title V Permit

16. The duration of each startup or shutdown shall not exceed two hours. [40 CFR 60.2; and District Rule 4703, 5.3] Federally Enforceable Through Title V Permit

17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. [District Rule 4703, 3.29] Federally Enforceable Through Title V Permit

18. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.26] Federally Enforceable Through Title V Permit

19. Bypass transition period is defined as the duration of time that a gas turbine's operation transitions between the heat recovery steam generator and bypass exhaust stacks, provided that the SCR catalyst is not within the required temperature range or the required ammonia saturation level has not yet been achieved; and NOx emissions shall not exceed 15 ppmvd @ 15% O2 averaged over 2 hours; and the duration of a bypass transition period shall not exceed two hours except during black start period. [District Rule 4703, 3.2] Federally Enforceable Through Title V Permit

20. Reduced load period is defined as the time during which a gas turbine is operated at less than rated capacity in order to change the position of the exhaust gas diverter gate. Each reduced load period shall not exceed one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit

21. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit

22. The owner or operator shall certify, maintain, operate, and quality-assure a continuous emission monitor system (CEMS) which continuously measures and records the exhaust gas NOx, CO, and O2 concentrations. Continuous emissions monitors shall be capable of monitoring emissions during normal operating conditions and during startups and shutdowns, provided that CEMS pass the relative accuracy requirements and performance specifications of: 40 CFR Part 60, Appendix B and F; 40 CFR Part 51, Appendix P; Performance Specification 2 (PS-2); and District approved protocol for startups. If relative accuracy of CEMS cannot be demonstrated during the startup, CEMS results during startup and shutdown events shall be replaced with startup emission rates obtained from the source test conducted by the facility to determine compliance with emission limits contained in this document. [40 CFR 60.334(b)(1); 40 CFR 64; and District Rules 1080, 6.7; and 4703, 6.2] Federally Enforceable Through Title V Permit

23. The owner or operator shall maintain all records of required monitoring data and support information for a period of five years from the date of data entry and shall make such records available to the District upon request. [District Rule 4703, 6.2] Federally Enforceable Through Title V Permit

24. The owner or operator shall maintain a stationary gas turbine system operating log that includes, on a daily basis, the actual local startup and stop time, length and reason for reduced load periods, total hours of operation, the type and quantity of fuel used, duration of each start-up (or black start), shutdown, and bypass transition time period. [District Rule 4703, 6.2] Federally Enforceable Through Title V Permit

25. Compliance source testing for NOx, CO, VOC, NH3 and fuel gas sulfur content shall be conducted at least once every 12 months. [40 CFR 60.335(a) and District Rules 1081; and 4703, 3.6, 6.3] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

26. The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front and back half) or 201 and 202a; Ammonia - BAAQMD ST-1B; O2 - EPA Method 3, 3A, or 20 or CARB Method 100; and HHV and LHV - ASTM D3588-91, ASTM 1826-88, or ASTM 1945-81. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.335(a) and (b)(1) and District Rules 1081; and 4703, 6.4] Federally Enforceable Through Title V Permit

27. CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

28. Results of continuous emission monitoring shall be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(b)(3) and 40 CFR 64] Federally Enforceable Through Title V Permit

29. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit

30. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, then a fuel sample shall be collected during the source test to determine the sulfur content of the fuel combusted in the turbine. The fuel sample shall be analyzed for the total sulfur content using ASTM D1072; D3246; D4084; D4468; D6228; or D6667; or double GC for H2S and mercaptans. The applicable ranges of some ASTM methods are not adequate to measure the levels of sulfur in some fuel gases. Dilution o10)f samples before analysis (with verification of dilution ratio) may be used after getting a prior approval from the District. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

31. Monitor downtime for NOx shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOX concentration or diluent O2 (or both). [40 CFR 60.334(j)1)(iii)(B)] Federally Enforceable Through Title V Permit

32. The owner or operator shall submit a written report of CEMS operations for each calendar quarter to the District. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j)(5); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

33. The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit

34. Permittee shall report the following emission exceedences to the District: emission rates of NOx & CO on a three-hour rolling average, and NSPS emission rate on a four hour average. [District Rule 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

35. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 2201] Federally Enforceable Through Title V Permit

36. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit

37. The sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D4084, D5504, D6228, Gas Processors Association Standard 2377 or double GC for H2S and mercaptans. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

38. The sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit

39. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080] Federally Enforceable Through Title V Permit

40. Results of continuous emission monitoring must be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(j),(j)(5); 40 CFR 64; and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

41. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.335(a), (b)(7); and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

42. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [40 CFR 60.7 (b); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

43. Permittee shall maintain accurate records of ammonia consumption and all maintenance activities related to this unit. [District Rule 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

44. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx and CO daily emission limitations by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District Rule 2201] Federally Enforceable Through Title V Permit

45. Audits of monitors shall be conducted annually by independent testing lab in accordance with EPA guidelines, witnessed or authorized by the District, and reports shall be submitted to the District within 60 days of audit. [District Rule 1080] Federally Enforceable Through Title V Permit

46. Operator shall submit a semiannual report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)(3)(D)] Federally Enforceable Through Title V Permit

47. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit

48. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [40 CFR 64 and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit

49. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

50. Formerly S-1109-362-18.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1038-11

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NW10 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
DORMANT 58.2 MMBTU/HR (NOMINAL RATING), 4.0 MW ALLISON MODEL 501-KB5 GAS-FIRED TURBINE ENGINE COGENERATION SYSTEM WITH WATER INJECTION, HEAT RECOVERY STEAM GENERATOR, AND CEM SYSTEMS FOR NOX, CO, AND O2

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4703] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4703 and all other applicable District regulations. [District Rule 4703] Federally Enforceable Through Title V Permit
4. Either conventional or pilotless fuel nozzles may be used. [District Rule 2010] Federally Enforceable Through Title V Permit
5. Lube oil cooler/accumulator shall be equipped with device to prevent detectable emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
6. If water injection is inoperative, turbine shall be shut down. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Turbine shall not burn more than 1.33 MMscf/day of natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
8. All turbine exhaust shall flow to heat recovery steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
9. CEM equipment shall be maintained and calibrated according to EPA guidelines specified in CFR Part 60, Appendix B. [40 CFR 60.334 (b); 40 CFR 60; and District Rule 1080] Federally Enforceable Through Title V Permit
10. Unit shall be equipped with continuously recording fuel gas flowmeter. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Gas turbine engine exhaust may be diverted to bypass stack under Rule 1100 (Equipment Breakdown), provided all applicable record keeping and reporting requirements of Rule 1100 are fulfilled. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Emission rates shall not exceed any of the following: PM10: 17.9 lb/day, SOx (as SO2): 8.4 lb/day, NOx (as NO2): 180.2 lb/day, VOC: 48.9 lb/day, or CO: 125.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

13. Except during periods of startup/shutdown, emission rates (3-hour rolling average) shall not exceed any of the following: PM10: 0.0128 lb/MMBTU, SOx (as SO2): 0.006 lb/MMBTU, NOx (as NO2): 0.129 lb/MMBTU or 38 ppmvd @ 15% O2, VOC: 0.035 lb/MMBTU, or CO: 40 ppmvd @ 15% O2. [40 CFR 60.333(a) and (b) and District Rules 2201; and 4703] Federally Enforceable Through Title V Permit
14. NOx emission rate (one hour average) shall not exceed the NSPS standard of 150 ppmvd @ 15% O2. [40 CFR 60.332(a)] Federally Enforceable Through Title V Permit
15. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
16. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Except during periods of gas turbine engine startup/shutdown, gas turbine water injection rate shall be maintained at water-to-fuel ratio documented to achieve compliance with emission limits. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Reduced load period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.16] Federally Enforceable Through Title V Permit
19. Thermal stabilization period shall be defined as the start-up or shutdown time necessary to bring the heat recovery steam generator to proper temperature, not exceeding two hours. [District Rule 4703, 3.21] Federally Enforceable Through Title V Permit
20. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx and CO daily emission limitations by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Compliance source testing for NOx, CO, fuel gas sulfur content, and demonstrated percent efficiency of gas turbine engine shall be conducted at least once every 12 months. [District Rules 2201; and 4703] Federally Enforceable Through Title V Permit
22. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Permittee shall submit to the APCO the information correlating the control system operating parameters to the associated measured NOx output. [District Rule 4703, 6.2.3] Federally Enforceable Through Title V Permit
24. Except during periods of thermal stabilization or reduced loads, NOx emission rate shall not exceed 35 ppmv at 15% O2 on a 3 hour rolling average basis. [District Rule 4703, 5.1.2 and 7.2.1] Federally Enforceable Through Title V Permit
25. Permittee shall report the following emission exceedences to the District: emission rates of NOx & CO on a three-hour rolling average, NSPS emission rate on one hour average, and DEL of NOx & CO during days of gas turbine engine startup/shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
26. For units equipped with continuous emissions monitors (CEMs), CEM records shall be used in place of calculated emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
27. If monitoring provisions fail, the emissions shall be calculated on operational data (steam production rate, inlet air and exhaust gas flowrates, etc.) or, if such data is not available, for the four days of operation preceding the breakdown. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Audits of monitors shall be conducted at least once every 12 months by independent testing lab in accordance with EPA guidelines, witnessed by District, and reports shall be submitted to District within 60 days of audit. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Kern County Rule 108.1; District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

30. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(h)(3) and (i)(3)(i)] Federally Enforceable Through Title V Permit

31. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, then a fuel sample shall be collected during the source test to determine the sulfur content of the fuel combusted in the turbine. The fuel sample shall be analyzed for the total sulfur content using ASTM D1072; D3246; D4084; D4468; D6228; or D6667; or double GC for H2S and mercaptans. The applicable ranges of some ASTM methods are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of dilution ratio) may be used after getting a prior approval from the District. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

32. The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front and back half) or 201 and 202a; Ammonia - BAAQMD ST-1B; O2 - EPA Method 3, 3A, or 20 or CARB Method 100; and HHV and LHV - ASTM D3588-91, ASTM 1826-88, or ASTM 1945-81. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.335(a) and (b)(1) and District Rules 1081; and 4703, 6.4] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of quantity of fuel used per day, all maintenance activities related to this unit, and date and time of fuel nozzle replacement, and type of fuel nozzle installed. [District Rule 2201] Federally Enforceable Through Title V Permit

34. Operator shall install, operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, and the exhaust gas NOx concentration at 15% O2 on a dry basis. [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit

35. The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit

36. The owner or operator shall certify, maintain, operate, and quality-assure a continuous emission monitor system (CEMS) which continuously measures and records the exhaust gas NOx, CO, and O2 concentrations. Continuous emissions monitors shall be capable of monitoring emissions during normal operating conditions and during startups and shutdowns, provided that CEMS pass the relative accuracy requirements and performance specifications of: 40 CFR Part 60, Appendix B and F; 40 CFR Part 51, Appendix P; Performance Specification 2 (PS-2); and District approved protocol for startups. If relative accuracy of CEMS cannot be demonstrated during the startup, CEMS results during startup and shutdown events shall be replaced with startup emission rates obtained from the source test conducted by the facility to determine compliance with emission limits contained in this document. [40 CFR 60.334(b)(1); 40 CFR 64; and District Rules 1080, 6.7; and 4703, 6.2] Federally Enforceable Through Title V Permit

37. Should the applicant decide to conduct performance evaluation of CEMS with the initial performance test, a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load shall be performed. The test data obtained during these run can be used to demonstrate compliance with the applicable NOx emission limit and to provide reference method data for the RATA of the CEMS. The requirement to test at three additional load levels is waived under this option. [40 CFR 60.335(b)(2)] Federally Enforceable Through Title V Permit

38. Monitor downtime for NOx shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOX concentration or diluent O2 (or both). [40 CFR 60.334(j)1)(iii)(B)] Federally Enforceable Through Title V Permit

39. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [40 CFR 60.7 (b); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

41. Results of continuous emission monitoring shall be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(b)(3) and 40 CFR 64] Federally Enforceable Through Title V Permit

42. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit

43. Operator shall submit a semiannual report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)(3)(D)] Federally Enforceable Through Title V Permit

44. CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

45. The owner or operator shall submit a written report of CEMS operations for each calendar quarter to the District. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j)(5); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

46. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit

47. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [40 CFR 64 and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit

48. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

49. Formerly S-1109-373-15.

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1039-11 **EXPIRATION DATE:** 02/28/2017

SECTION: NW10 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
DORMANT 58.2 MMBTU/HR (NOMINAL RATING), 4.0 MW ALLISON MODEL 501-KB5 GAS-FIRED TURBINE ENGINE COGENERATION SYSTEM WITH WATER INJECTION, HEAT RECOVERY STEAM GENERATOR, AND CEM SYSTEMS FOR NOX, CO, AND O2

DRAFT

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4703] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4703 and all other applicable District regulations. [District Rule 4703] Federally Enforceable Through Title V Permit
4. Either conventional or pilotless fuel nozzles may be used. [District Rule 2010] Federally Enforceable Through Title V Permit
5. Lube oil cooler/accumulator shall be equipped with device to prevent detectable emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
6. If water injection is inoperative, turbine shall be shut down. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Turbine shall not burn more than 1.33 MMscf/day of natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
8. All turbine exhaust shall flow to heat recovery steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
9. CEM equipment shall be maintained and calibrated according to EPA guidelines specified in CFR Part 60, Appendix B. [40 CFR 60.334 (b); 40 CFR 60; and District Rule 1080] Federally Enforceable Through Title V Permit
10. Unit shall be equipped with continuously recording fuel gas flowmeter. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Gas turbine engine exhaust may be diverted to bypass stack under Rule 1100 (Equipment Breakdown), provided all applicable record keeping and reporting requirements of Rule 1100 are fulfilled. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Emission rates shall not exceed any of the following: PM10: 17.9 lb/day, SOx (as SO2): 8.4 lb/day, NOx (as NO2): 180.2 lb/day, VOC: 48.9 lb/day, or CO: 125.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Except during periods of startup/shutdown, emission rates (3-hour rolling average) shall not exceed any of the following: PM10: 0.0128 lb/MMBTU, SOx (as SO2): 0.006 lb/MMBTU, NOx (as NO2): 0.129 lb/MMBTU or 38 ppmvd @ 15% O2, VOC: 0.035 lb/MMBTU, or CO: 40 ppmvd @ 15% O2. [40 CFR 60.333(a) and (b) and District Rules 2201; and 4703] Federally Enforceable Through Title V Permit
14. NOx emission rate (one hour average) shall not exceed the NSPS standard of 150 ppmvd @ 15% O2. [40 CFR 60.332(a)] Federally Enforceable Through Title V Permit
15. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
16. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Except during periods of gas turbine engine startup/shutdown, gas turbine water injection rate shall be maintained at water-to-fuel ratio documented to achieve compliance with emission limits. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Reduced load period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.16] Federally Enforceable Through Title V Permit
19. Thermal stabilization period shall be defined as the start-up or shutdown time necessary to bring the heat recovery steam generator to proper temperature, not exceeding two hours. [District Rule 4703, 3.21] Federally Enforceable Through Title V Permit
20. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx and CO daily emission limitations by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Compliance source testing for NOx, CO, fuel gas sulfur content, and demonstrated percent efficiency of gas turbine engine shall be conducted at least once every 12 months. [District Rules 2201; and 4703] Federally Enforceable Through Title V Permit
22. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Permittee shall submit to the APCO the information correlating the control system operating parameters to the associated measured NOx output. [District Rule 4703, 6.2.3] Federally Enforceable Through Title V Permit
24. Except during periods of thermal stabilization or reduced loads, NOx emission rate shall not exceed 35 ppmv at 15% O2 on a 3 hour rolling average basis. [District Rule 4703, 5.1.2 and 7.2.1] Federally Enforceable Through Title V Permit
25. Permittee shall report the following emission exceedences to the District: emission rates of NOx & CO on a three-hour rolling average, NSPS emission rate on one hour average, and DEL of NOx & CO during days of gas turbine engine startup/shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
26. For units equipped with continuous emissions monitors (CEMs), CEM records shall be used in place of calculated emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
27. If monitoring provisions fail, the emissions shall be calculated on operational data (steam production rate, inlet air and exhaust gas flowrates, etc.) or, if such data is not available, for the four days of operation preceding the breakdown. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Audits of monitors shall be conducted at least once every 12 months by independent testing lab in accordance with EPA guidelines, witnessed by District, and reports shall be submitted to District within 60 days of audit. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Kern County Rule 108.1; District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

30. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(h)(3) and (i)(3)(i)] Federally Enforceable Through Title V Permit

31. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, then a fuel sample shall be collected during the source test to determine the sulfur content of the fuel combusted in the turbine. The fuel sample shall be analyzed for the total sulfur content using ASTM D1072; D3246; D4084; D4468; D6228; or D6667; or double GC for H2S and mercaptans. The applicable ranges of some ASTM methods are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of dilution ratio) may be used after getting a prior approval from the District. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

32. The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front and back half) or 201 and 202a; Ammonia - BAAQMD ST-1B; O2 - EPA Method 3, 3A, or 20 or CARB Method 100; and HHV and LHV - ASTM D3588-91, ASTM 1826-88, or ASTM 1945-81. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.335(a) and (b)(1) and District Rules 1081; and 4703, 6.4] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of quantity of fuel used per day, all maintenance activities related to this unit, and date and time of fuel nozzle replacement, and type of fuel nozzle installed. [District Rule 2201] Federally Enforceable Through Title V Permit

34. Operator shall install, operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, and the exhaust gas NOx concentration at 15% O2 on a dry basis. [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit

35. The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit

36. The owner or operator shall certify, maintain, operate, and quality-assure a continuous emission monitor system (CEMS) which continuously measures and records the exhaust gas NOx, CO, and O2 concentrations. Continuous emissions monitors shall be capable of monitoring emissions during normal operating conditions and during startups and shutdowns, provided that CEMS pass the relative accuracy requirements and performance specifications of: 40 CFR Part 60, Appendix B and F; 40 CFR Part 51, Appendix P; Performance Specification 2 (PS-2); and District approved protocol for startups. If relative accuracy of CEMS cannot be demonstrated during the startup, CEMS results during startup and shutdown events shall be replaced with startup emission rates obtained from the source test conducted by the facility to determine compliance with emission limits contained in this document. [40 CFR 60.334(b)(1); 40 CFR 64; and District Rules 1080, 6.7; and 4703, 6.2] Federally Enforceable Through Title V Permit

37. Should the applicant decide to conduct performance evaluation of CEMS with the initial performance test, a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load shall be performed. The test data obtained during these run can be used to demonstrate compliance with the applicable NOx emission limit and to provide reference method data for the RATA of the CEMS. The requirement to test at three additional load levels is waived under this option. [40 CFR 60.335(b)(2)] Federally Enforceable Through Title V Permit

38. Monitor downtime for NOx shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOX concentration or diluent O2 (or both). [40 CFR 60.334(j)1)(iii)(B)] Federally Enforceable Through Title V Permit

39. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [40 CFR 60.7 (b); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

41. Results of continuous emission monitoring shall be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(b)(3) and 40 CFR 64] Federally Enforceable Through Title V Permit

42. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit

43. Operator shall submit a semiannual report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)(3)(D)] Federally Enforceable Through Title V Permit

44. CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

45. The owner or operator shall submit a written report of CEMS operations for each calendar quarter to the District. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j)(5); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

46. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit

47. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [40 CFR 64 and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit

48. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

49. Formerly S-1109-374-15.

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1084-4 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
83 BHP FORD MODEL CGS-649 4.9 LITER 6-CYLINDER NATURAL GAS-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.0] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 5.7] Federally Enforceable Through Title V Permit
3. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702, 3.15] Federally Enforceable Through Title V Permit
4. During or before periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702, 5.7] Federally Enforceable Through Title V Permit
5. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year, as determined by an operational nonresettable elapsed operating time meter. [District Rule 4702, 3.15] Federally Enforceable Through Title V Permit
6. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702, 3.15] Federally Enforceable Through Title V Permit
7. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702, 5.7] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 6.2] Federally Enforceable Through Title V Permit
9. Permittee must minimize the engine's time spent at idle during startup and minimize the engine's startup time to a period needed for appropriate and safe loading of the engine, not to exceed 30 minutes. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The engine shall be in full compliance with 40 CFR Part 63, Subpart ZZZZ (National Emission Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines). [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

11. The engine's oil and filter shall be changed every 500 hours of operation or every 12 months, whichever comes first. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

12. The engine's spark plugs shall be inspected every 1,000 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

13. The engine's hoses and belts shall be inspected every 500 hours of operation or every 12 months, whichever comes first, and replaced as necessary. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

14. The permittee shall maintain monthly records of the occurrence and duration of each malfunction of operation (i.e., process equipment) or the air pollution control and monitoring equipment. The permittee shall also maintain monthly records of action taken during periods of malfunction to minimize emissions in accordance with §63.6605(b), including corrective actions to restore malfunctioning process and air pollution control and monitoring equipment to its normal or usual manner of operation. [District Rule 1070 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

15. The permittee has the option of utilizing an oil analysis program in order to extend the specified oil change requirement in Tables 2c and 2d of Subpart ZZZZ. The oil analysis must be performed at the same frequency specified for changing the oil in Table 2c or 2d to this subpart. The analysis program must at a minimum analyze the following three parameters: Total Acid Number, viscosity, and percent water content. The condemning limits for these parameters are as follows: Total Acid Number increases by more than 3.0 milligrams of potassium hydroxide (KOH) per gram from Total Acid Number of the oil when new; viscosity of the oil has changed by more than 20 percent from the viscosity of the oil when new; or percent water content (by volume) is greater than 0.5. If all of these condemning limits are not exceeded, the engine owner or operator is not required to change the oil. If any of the limits are exceeded, the engine owner or operator must change the oil within 2 days of receiving the results of the analysis; if the engine is not in operation when the results of the analysis are received, the engine owner or operator must change the oil within 2 days or before commencing operation, whichever is later. The owner or operator must keep records of the parameters that are analyzed as part of the program, the results of the analysis, and the oil changes for the engine. The analysis program must be part of the maintenance plan for the engine. [40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

16. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 4702 and 40 CFR 63 Subpart ZZZZ] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1085-9 **EXPIRATION DATE:** 02/28/2017

SECTION: 19 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
83.3 MMBTU/HR AIR-ASSISTED STANDBY FLARE WITH AUTOMATIC ELECTRONIC IGNITOR, NATURAL GAS AUXILIARY FUEL, AND NATURAL GAS OR PROPANE PILOT ASSEMBLY (RAMBLER LEASE)

DRAFT

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modifications, except for changes specified in the conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. This unit may be designated as a dormant emissions unit or an active emissions unit. Permittee shall notify the District's Compliance Division in writing (US Mail, Fax or Email) within 7 days after re-designating this unit as a dormant or active emissions unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing and monitoring shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing and monitoring shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
8. Flare shall only operate when steam generators S-1131-999, S-1131-065, S-1131-066 and S-1131-067 are not operating. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Thermally Enhanced Oil Recovery (TEOR)/ vapor control gas, natural gas, pilot gas, and purge gas lines to flare shall be equipped with volumetric flow rate indicator. [District Rules 2201; and 4311, 5.10, 6.7] Federally Enforceable Through Title V Permit
10. A flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit
11. Flare shall be equipped with a natural gas or propane fired pilot and an automatic re-ignition system. [District Rules 2201; and 4311, 5.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. Flare shall be equipped with a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an equivalent device capable of continuously detecting at least one pilot flame or the flare flame is present. The flame detection device shall be kept operational at all times except during flare maintenance when the flare is isolated from gas flow. During essential planned power outages when the flare is operating, the pilot monitor is allowed to be non-functional if the flare flame is clearly visible to onsite operators. Effective on and after July 1, 2012, all pilot monitor downtime shall be reported annually pursuant to Rule 4311, section 6.2.3.6. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit
13. Only PUC quality natural gas or propane shall be used as pilot fuel. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Only PUC-quality gas with sulfur content less than or equal to 1 grain sulfur per 100 scf of gas shall be used to supplement gas to the flare. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum volume of gas incinerated in this flare shall not exceed the following: 500,000 scf/day vapor recovery gas and 302,160 scf/day PUC quality natural gas (includes 2,160 scf/day natural gas pilot fuel). [District Rule 2201] Federally Enforceable Through Title V Permit
16. The vapor recovery gas sulfur compound concentration shall not exceed 600 ppmv (35.4 grains S/100scf). [District Rule 2201] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed any of the following in lb/MMBtu: PM10 - 0.026, NOx (as NO2) - 0.068, VOC - 0.063, and CO - 0.370. [District Rule 2201] Federally Enforceable Through Title V Permit
18. If the flare uses a flow-sensing automatic ignition system and does not use a continuous flame pilot, the flare shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit
19. Open flares in which the flare gas pressure is less than 5 psig shall be operated in such a manner that meets the provisions of 40 CFR 60.18. [District Rule 4311, 5.6] Federally Enforceable Through Title V Permit
20. Operator shall monitor vent gas composition using one of the five following methods: 1) Sampling vent gas pursuant to Rule 4311 Section 6.6.1, 2) Integrated sampling pursuant to Rule 4311 Section 6.6.2, 3) Operate continuous analyzers that meet the requirements of Rule 4311 Section 6.6.3, 4) Operate continuous analyzers employing gas chromatography pursuant to Rule 4311 Section 6.6.4, or 5) Monitor sulfur content using a colorimetric tube system, and monitor vent gas hydrocarbons pursuant to Rule 4311 Section 6.6.5. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit
21. Operator shall monitor the volumetric flows of purge and pilot gases. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit
22. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. The operator shall provide the APCO with access to the monitoring system to collect vent gas samples to verify the analysis required by Rule 4311 Section 5.11. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit
23. Operator shall report periods of monitor inoperation greater than 24 continuous hours by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit
24. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Rule 4311 Section 6.3.4. During periods of inoperation of flow monitors, flow shall be calculated using good engineering practices. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

25. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

26. All in-line continuous analyzer and flow monitoring data must be continuously recorded by an electronic data acquisition system capable of one-minute averages. Flow monitoring data shall be recorded as one-minute averages. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

27. Permit holder shall document compliance with vapor recovery gas sulfur concentration limit on a monthly basis by sample collection and independent laboratory analysis using ASTM method 3246. [District Rule 1081] Federally Enforceable Through Title V Permit

28. The operator shall notify the District of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, whichever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

29. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that summarizes all reportable flaring events during the previous 12-month period. The report shall include the following: 1) The results of an investigation to determine the primary cause and contributing factors of the flaring event; 2) Any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; 3) If appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and 4) The date, time, and duration of the flaring event. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

30. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that includes the following: 1) The total volumetric flow of vent gas in standard cubic feet for each day; 2) Hydrogen sulfide content, methane content, and hydrocarbon content of vent gas composition pursuant to Section 6.6; 3) If vent gas composition is monitored by a continuous analyzer or analyzers pursuant to Section 5.11, average total hydrocarbon content by volume, average methane content by volume, and depending upon the analytical method used pursuant to Section 6.3.4, total reduced sulfur content by volume or hydrogen sulfide content by volume of vent gas flared for each hour of the month; 4) If the flow monitor used pursuant to Section 5.10 measures molecular weight, the average molecular weight for each hour of each month; 5) For any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month, and the means used to determine flow; 6) Flare monitoring system downtime periods, including dates and times; 7) For each day and for each month provide calculated sulfur dioxide emissions; and 8) A flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing pursuant to Section 6.3.5. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

31. Vent gas composition shall be monitored using one of the methods outlined in Rule 4311, Section 6.6.1 through 6.6.5. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. [District Rule 4311, 6.6] Federally Enforceable Through Title V Permit

32. Periods of flare monitoring system inoperation greater than 24 continuous hours shall be reported by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

33. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Section 6.3.4. During periods of inoperation of flow monitors required by Section 5.10, flow shall be calculated using good engineering practices. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

34. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device in question. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

35. The permittee shall keep accurate daily records of volume, type, & location of gas flared and operational status of steam generators S-1131-999, S-1131-065, S-1131-066 and S-1131-067, for a period of five years, and shall make such records available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; and 4311, 6.1] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1086-9 **EXPIRATION DATE:** 02/28/2017

SECTION: SW34 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
83.3 MMBTU/HR AIR-ASSISTED STANDBY FLARE WITH AUTOMATIC ELECTRONIC IGNITOR, AND NATURAL GAS OR PROPANE PILOT ASSEMBLY, OPERATED AT VARIOUS UNSPECIFIED LOCATIONS WITHIN THE KERN RIVER OIL FIELD

DRAFT

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modifications, except for changes specified in the conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. This unit may be designated as a dormant emissions unit or an active emissions unit. Permittee shall notify the District's Compliance Division in writing (US Mail, Fax or Email) within 7 days after re-designating this unit as a dormant or active emissions unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing and monitoring shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing and monitoring shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
8. This flare shall not operate within 1,000 feet of any K-12 school. [District Rule 4102]
9. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made in writing no later than 48 hours after starting operation at the location. [District Rule 1070]
10. Flare shall only operate when steam generators S-1131-064, S-1131-998 and S-1131-1003 are not operating. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Thermally Enhanced Oil Recovery (TEOR)/ vapor control gas, natural gas, pilot gas, and purge gas lines to flare shall be equipped with volumetric flow rate indicator. [District Rules 2201; and 4311, 5.10, 6.7] Federally Enforceable Through Title V Permit
12. A flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

13. Flare shall be equipped with a natural gas or propane fired pilot and an automatic re-ignition system. [District Rules 2201; and 4311, 5.3] Federally Enforceable Through Title V Permit

14. Flare shall be equipped with a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an equivalent device capable of continuously detecting at least one pilot flame or the flare flame is present. The flame detection device shall be kept operational at all times except during flare maintenance when the flare is isolated from gas flow. During essential planned power outages when the flare is operating, the pilot monitor is allowed to be non-functional if the flare flame is clearly visible to onsite operators. Effective on and after July 1, 2012, all pilot monitor downtime shall be reported annually pursuant to Rule 4311, section 6.2.3.6. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit

15. Only PUC quality natural gas or propane shall be used as pilot fuel. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit

16. Maximum volume of gas incinerated in this flare shall not exceed the following: 210,000 scf/day TEOR/ vapor control gas and 202,160 scf/day PUC quality natural gas (includes 2,160 scf/day pilot fuel). [District Rule 2201] Federally Enforceable Through Title V Permit

17. Sulfur compound concentration (as H2S) of TEOR/ vapor control gas shall not exceed 360 ppmv. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit

18. Emission rates shall not exceed any of the following in lb/MMBtu: PM10 - 0.0202, NOx (as NO2) - 0.068, VOC - 0.006, and CO - 0.370. [District Rule 2201] Federally Enforceable Through Title V Permit

19. If the flare uses a flow-sensing automatic ignition system and does not use a continuous flame pilot, the flare shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit

20. Open flares in which the flare gas pressure is less than 5 psig shall be operated in such a manner that meets the provisions of 40 CFR 60.18. [District Rule 4311, 5.6] Federally Enforceable Through Title V Permit

21. Operator shall monitor vent gas composition using one of the five following methods: 1) Sampling vent gas pursuant to Rule 4311 Section 6.6.1, 2) Integrated sampling pursuant to Rule 4311 Section 6.6.2, 3) Operate continuous analyzers that meet the requirements of Rule 4311 Section 6.6.3, 4) Operate continuous analyzers employing gas chromatography pursuant to Rule 4311 Section 6.6.4, or 5) Monitor sulfur content using a colorimetric tube system, and monitor vent gas hydrocarbons pursuant to Rule 4311 Section 6.6.5. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

22. Operator shall monitor the volumetric flows of purge and pilot gases. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

23. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. The operator shall provide the APCO with access to the monitoring system to collect vent gas samples to verify the analysis required by Rule 4311 Section 5.11. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

24. Operator shall report periods of monitor inoperation greater than 24 continuous hours by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

25. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Rule 4311 Section 6.3.4. During periods of inoperation of flow monitors, flow shall be calculated using good engineering practices. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

26. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

27. All in-line continuous analyzer and flow monitoring data must be continuously recorded by an electronic data acquisition system capable of one-minute averages. Flow monitoring data shall be recorded as one-minute averages. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

28. At least once per month, the permittee shall document compliance with TEOR/ vapor control gas sulfur concentration limit by sample collection and independent laboratory analysis using ASTM method 3246. [District Rule 1081] Federally Enforceable Through Title V Permit

29. Permittee shall maintain accurate daily records of type and volume of gas flared and H2S concentration. [District Rules 1070; and 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. The operator shall notify the District of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, whichever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

31. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that summarizes all reportable flaring events during the previous 12-month period. The report shall include the following: 1) The results of an investigation to determine the primary cause and contributing factors of the flaring event; 2) Any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; 3) If appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and 4) The date, time, and duration of the flaring event. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

32. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that includes the following: 1) The total volumetric flow of vent gas in standard cubic feet for each day; 2) Hydrogen sulfide content, methane content, and hydrocarbon content of vent gas composition pursuant to Section 6.6; 3) If vent gas composition is monitored by a continuous analyzer or analyzers pursuant to Section 5.11, average total hydrocarbon content by volume, average methane content by volume, and depending upon the analytical method used pursuant to Section 6.3.4, total reduced sulfur content by volume or hydrogen sulfide content by volume of vent gas flared for each hour of the month; 4) If the flow monitor used pursuant to Section 5.10 measures molecular weight, the average molecular weight for each hour of each month; 5) For any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month, and the means used to determine flow; 6) Flare monitoring system downtime periods, including dates and times; 7) For each day and for each month provide calculated sulfur dioxide emissions; and 8) A flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing pursuant to Section 6.3.5. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

33. Vent gas composition shall be monitored using one of the methods outlined in Rule 4311, Section 6.6.1 through 6.6.5. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. [District Rule 4311, 6.6] Federally Enforceable Through Title V Permit

34. Periods of flare monitoring system inoperation greater than 24 continuous hours shall be reported by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Section 6.3.4. During periods of inoperation of flow monitors required by Section 5.10, flow shall be calculated using good engineering practices. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

36. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device in question. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

37. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4311, 6.1] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1087-7 **EXPIRATION DATE:** 02/28/2017

SECTION: SW28 **TOWNSHIP:** 28S **RANGE:** 28E

DRAFT

EQUIPMENT DESCRIPTION:
83.3 MMBTU/HR AIR-ASSISTED STANDBY FLARE WITH AUTOMATIC ELECTRONIC IGNITOR, AND NATURAL GAS OR PROPANE PILOT ASSEMBLY OPERATED AT VARIOUS SPECIFIED LOCATIONS WITHIN THE KERN RIVER OIL FIELD.

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modifications, except for changes specified in the conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. This unit may be designated as a dormant emissions unit or an active emissions unit. Permittee shall notify the District's Compliance Division in writing (US Mail, Fax or Email) within 7 days after re-designating this unit as a dormant or active emissions unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing and monitoring shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing and monitoring shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
8. Approved locations of operation are Sections 25, 28, 30, 31, 32, and 36 of T28S, R28W and Sec 5, 6, 7, and 8 of T29S, R28E. [District Rule 4102]
9. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made in writing no later than 48 hours after starting operation at the location. [District Rule 1070]
10. Flare shall only operate when steam generators S-1131-997 and S-1131-1016 are not operating. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Thermally Enhanced Oil Recovery (TEOR)/ vapor control gas, natural gas, pilot gas, and purge gas lines to flare shall be equipped with volumetric flow rate indicator. [District Rules 2201; and 4311, 5.10, 6.7] Federally Enforceable Through Title V Permit
12. A flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Flare shall be equipped with a natural gas or propane fired pilot and an automatic re-ignition system. [District Rules 2201; and 4311, 5.3] Federally Enforceable Through Title V Permit

14. Flare shall be equipped with a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an equivalent device capable of continuously detecting at least one pilot flame or the flare flame is present. The flame detection device shall be kept operational at all times except during flare maintenance when the flare is isolated from gas flow. During essential planned power outages when the flare is operating, the pilot monitor is allowed to be non-functional if the flare flame is clearly visible to onsite operators. Effective on and after July 1, 2012, all pilot monitor downtime shall be reported annually pursuant to Rule 4311, section 6.2.3.6. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit

15. Only PUC quality natural gas or propane shall be used as pilot fuel. [District Rules 2201, 4102] Federally Enforceable Through Title V Permit

16. Maximum volume of gas incinerated in this flare shall not exceed the following: 200,000 scf/day vapor recovery gas and 37,160 scf/day PUC quality natural gas (includes 2,160 scf/day pilot fuel). [District Rule 2201] Federally Enforceable Through Title V Permit

17. Emission rates shall not exceed any of the following in lb/MMBtu: PM10 - 0.0202, NOx (as NO2) - 0.068, VOC - 0.004, and CO - 0.370. [District Rule 2201] Federally Enforceable Through Title V Permit

18. Sulfur compound concentration (as H2S) of vapor recovery gas shall not exceed 810 ppmv. [District Rule 2201] Federally Enforceable Through Title V Permit

19. If the flare uses a flow-sensing automatic ignition system and does not use a continuous flame pilot, the flare shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit

20. Open flares in which the flare gas pressure is less than 5 psig shall be operated in such a manner that meets the provisions of 40 CFR 60.18. [District Rule 4311, 5.6] Federally Enforceable Through Title V Permit

21. Operator shall monitor vent gas composition using one of the five following methods: 1) Sampling vent gas pursuant to Rule 4311 Section 6.6.1, 2) Integrated sampling pursuant to Rule 4311 Section 6.6.2, 3) Operate continuous analyzers that meet the requirements of Rule 4311 Section 6.6.3, 4) Operate continuous analyzers employing gas chromatography pursuant to Rule 4311 Section 6.6.4, or 5) Monitor sulfur content using a colorimetric tube system, and monitor vent gas hydrocarbons pursuant to Rule 4311 Section 6.6.5. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

22. Operator shall monitor the volumetric flows of purge and pilot gases. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

23. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. The operator shall provide the APCO with access to the monitoring system to collect vent gas samples to verify the analysis required by Rule 4311 Section 5.11. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

24. Operator shall report periods of monitor inoperation greater than 24 continuous hours by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

25. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Rule 4311 Section 6.3.4. During periods of inoperation of flow monitors, flow shall be calculated using good engineering practices. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

26. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

27. All in-line continuous analyzer and flow monitoring data must be continuously recorded by an electronic data acquisition system capable of one-minute averages. Flow monitoring data shall be recorded as one-minute averages. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

28. At least once per month, the permittee shall document compliance with TEOR/ vapor control gas sulfur concentration limit by sample collection and independent laboratory analysis using ASTM method 3246. [District Rule 1081] Federally Enforceable Through Title V Permit

29. The results of sample analysis, conducted for startup, shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

30. Permittee shall maintain accurate daily records of type and volume of gas flared and H2S concentration. [District Rules 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

31. The operator shall notify the District of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, whichever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

32. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that summarizes all reportable flaring events during the previous 12-month period. The report shall include the following: 1) The results of an investigation to determine the primary cause and contributing factors of the flaring event; 2) Any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; 3) If appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and 4) The date, time, and duration of the flaring event. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

33. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that includes the following: 1) The total volumetric flow of vent gas in standard cubic feet for each day; 2) Hydrogen sulfide content, methane content, and hydrocarbon content of vent gas composition pursuant to Section 6.6; 3) If vent gas composition is monitored by a continuous analyzer or analyzers pursuant to Section 5.11, average total hydrocarbon content by volume, average methane content by volume, and depending upon the analytical method used pursuant to Section 6.3.4, total reduced sulfur content by volume or hydrogen sulfide content by volume of vent gas flared for each hour of the month; 4) If the flow monitor used pursuant to Section 5.10 measures molecular weight, the average molecular weight for each hour of each month; 5) For any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month, and the means used to determine flow; 6) Flare monitoring system downtime periods, including dates and times; 7) For each day and for each month provide calculated sulfur dioxide emissions; and 8) A flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing pursuant to Section 6.3.5. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

34. Vent gas composition shall be monitored using one of the methods outlined in Rule 4311, Section 6.6.1 through 6.6.5. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. [District Rule 4311, 6.6] Federally Enforceable Through Title V Permit

35. Periods of flare monitoring system inoperation greater than 24 continuous hours shall be reported by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Section 6.3.4. During periods of inoperation of flow monitors required by Section 5.10, flow shall be calculated using good engineering practices. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

37. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device in question. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

38. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4311, 6.1] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1091-4

EXPIRATION DATE: 02/28/2017

DRAFT

EQUIPMENT DESCRIPTION:
1,650 GALLON TRANSPORTABLE CHEMICAL STORAGE TANK

PERMIT UNIT REQUIREMENTS

1. The equipment shall not be operated within 1000 feet of any K-12 school. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 1.5 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit

12. This tank shall be in a gas-tight condition. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623. [District Rule 4623] Federally Enforceable Through Title V Permit

13. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623] Federally Enforceable Through Title V Permit

14. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623] Federally Enforceable Through Title V Permit

15. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 4623] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1097-11 **EXPIRATION DATE:** 02/28/2017

SECTION: NW05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
43,000 BBL FIXED ROOF CRUDE OIL SURGE TANK #8 SERVED BY VAPOR RECOVERY SYSTEM LISTED ON S-1131-598

DRAFT

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 6.4 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Tank seams, welds, joints, piping, valves and fittings shall be inspected for gas leaks. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours after detection of the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

8. All piping, fittings, valves, and tank gauging or sampling devices shall be inspected annually by the facility operator to ensure compliance with the provisions of this permit. However, if two (2) percent or more of the components of any type subject to the requirements of this permit are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If less than two percent of the components of that type are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

9. Operator shall determine the presence of VOC leaks by EPA Method 21. The instrument shall be calibrated before use each day of its use by the procedures specified in Method 21 using the following calibration gases; 1.) Zero air (less than 10 ppm of hydrocarbon in air); and 2.) A mixture of methane or n-hexane and air at a concentration of about, but less than, 10,000 ppm methane or n-hexane [40 CFR 60.112b(a)(3)(i)] Federally Enforceable Through Title V Permit

10. A facility operator, upon detection of a leaking component, shall affix to that component a weatherproof readily visible tag bearing the date on which the leak is detected. The tag shall remain in place until the leaking component is repaired, reinspected, and found to be in compliance with the requirements of this permit. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired; 4) Identification and location of essential parts of critical process units found leaking that cannot be repaired until the next process unit turnaround; and 5) Method used to minimize the leak from essential parts of critical process units which cannot be repaired until the next process unit turnaround. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit

13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. Operator shall maintain a record showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel. [40 CFR 60.116b(b)] Federally Enforceable Through Title V Permit
20. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Compliance with permit conditions in the Title V permit shall be deemed compliance with 40 CFR 60 Subpart Kb (except 60.113b(c)). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
22. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
23. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
24. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
25. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit
26. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
27. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit
28. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit
29. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit
30. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit
31. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1106-17 **EXPIRATION DATE:** 02/28/2017

SECTION: 25/36 **TOWNSHIP:** 28S **RANGE:** 27E

DRAFT

EQUIPMENT DESCRIPTION:
TEOR OPERATION CONSISTING OF 140 STEAM-ENHANCED CRUDE OIL PRODUCTION WELLS WITH VAPOR CONTROL SYSTEM INCLUDING ELECTRIC COMPRESSOR(S) AND HIGH POINT SEPARATOR(S) CONNECTED TO STATION 36 PRODUCTION LINE (S-1131-598), FLARE S-1131-1086, FLARE S-1131-1087 OR FLARE S-1131-1108

PERMIT UNIT REQUIREMENTS

1. {1829} The facility shall submit an application to modify the Title V permit in accordance with the timeframes and procedures of District Rule 2520. [District Rule 2520] Federally Enforceable Through Title V Permit
2. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
3. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs prior to blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit
4. Except for fluids from the well casing, fluids produced from these steam-enhanced wells shall be introduced only to tanks vented to a District approved vapor collection and control system, or to permit exempt storage equipment as defined by Rule 2020, Section 6.6. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The well casing vents shall either be (1) connected to the well casing vapor collection system that serves this permit unit; (2) connected to the Station 36 production pipeline; (3) connected to the Station 36 tank vapor control system listed on S-1131-598; or (4) connected to flare S-1131-1086, flare S-1131-1087 or flare S-1131-1108. [District Rule 2201] Federally Enforceable Through Title V Permit
6. High point separators shall vent only to flares S-1131-1086, '-1087, and '-1108 and/or to tank vapor control system S-1131-598. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall maintain a map of the high point separators and it shall be kept at the facility, updated annually, and made readily available to the District upon request. . [District Rule 2201] Federally Enforceable Through Title V Permit
8. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
9. The VOC content of the casing gas shall not exceed 10% by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Operator shall conduct quarterly sampling of the well casing gas. If the gas sampled is 10% or less VOC by weight for eight consecutive quarterly samplings, the sampling frequency shall only be required annually. If a test shows noncompliance with the percent VOC requirement, the source must return to quarterly testing until eight consecutive quarters show compliance. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

12. The inspection requirements of Section 5.4.1 through Section 5.4.7 of Rule 4401 shall not apply to components exclusively handling gas/vapor or liquid with a VOC content of ten percent by weight (10%) or less, as determined by the test methods in Section 6.3.4 of Rule 4401. [District Rule 4401, 4.7] Federally Enforceable Through Title V Permit

13. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401, 3.20] Federally Enforceable Through Title V Permit

14. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1 and 5.1] Federally Enforceable Through Title V Permit

15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit

16. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit

17. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit

18. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit

19. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit

20. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit

21. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
23. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
24. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
25. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
26. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
27. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401 5.5] Federally Enforceable Through Title V Permit
28. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
29. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
30. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
31. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
32. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

33. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit

34. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

35. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

36. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

37. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

38. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401 6.1] Federally Enforceable Through Title V Permit

39. The results of gauge tank TVP testing conducted pursuant to Section 6.2.3 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

40. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

41. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. A process system as defined in Section 3.30 of Rule 4401 is not subject to compliance source testing requirements. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

42. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection are controlled by an internal combustion engine subject to Rule 4702, a combustion device subject to Rule 4320, 4307 or 4308, a flare subject to Rule 4311. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

43. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.0 of Rule 4401: Conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.9 of Rule 4401. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

44. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

45. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

46. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

47. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

48. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401, 6.4] Federally Enforceable Through Title V Permit

49. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401, 6.1 and 6.5] Federally Enforceable Through Title V Permit

50. Operator shall keep a list of all gauge tanks, as defined in Section 3.0 of Rule 4401. The list shall contain the size, identification number, the location of each gauge tank and specify whether the gauge tank is upstream of all front line production equipment. [District Rule 4401, 6.1 and 6.6] Federally Enforceable Through Title V Permit

51. By January 30 of each year, an operator shall submit to the APCO for approval, in writing, an annual report indicating any changes to an existing Operator Management Plan. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

52. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1108-5 **EXPIRATION DATE:** 02/28/2017

DRAFT

EQUIPMENT DESCRIPTION:
83.0 MMBTU/HR AIR ASSISTED LOW USE FLARE WITH AUTOMATIC IGNITION AND NATURAL GAS PILOT ASSEMBLY OPERATED AT MULTIPLE SPECIFIED LOCATIONS WITHIN CHEVRON USA'S HEAVY OIL CENTRAL STATIONARY SOURCE

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modifications, except for changes specified in the conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. This unit may be designated as a dormant emissions unit or an active emissions unit. Permittee shall notify the District's Compliance Division in writing (US Mail, Fax or Email) within 7 days after re-designating this unit as a dormant or active emissions unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing and monitoring shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing and monitoring shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
8. Flare is authorized to operate only at Sections 25, 30, 31, 32, and 36 in T28S/R28E and Sections 5, 6, 7, and 8 in T29S/R28E. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made in writing no later than 48 hours after starting operation at the location. [District Rule 1070]
10. Thermally Enhanced Oil Recovery (TEOR)/ vapor control gas, natural gas, pilot gas, and purge gas lines to flare shall be equipped with volumetric flow rate indicator. [District Rules 2201; and 4311, 5.10, 6.7] Federally Enforceable Through Title V Permit
11. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark or darker than Ringelmann 1/4 or 5% opacity. [District Rule 2201] Federally Enforceable Through Title V Permit
12. The Thermally Enhanced Oil Recovery (TEOR)/vapor control gas line to the flare shall be equipped with a non-resettable totalizing volumetric flow meter. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. A flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit

14. Flare shall be equipped with a natural gas-fired pilot and an automatic re-ignition system. [District Rules 2201; and 4311, 5.3] Federally Enforceable Through Title V Permit

15. Flare shall be equipped with a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an equivalent device capable of continuously detecting at least one pilot flame or the flare flame is present. The flame detection device shall be kept operational at all times except during flare maintenance when the flare is isolated from gas flow. During essential planned power outages when the flare is operating, the pilot monitor is allowed to be non-functional if the flare flame is clearly visible to onsite operators. Effective on and after July 1, 2012, all pilot monitor downtime shall be reported annually pursuant to Rule 4311, section 6.2.3.6. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit

16. Only PUC quality natural gas shall be used as pilot fuel. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit

17. Maximum amount of flared gas and pilot gas combusted shall not exceed 199.177 MMBtu/day nor 53,943.8 MMBtu/yr. [District Rule 2201] Federally Enforceable Through Title V Permit

18. Emissions from the flare shall not exceed any of the following limits (based on total gas combusted): NOx (as NO2): 0.068 lb/MMBtu; PM10: 0.008 lb/MMBtu; CO: 0.37 lb/MMBtu; or VOC: 0.063 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

19. Sulfur content of flared gas and pilot gas shall not exceed 1.0 gr/100scf. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit

20. If the flare uses a flow-sensing automatic ignition system and does not use a continuous flame pilot, the flare shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit

21. Open flares in which the flare gas pressure is less than 5 psig shall be operated in such a manner that meets the provisions of 40 CFR 60.18. [District Rule 4311, 5.6] Federally Enforceable Through Title V Permit

22. Operator shall monitor vent gas composition using one of the five following methods: 1) Sampling vent gas pursuant to Rule 4311 Section 6.6.1, 2) Integrated sampling pursuant to Rule 4311 Section 6.6.2, 3) Operate continuous analyzers that meet the requirements of Rule 4311 Section 6.6.3, 4) Operate continuous analyzers employing gas chromatography pursuant to Rule 4311 Section 6.6.4, or 5) Monitor sulfur content using a colorimetric tube system, and monitor vent gas hydrocarbons pursuant to Rule 4311 Section 6.6.5. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

23. Operator shall monitor the volumetric flows of purge and pilot gases. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

24. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. The operator shall provide the APCO with access to the monitoring system to collect vent gas samples to verify the analysis required by Rule 4311 Section 5.11. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

25. Operator shall report periods of monitor inoperation greater than 24 continuous hours by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

26. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Rule 4311 Section 6.3.4. During periods of inoperation of flow monitors, flow shall be calculated using good engineering practices. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

27. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

28. All in-line continuous analyzer and flow monitoring data must be continuously recorded by an electronic data acquisition system capable of one-minute averages. Flow monitoring data shall be recorded as one-minute averages. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

29. Measured heating value and quantity of flared gas shall be used to determine compliance with heat input limits. [District Rule 2201] Federally Enforceable Through Title V Permit

30. Flared gas and pilot gas shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a flared gas and pilot gas, then the testing frequency shall be quarterly. If a quarterly testing fails to show compliance, weekly testing shall resume. [District Rule 1070]

31. Sulfur content of flared gas and pilot gas shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD, double GC for H2S and mercaptans, performed in the laboratory. Should the applicant decided to use different methodology, the methodology must be approved by the District prior to its use. [District Rule 1070]

32. Higher heating value of flared gas and pilot gas shall be determined using ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 1070]

33. The flare shall be operated according to the manufacturer's specifications, a copy of which shall be maintained on site. [District Rule 2201] Federally Enforceable Through Title V Permit

34. Permittee shall maintain accurate records of types of pilot gas and flared gas, sulfur contents of flared gas and pilot gas, higher heating values of flared and pilot gas, and daily and annual quantities of flared gas and pilot gas combusted in the flare. [District Rule 2201] Federally Enforceable Through Title V Permit

35. The operator shall notify the District of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, whichever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

36. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that summarizes all reportable flaring events during the previous 12-month period. The report shall include the following: 1) The results of an investigation to determine the primary cause and contributing factors of the flaring event; 2) Any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; 3) If appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and 4) The date, time, and duration of the flaring event. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

37. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that includes the following: 1) The total volumetric flow of vent gas in standard cubic feet for each day; 2) Hydrogen sulfide content, methane content, and hydrocarbon content of vent gas composition pursuant to Section 6.6; 3) If vent gas composition is monitored by a continuous analyzer or analyzers pursuant to Section 5.11, average total hydrocarbon content by volume, average methane content by volume, and depending upon the analytical method used pursuant to Section 6.3.4, total reduced sulfur content by volume or hydrogen sulfide content by volume of vent gas flared for each hour of the month; 4) If the flow monitor used pursuant to Section 5.10 measures molecular weight, the average molecular weight for each hour of each month; 5) For any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month, and the means used to determine flow; 6) Flare monitoring system downtime periods, including dates and times; 7) For each day and for each month provide calculated sulfur dioxide emissions; and 8) A flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing pursuant to Section 6.3.5. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

38. Vent gas composition shall be monitored using one of the methods outlined in Rule 4311, Section 6.6.1 through 6.6.5. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. [District Rule 4311, 6.6] Federally Enforceable Through Title V Permit

39. Periods of flare monitoring system inoperation greater than 24 continuous hours shall be reported by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

40. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Section 6.3.4. During periods of inoperation of flow monitors required by Section 5.10, flow shall be calculated using good engineering practices. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

41. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device in question. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

42. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4311, 6.1] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1117-3 **EXPIRATION DATE:** 02/28/2017

DRAFT

EQUIPMENT DESCRIPTION:
480 HP CATERPILLAR MODEL C9 DIESEL-FIRED EMERGENCY IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.0] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 5.7; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702, 3.15] Federally Enforceable Through Title V Permit
5. During or before periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702, 5.7] Federally Enforceable Through Title V Permit
6. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 3.15; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
7. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702, 3.15] Federally Enforceable Through Title V Permit
8. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
9. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201; 4801, 3.1; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
10. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702, 5.7; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Emissions from this IC engine shall not exceed any of the following limits: 2.61 g-NOx/bhp-hr, 2.31 g-CO/bhp-hr, or 0.15 g-VOC/bhp-hr. [District Rule 2201; 13 CCR 2423; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit

12. Emissions from this IC engine shall not exceed 0.11 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201; 4102; 13 CCR 2423; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit

13. U.S. EPA administers the requirements of 40 CFR Part 60 Subpart IIII. The owner or operator shall comply with the emission and operating limitations, testing requirements, initial and continuous compliance requirements as specified in this subpart. The owner or operator shall submit all applicable notifications, reports, and records to the administrator by the required compliance dates. [District Rule 4001] Federally Enforceable Through Title V Permit

14. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 6.2; and 17 CCR 93115] Federally Enforceable Through Title V Permit

15. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [17 CCR 93115] Federally Enforceable Through Title V Permit

16. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 6.2; and 17 CCR 93115] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1119-6

EXPIRATION DATE: 02/28/2017

DRAFT

EQUIPMENT DESCRIPTION:
EPA-TIER 3 CERTIFIED DIESEL-FIRED TRANSPORTABLE IC ENGINE UPTO 532 HP POWERING MECHANICAL PUMP, COMPRESSOR, OR ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Permittee shall provide written notification to the District within 48 hours of operating an engine under this permit (if an engine is located onsite longer than 24 hours). Such notification shall include the date the unit was brought onsite, the manufacturer, model number, maximum rating, and emissions information that documents that the unit meets the emission limits and requirements specified in the permit. [District Rule 1070]
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The exhaust stack of any IC engine utilized for this permit unit shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
4. Any IC engine utilized for this permit unit shall not be located within 1000 feet of any receptor or any K-12 school. [District Rule 4102; and CH&SC 42301.6]
5. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used in any IC engine utilized for this permit unit. [District Rules 2201; 4801, 3.1; 17 CCR 93116; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
6. Emissions from any IC engine utilized for this permit unit shall not exceed any of the following limits: 2.80 g-NOx/bhp-hr, 2.60 g-CO/bhp-hr, or 0.20 g-VOC/bhp-hr. [District Rule 2201; 17 CCR 93115; and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
7. Emissions from any IC engine utilized for this permit shall not exceed 0.15 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201; 4102; 13 CCR 2423; 17 CCR 93116; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
8. Total operation of this permit unit shall not exceed 300 hours per year on a rolling month average. [District Rules 2201; and 4102] Federally Enforceable Through Title V Permit
9. Any IC engine utilized for this permit unit shall not be operated at any single location (as defined in Rule 4701) for more than 12 consecutive months. [District Rule 4701, 3.24; and 40 CFR Part 89] Federally Enforceable Through Title V Permit
10. Any IC engine utilized for this permit unit shall be operated in accordance with the requirements of the Code of Federal Regulations [District Rule 2201; and 40 CFR Part 89] Federally Enforceable Through Title V Permit
11. Any IC engine utilized for this permit unit shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702, 5.7; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. During or before periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702, 5.7] Federally Enforceable Through Title V Permit

13. Any IC engine utilized for this permit unit shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 5.7; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit

14. U.S. EPA administers the requirements of 40 CFR Part 60 Subpart IIII. The owner or operator shall comply with the emission and operating limitations, testing requirements, initial and continuous compliance requirements as specified in this subpart. The owner or operator shall submit all applicable notifications, reports, and records to the administrator by the required compliance dates. [District Rule 4001]

15. The permittee shall maintain a permit unit operating log that shall include the following: a record of the cumulative annual hours of operation of the engine, the quantity of diesel fuel used, and a record of maintenance or modifications performed on any IC engine utilized for this permit unit. These records shall be updated on a monthly basis. [District Rule 4702, 6.2; and 17 CCR 93115] Federally Enforceable Through Title V Permit

16. The permittee shall maintain records of each location where the permit unit is operated, including dates and duration of residency at each location, and shall update those records each time any IC engine utilized for this permit unit is moved . [District Rule 2201; 40 CFR 89; and 17 CCR 93116] Federally Enforceable Through Title V Permit

17. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 6.2; and 17 CCR 93115] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1120-2

EXPIRATION DATE: 02/28/2017

SECTION: 5 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
1000 GALLON OIL TREATMENT CHEMICAL TANK

DRAFT

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 1.5 psia under all storage conditions. [District Rules 2201] Federally Enforceable Through Title V Permit
2. VOC emission rate from the tank shall not exceed 0.3 lb/day, [District Rule 2201] Federally Enforceable Through Title V Permit
3. The tank shall be equipped with a fixed roof with no holes or openings. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fluid throughput shall not exceed 55 gallons per day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Permittee shall maintain daily records of fluid throughput and shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, and TVP. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1127-3 **EXPIRATION DATE:** 02/28/2017

SECTION: NE 18 **TOWNSHIP:** 28S **RANGE:** 28E

DRAFT

EQUIPMENT DESCRIPTION:
THERMALLY ENHANCED OIL RECOVERY OPERATION (TEOR) SERVING UP TO 60 STEAM ENHANCED WELLS WITH WELL VENT COLLECTION AND CONTROL SYSTEM VENTED TO STATION 36 TVR SYSTEM S-1131-598 (MCWORTER LEASE)

PERMIT UNIT REQUIREMENTS

1. A current and complete listing of all steam enhanced wells connected to this system shall be maintained with the Permit to Operate. [District Rule 2201] Federally Enforceable Through Title V Permit
2. All steam enhanced wells shall be equipped with a vapor loss prevention system consisting of vapor and condensate collection systems with a control device capable of reducing VOC emissions by at least 99%. [District Rules 2201 and 4401] Federally Enforceable Through Title V Permit
3. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
4. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401] Federally Enforceable Through Title V Permit
5. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
6. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
7. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401] Federally Enforceable Through Title V Permit
9. Fugitive VOC emissions from components in vapor and condensate service shall not exceed 2.5 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
10. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Permittee shall determine sulfur content of scrubbed TEOR gas weekly for eight consecutive weeks. After demonstrating compliance for eight consecutive weeks testing may be conducted on a quarterly basis. Weekly sulfur testing shall resume if quarterly testing does not indicate compliance. Weekly gas analysis shall be performed using Draeger tubes and quarterly analysis using ASTM method D3246 or double GC for H2S and mercaptans. First of the weekly gas analyses shall be done using laboratory analysis. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
12. There shall be no leaks in excess of 10,000 ppmv from components in vapor service when measured with a portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. [District Rule 2201] Federally Enforceable Through Title V Permit
13. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
14. Permittee shall inspect all components service quarterly for leaks with a portable hydrocarbon detection instrument to ensure compliance with the provisions of this permit. [District Rule 2201 and 4401] Federally Enforceable Through Title V Permit
15. The inspection requirements of Section 5.4.1 through Section 5.4.7 of Rule 4401 shall not apply to components exclusively handling gas/vapor or liquid with a VOC content of ten percent by weight (10%) or less, as determined by the test methods in Section 6.3.4 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
16. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
17. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401] Federally Enforceable Through Title V Permit
18. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
19. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401] Federally Enforceable Through Title V Permit
21. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401] Federally Enforceable Through Title V Permit
22. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401] Federally Enforceable Through Title V Permit
23. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401] Federally Enforceable Through Title V Permit
24. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401] Federally Enforceable Through Title V Permit
25. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401] Federally Enforceable Through Title V Permit
26. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401] Federally Enforceable Through Title V Permit
27. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401] Federally Enforceable Through Title V Permit
28. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
29. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
30. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401] Federally Enforceable Through Title V Permit
31. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401] Federally Enforceable Through Title V Permit

33. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401] Federally Enforceable Through Title V Permit

34. The results of gauge tank TVP testing conducted pursuant to Section 6.2.3 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401] Federally Enforceable Through Title V Permit

35. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. A process system as defined in Section 3.30 of Rule 4401 is not subject to compliance source testing requirements. [District Rule 4401] Federally Enforceable Through Title V Permit

36. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection are controlled by an internal combustion engine subject to Rule 4702, a combustion device subject to Rule 4320, 4307 or 4308, a flare subject to Rule 4311. [District Rule 4401] Federally Enforceable Through Title V Permit

37. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.0 of Rule 4401: Conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.9 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

38. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401] Federally Enforceable Through Title V Permit

39. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401] Federally Enforceable Through Title V Permit

40. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401] Federally Enforceable Through Title V Permit

41. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

42. Permittee shall maintain with the permit accurate fugitive component counts for vapor control system according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Range emission factors. [District Rule 2201] Federally Enforceable Through Title V Permit

43. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit

44. Permittee shall maintain records of quarterly inspections including measured leaks greater than 10,000 ppm. [District Rule 2201] Federally Enforceable Through Title V Permit

45. By January 30 of each year, an operator shall submit to the APCO for approval, in writing, an annual report indicating any changes to an existing Operator Management Plan. [District Rule 4401] Federally Enforceable Through Title V Permit

46. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

47. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401] Federally Enforceable Through Title V Permit

48. Operator shall keep a list of all gauge tanks, as defined in Section 3.0 of Rule 4401. The list shall contain the size, identification number, the location of each gauge tank and specify whether the gauge tank is upstream of all front line production equipment. [District Rule 4401] Federally Enforceable Through Title V Permit

49. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401] Federally Enforceable Through Title V Permit

50. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

51. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401] Federally Enforceable Through Title V Permit

52. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4401] Federally Enforceable Through Title V Permit

53. All records required by this permit shall be maintained and retained on-site for a minimum of five (5) years and made available for District, ARB, and EPA inspection upon request. [District Rule 1070]

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1134-1 **EXPIRATION DATE:** 02/28/2017

SECTION: SE 31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
85.0 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (ANO 6; DIS# 41754-15), WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (FGR) (ANO)

PERMIT UNIT REQUIREMENTS

1. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The permittee's request for approval of equivalent equipment shall include the make, model, manufacturer's maximum rating, manufacturer's guaranteed emission rates, equipment drawing(s), and other relevant operational characteristics. [District Rule 2201] Federally Enforceable Through Title V Permit
3. A burner is not equivalent if any of the emission factors or the maximum heat input rating is greater than those authorized in this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
5. This unit shall be fired on PUC quality natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Fuel gas shall not contain more than 1 grain of total sulfur per 100 standard cubic feet or 0.00285 lb/MMBtu. [District Rule 2201, 4320 and 4801] Federally Enforceable Through Title V Permit
7. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
9. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102] Federally Enforceable Through Title V Permit
10. During the 60-day shakedown period, the operator shall operate the burner with the maximum FGR setting that can be accommodated by the specific commissioning activity being undertaken, perform expeditious completion of commissioning activities, and shall use good work practice standards to minimize emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Except during startup and shutdown periods, and the 60-day shakedown period, emissions shall not exceed either of the following limits: 7 ppmvd NOx (as NO2) @ 3% O2 (0.0085 lb/MMBtu), 0.003 lb PM10/MMBtu, 25 ppmvd CO @ 3% O2 (0.0185 lb/MMBtu) or 12 ppmvd VOC @ 3% O2 (0.0055 lb VOC/MMBtu). [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. During the 60-day shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx (as NO2) @ 3% O2 (0.018 lb/MMBtu), 0.0032 lb PM10/MMBtu, 50 ppmvd CO @ 3% O2 (0.037 lb/MMBtu) or 12 ppmvd VOC @ 3% O2 (0.0055 lb VOC/MMBtu). [District Rule 2201] Federally Enforceable Through Title V Permit

13. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit

15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOX, CO, and O2 at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3%, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

18. All NOx, CO, and O2 emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The NOx, CO, and O2 analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute sample period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

19. The permittee shall maintain records of: (1) the date and time of NOx, CO and O2 measurements, (2) the O2 concentration in percent by volume and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

20. A source test to demonstrate compliance with NOx and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

26. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100, Stack Gas Velocity (ft/min) - EPA Method 2, Stack Gas Moisture Content (%) - EPA Method 4, SOx (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6A, 6B, 6C or fuel gas sulfur content analysis and EPA Method 19, Fuel Gas Sulfur Content - EPA Method 11 or 15, ASTM D1072, D3031, D4084 D3246 or grab sample analysis by GC-FPD/TCD or double GC for H2S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588, PM10 - EPA Methods 5, 201A, and/or 202, CARB Method 5, or any combination of these PM10 methods with both filterable and condensable PM10 measured. [District Rules 1081, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

27. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Each fuel source shall be tested semi-annually for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which semi-annual testing may resume. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1135-1 **EXPIRATION DATE:** 02/28/2017

SECTION: SE 13 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:
85.0 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR (ANGUS 3; DIS# 41753-15), WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (FGR) (ANGUS)

PERMIT UNIT REQUIREMENTS

1. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The permittee's request for approval of equivalent equipment shall include the make, model, manufacturer's maximum rating, manufacturer's guaranteed emission rates, equipment drawing(s), and other relevant operational characteristics. [District Rule 2201] Federally Enforceable Through Title V Permit
3. A burner is not equivalent if any of the emission factors or the maximum heat input rating is greater than those authorized in this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] Federally Enforceable Through Title V Permit
5. This unit shall be fired on PUC quality natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Fuel gas shall not contain more than 1 grain of total sulfur per 100 standard cubic feet or 0.00285 lb/MMBtu. [District Rule 2201, 4320 and 4801] Federally Enforceable Through Title V Permit
7. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
8. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
9. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102] Federally Enforceable Through Title V Permit
10. During the 60-day shakedown period, the operator shall operate the burner with the maximum FGR setting that can be accommodated by the specific commissioning activity being undertaken, perform expeditious completion of commissioning activities, and shall use good work practice standards to minimize emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Except during startup and shutdown periods, and the 60-day shakedown period, emissions shall not exceed either of the following limits: 7 ppmvd NOx (as NO2) @ 3% O2 (0.0085 lb/MMBtu), 0.003 lb PM10/MMBtu, 25 ppmvd CO @ 3% O2 (0.0185 lb/MMBtu) or 12 ppmvd VOC @ 3% O2 (0.0055 lb VOC/MMBtu). [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. During the 60-day shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx (as NO2) @ 3% O2 (0.018 lb/MMBtu), 0.0032 lb PM10/MMBtu, 50 ppmvd CO @ 3% O2 (0.037 lb/MMBtu) or 12 ppmvd VOC @ 3% O2 (0.0055 lb VOC/MMBtu). [District Rule 2201] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit
16. The permittee shall monitor and record the stack concentration of NOX, CO, and O2 at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
17. If either the NOx or CO concentrations corrected to 3%, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
18. All NOx, CO, and O2 emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The NOx, CO, and O2 analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute sample period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
19. The permittee shall maintain records of: (1) the date and time of NOx, CO and O2 measurements, (2) the O2 concentration in percent by volume and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit
20. A source test to demonstrate compliance with NOx and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

25. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

26. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100, Stack Gas Velocity (ft/min) - EPA Method 2, Stack Gas Moisture Content (%) - EPA Method 4, SOx (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6A, 6B, 6C or fuel gas sulfur content analysis and EPA Method 19, Fuel Gas Sulfur Content - EPA Method 11 or 15, ASTM D1072, D3031, D4084 D3246 or grab sample analysis by GC-FPD/TCD or double GC for H2S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588, PM10 - EPA Methods 5, 201A, and/or 202, CARB Method 5, or any combination of these PM10 methods with both filterable and condensable PM10 measured. [District Rules 1081, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

27. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

28. Each fuel source shall be tested semi-annually for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which semi-annual testing may resume. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1140-1

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SW3 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (34-3; DIS #43006-74) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SEC 3 LOWER)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
7. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
9. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
12. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
16. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
24. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
29. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

31. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit

35. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

36. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

37. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1141-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (40-32; DIS# 43001-75) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (MONTE CRISTO 2)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

15. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

17. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

18. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

19. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520. 9.3.2] Federally Enforceable Through Title V Permit
21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
23. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
26. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
27. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
28. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
29. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
30. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
32. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

33. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

34. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

35. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

36. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

37. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

38. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1142-1 **EXPIRATION DATE:** 02/28/2017

SECTION: NW09 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (43-9; DIS# 43010-75) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (KCL 39)

DRAFT

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 4305, 4351, 4306 and 4320] Federally Enforceable Through Title V Permit
7. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

37. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rules 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit

38. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1, and 4320] Federally Enforceable Through Title V Permit

39. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

40. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1143-1 **EXPIRATION DATE:** 02/28/2017

SECTION: NW09 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (44-9; DIS #43007-75) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (KCL 39)

DRAFT

PERMIT UNIT REQUIREMENTS

1. Flue gas recirculation shall be utilized, as needed, in conjunction with low-NOx burner to maintain ongoing compliance with permitted emission limits. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
3. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
7. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

8. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit

9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit

11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit

13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

17. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit

18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
25. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

36. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1144-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 9 **TOWNSHIP:** 29S **RANGE:** 28E

DRAFT

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (45-9; DIS #43008-75) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (KCL 39)

PERMIT UNIT REQUIREMENTS

1. Flue gas recirculation shall be utilized, as needed, in conjunction with low-NOx burner to maintain ongoing compliance with permitted emission limits. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
3. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
4. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520] Federally Enforceable Through Title V Permit
7. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
8. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit

37. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

38. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

39. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1145-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 9 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (46-9; DIS #43009-75) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (KCL 39)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
3. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
7. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
25. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit

36. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1146-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

DRAFT

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (49-5; DIS# 43003-76) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (MONTE CRISTO 1)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, and 4351] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
9. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit
10. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
12. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
13. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
15. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

DRAFT

21. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

37. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

38. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

39. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

40. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1147-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 5 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (50-5; DIS# 4005-76) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (MONTE CRISTO 1)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, 4320, and 4351] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
9. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit
10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

22. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit

26. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

30. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

37. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

38. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

39. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1148-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (51-5; DIS #43004-76) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (MONTE CRISTO 1)

DRAFT

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
3. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
7. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
25. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit

36. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1149-1 **EXPIRATION DATE:** 02/28/2017

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (35-3; DIS# 43007-74) NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SEC 3 LOWER)

DRAFT

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, 4351, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
9. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

22. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit

26. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

30. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1150-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (36-3; DIS# 43008-74) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (SEC 3 LOWER)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

15. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

17. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520. 9.3.2] Federally Enforceable Through Title V Permit
21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
23. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
26. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
27. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
28. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
29. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
30. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

33. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

34. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

35. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

36. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

37. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

38. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1151-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (42-3; DIS# 43003-75) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (SEC 3 UPPER)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. {1400} The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

15. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

17. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rule 4305] Federally Enforceable Through Title V Permit
19. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
20. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
21. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
22. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
23. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. The permittee shall keep daily records of the sulfur content of the natural gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted and shall make records available for inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
27. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
29. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
30. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

32. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

33. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

35. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

36. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

37. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

38. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

39. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

40. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1152-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (65-3; DIS# 43006-80) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (SEC 3 UPPER)

DRAFT

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. {1400} The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

15. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

17. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

18. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
20. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
21. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O2, NOx concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520, 9.5.1] Federally Enforceable Through Title V Permit
25. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
28. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
29. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
31. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit
32. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

33. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

34. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

35. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

36. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

37. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

38. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1153-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (67; DIS# 43008-80) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (ANGUS)

DRAFT

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, 4351, and Rule 4306] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
9. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520] Federally Enforceable Through Title V Permit
13. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
15. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

21. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit

27. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

37. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

38. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1, and 4320] Federally Enforceable Through Title V Permit

39. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

40. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1154-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 09 **TOWNSHIP:** 29S **RANGE:** 28E

DRAFT

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (64-9; DIS# 43005-80) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (KCL 39)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 4305, 4351, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081 and 2520] Federally Enforceable Through Title V Permit
8. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O2, NOx concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

9. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
10. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
12. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
13. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
15. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

37. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit

38. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1, and 4320] Federally Enforceable Through Title V Permit

39. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

40. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1155-1 **EXPIRATION DATE:** 02/28/2017

SECTION: NW5 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (81-4; DIS# 43013-82) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (MONTE CRISTO 1)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, and 4351] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by a District-approved independent laboratory on an annual basis. Sample collection for such determination shall be District-witnessed or approved. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
8. Permittee shall keep weekly records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
10. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
12. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
13. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
15. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit

27. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

37. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

38. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

39. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1156-1 **EXPIRATION DATE:** 02/28/2017

SECTION: NW 3 **TOWNSHIP:** 29S **RANGE:** 28E

DRAFT

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (80-4; DIS #43010-82) WITH NORTH AMERICAN GLE LOW NOX BURNER, AND FLUE GAS RECIRCULATION (SEC 3 UPPER)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District RuleS 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520] Federally Enforceable Through Title V Permit
5. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
6. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
7. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
9. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201 and 4306] Federally Enforceable Through Title V Permit
11. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
14. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
15. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

22. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit

23. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

25. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

27. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

28. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

29. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

31. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit

34. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

35. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

36. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1157-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

DRAFT

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (79-4, DIS# 43009-82) (SEC 4)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected or prevented from entering this unit. [District NSR Rule and District Rule 2080] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

DRAFT

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. {1400} The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

15. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

16. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

17. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

18. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

19. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

20. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

21. Emission rates shall not exceed PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, and CO: 0.021 lb/MMBtu. [District NSR Rule and District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

22. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District NSR Rule] Federally Enforceable Through Title V Permit

23. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

24. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit

25. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit

26. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit

27. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

28. NOx and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

29. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O2, NOx concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520, 9.3.2] Federally Enforceable Through Title V Permit

32. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. This mean shall be multiplied by the appropriate factor. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

33. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

34. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

35. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

36. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit

37. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1158-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (53-32; DIS# 43012-78) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (MONTE CRISTO 2)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. {1400} The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

15. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

17. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rule 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
20. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
21. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
22. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
23. NOx and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
27. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
29. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
30. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

33. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

34. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

35. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

36. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

37. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1159-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (77-32; DIS# 43011-82) WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (MONTE CRISTO 2)

DRAFT

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. {1400} The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

14. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

15. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

16. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

17. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

19. {1669} This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

20. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

21. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2, and 2520, 9.5.1] Federally Enforceable Through Title V Permit

22. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

23. NOx and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit

27. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. This mean shall be multiplied by the appropriate factor. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

29. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit

30. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

32. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

33. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

34. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

35. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

36. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

37. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520 section 6.4.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

DRAFT

PERMIT UNIT: S-1131-1160-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT A, DIS# 47003-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL

PERMIT UNIT REQUIREMENTS

1. Operation shall include GE LM-2500-PE gas fired 240 MMBtu/hr (nominal rating) gas turbine engine, 22.3 MW electrical generator, inlet air evaporative cooler, turbine combustor water injectors, gas-fired Coen duct burner rated at 70 MM Btu/hr (nominal rating), Nooter heat recovery steam generator, CO oxidizing catalyst, ammonia injection grid, selective catalytic reduction (SCR) bed, and in-stack continuous emissions monitors (CEMs) for NOx, CO, and O2. [District Rule 2010] Federally Enforceable Through Title V Permit
2. {719} Unit shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(a) & (b); 60.332(a); Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
3. {720} Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
4. {724} Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Rule 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), Rule 110 (Madera), and Rule 108 (Kings); District Rule 1081] Federally Enforceable Through Title V Permit
5. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246 or grab bag analysis by GC-FPD/TCD performed in the laboratory. [40 CFR 60.335(d)] Federally Enforceable Through Title V Permit
6. {726} If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)] Federally Enforceable Through Title V Permit
7. The HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, OR ASTM 1945. [40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
8. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.332(a),(b) and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Unit shall demonstrate compliance annually with NOx and CO emissions limits with the duct burner in operation and not in operation. An annual demonstration of compliance with the duct burner in operation is not required in any year in which the duct burner is not operated at all in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of resumption of operation of the duct burner. An annual demonstration of compliance with the duct burner not in operation is not required in any year in which the duct burner operated continuously in conjunction with the turbine in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of shutdown of operation of the duct burner. [40 CFR 60.335(b) and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit

10. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.2] Federally Enforceable Through Title V Permit

11. {802} Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.3 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit

12. If the turbine is fired on PUC-regulated natural gas, then the operator shall maintain a log describing the source of natural gas and the quantity used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

13. Results of continuous emission monitoring must be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(a),(b),(c) and District Rule 4703, 5.0] Federally Enforceable Through Title V Permit

14. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(a),(b) and District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit

15. Operator shall operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 concentration . [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit

16. {808} The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit

17. {748} A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 9.0] Federally Enforceable Through Title V Permit

18. {809} The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit

19. {810} Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Sulfur content of gas burned shall not exceed 1.0 gr/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
21. Gas turbine engine shall be equipped with continuously recording fuel gas flowmeter. [District Rules 1070 and 4703] Federally Enforceable Through Title V Permit
22. Daily emissions shall not exceed any of the following: PM10: 89.3 lb/day, SOx (as SO2): 29.8 lb/day, NOx (as NO2): 133.9 lb/day, VOC: 245.5 lb/day, or CO: 223.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
23. Ammonia (NH3) emissions shall not exceed 21 ppmvd @ 15% O2 over a 24-hour average period. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
24. Ammonia slip shall be calculated as: slip = (a-bxc/1,000,000) x 1,000,000/b, where a=ammonia injection rate(lb/hr)/17(lb/lb.mol), and b=dry exhaust gas flow rate (lb/hr)/29(lb/lb.mol); and c=change in measured NOx concentration in ppmvd at the actual stack oxygen (O2) concentration or by another method approved by the District. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
25. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 4001] Federally Enforceable Through Title V Permit
26. Transitional operation period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
27. Except during periods of gas turbine engine startup/shutdown, and transitional operation period, emission rates (three-hour average) shall not exceed any of the following: PM10: 0.012 lb/MMBtu, SOx (as SO2): 0.004 lb/MMBtu; or VOC: 0.033 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
28. Maximum NOx emission rate (one hour average) shall not exceed the NSPS standard of 105 ppmv dry @ 15% O2. [District Rule 4001] Federally Enforceable Through Title V Permit
29. Except during periods of gas turbine engine startup/shutdown, and transitional operation period, emission rates (based on three-hour rolling average) shall not exceed either of the following: NOx (as NO2): 5 ppmv dry @ 15% oxygen (O2); or CO: 13.5 ppmv @ 15% oxygen (O2). [District Rule 4703, 5.1.2, 5.2 and District NSR Rule] Federally Enforceable Through Title V Permit
30. Permittee shall report the following emission exceedences to the District: NOx emission rate on a three-hour average, NSPS NOx emission rate on one hour average, and DEL of NOx during days of gas turbine engine startup/shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
31. The three-hour average will be compiled from the three most recent one-hour periods, with each one-hour period commencing on the hour. [District Rule 1081] Federally Enforceable Through Title V Permit
32. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx daily emission limitation by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Permittee shall comply in full with Rule 4001 (New Source Performance Standards) requirements, including notification, recordkeeping and monitoring requirements. [District Rule 4001] Federally Enforceable Through Title V Permit
34. Continuous emissions monitoring system shall conform to Rule 1080 specifications. [District Rule 1080] Federally Enforceable Through Title V Permit
35. Continuous emission monitoring systems shall be calibrated and operated according to EPA guidelines as specified in CFR, Part 60, Appendix B. CEM ppm and lb/hr shall be calculated as a three-hour and a 1 hour average. [District Rules 4001 and 4703] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. Annual relative accuracy audits of CEM's shall be conducted by independent laboratory in accordance with EPA guidelines. The District shall be notified of the audit in advance and reports shall be submitted to the District within 60 days of each test. [District Rule 4001] Federally Enforceable Through Title V Permit

37. Permittee shall keep accurate records of turbine daily NOx (as NO2) and oxygen (O2) monitors output for a period of five years, and shall make such records readily available for District inspection upon request. [District Rules 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit

38. Compliance source testing for NOx, CO, and O2 shall be conducted at least once every 12 months under conditions representative of normal operation. [District NSR Rule and District Rule 4703, 6.3.1] Federally Enforceable Through Title V Permit

39. Compliance source testing shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

40. Source test protocol shall be submitted for District approval at least 15 days prior to test date. [District Rule 1081] Federally Enforceable Through Title V Permit

41. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

42. The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front half and back half) or 201A and 202 or CARB Method 5 (front and back half); ammonia - BAAQMD ST-1B; and O2 - EPA Method 3, 3A, or 20 or CARB Method 100. [40 CFR 60.335(a) and District Rules 2520 and 4703] Federally Enforceable Through Title V Permit

43. Exhaust stack following last economizer shall be of circular cross-section and shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods, including flow straighteners, if necessary, to minimize turbulence. [District Rule 1081] Federally Enforceable Through Title V Permit

44. Permittee shall maintain records of all fuel sulfur content testing performed. [District NSR Rule] Federally Enforceable Through Title V Permit

45. Permittee shall maintain daily records of the following: time of start-up(s) and shutdown(s), length and reason for reduced load periods, total hours of operation, and source(s) of and quantity of fuel used. [District Rules 1070 and 4703, 6.2.6] Federally Enforceable Through Title V Permit

46. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1161-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

DRAFT

EQUIPMENT DESCRIPTION:
22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT B, DIS# 47004-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL

PERMIT UNIT REQUIREMENTS

1. Operation shall include GE LM-2500-PE gas fired 240 MMBtu/hr (nominal rating) gas turbine engine, 22.3 MW electrical generator, inlet air evaporative cooler, turbine combustor water injectors, gas-fired Coen duct burner rated at 70 MM Btu/hr (nominal rating), Nooter heat recovery steam generator, CO oxidizing catalyst, ammonia injection grid, selective catalytic reduction (SCR) bed, and in-stack continuous emissions monitors (CEMs) for NOx, CO, and O2. [District Rule 2010] Federally Enforceable Through Title V Permit
2. {719} Unit shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(a) & (b); 60.332(a); Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
3. {720} Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
4. {724} Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Rule 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), Rule 110 (Madera), and Rule 108 (Kings); District Rule 1081] Federally Enforceable Through Title V Permit
5. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246 or grab bag analysis by GC-FPD/TCD performed in the laboratory. [40 CFR 60.335(d)] Federally Enforceable Through Title V Permit
6. {726} If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)] Federally Enforceable Through Title V Permit
7. The HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, OR ASTM 1945. [40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
8. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.332(a),(b) and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Unit shall demonstrate compliance annually with NOx and CO emissions limits with the duct burner in operation and not in operation. An annual demonstration of compliance with the duct burner in operation is not required in any year in which the duct burner is not operated at all in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of resumption of operation of the duct burner. An annual demonstration of compliance with the duct burner not in operation is not required in any year in which the duct burner operated continuously in conjunction with the turbine in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of shutdown of operation of the duct burner. [40 CFR 60.335(b) and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit

10. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.2] Federally Enforceable Through Title V Permit

11. {802} Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.3 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit

12. If the turbine is fired on PUC-regulated natural gas, then the operator shall maintain a log describing the source of natural gas and the quantity used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

13. Results of continuous emission monitoring must be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(a),(b),(c) and District Rule 4703, 5.0] Federally Enforceable Through Title V Permit

14. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(a),(b) and District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit

15. {807} Operator shall install, operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 concentration . [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit

16. {808} The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit

17. {748} A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 9.0] Federally Enforceable Through Title V Permit

18. {809} The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit

19. {810} Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Sulfur content of gas burned shall not exceed 1.0 gr/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
21. Gas turbine engine shall be equipped with continuously recording fuel gas flowmeter. [District Rules 1070 and 4703] Federally Enforceable Through Title V Permit
22. Daily emissions shall not exceed any of the following: PM10: 89.3 lb/day, SOx (as SO2): 29.8 lb/day, NOx (as NO2): 133.9 lb/day, VOC: 245.5 lb/day, or CO: 223.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
23. Ammonia (NH3) emissions shall not exceed 21 ppmvd @ 15% O2 over a 24-hour average period. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
24. Ammonia slip shall be calculated as: slip = (a-bxc/1,000,000) x 1,000,000/b, where a=ammonia injection rate(lb/hr)/17(lb/lb.mol), and b=dry exhaust gas flow rate (lb/hr)/29(lb/lb.mol); and c=change in measured NOx concentration in ppmvd at the actual stack oxygen (O2) concentration or by another method approved by the District. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
25. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 4001] Federally Enforceable Through Title V Permit
26. Transitional operation period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
27. Except during periods of gas turbine engine startup/shutdown, and transitional operation period, emission rates (three-hour average) shall not exceed any of the following: PM10: 0.012 lb/MMBtu, SOx (as SO2): 0.004 lb/MMBtu; or VOC: 0.033 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
28. Maximum NOx emission rate (one hour average) shall not exceed the NSPS standard of 105 ppmv dry @ 15% O2. [District Rule 4001] Federally Enforceable Through Title V Permit
29. Except during periods of gas turbine engine startup/shutdown, and transitional operation period, emission rates (based on three-hour rolling average) shall not exceed either of the following: NOx (as NO2): 5 ppmv dry @ 15% oxygen (O2); or CO: 13.5 ppmv @ 15% oxygen (O2). [District Rule 4703, 5.1.2, 5.2 and District NSR Rule] Federally Enforceable Through Title V Permit
30. Permittee shall report the following emission exceedences to the District: NOx emission rate on a three-hour average, NSPS NOx emission rate on one hour average, and DEL of NOx during days of gas turbine engine startup/shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
31. The three-hour average will be compiled from the three most recent one-hour periods, with each one-hour period commencing on the hour. [District Rule 1081] Federally Enforceable Through Title V Permit
32. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx daily emission limitation by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Permittee shall comply in full with Rule 4001 (New Source Performance Standards) requirements, including notification, recordkeeping and monitoring requirements. [District Rule 4001] Federally Enforceable Through Title V Permit
34. Continuous emissions monitoring system shall conform to Rule 1080 specifications. [District Rule 1080] Federally Enforceable Through Title V Permit
35. Continuous emission monitoring systems shall be calibrated and operated according to EPA guidelines as specified in CFR, Part 60, Appendix B. CEM ppm and lb/hr shall be calculated as a three-hour and a 1 hour average. [District Rules 4001 and 4703] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. Annual relative accuracy audits of CEM's shall be conducted by independent laboratory in accordance with EPA guidelines. The District shall be notified of the audit in advance and reports shall be submitted to the District within 60 days of each test. [District Rule 4001] Federally Enforceable Through Title V Permit

37. Permittee shall keep accurate records of turbine daily NOx (as NO2) and oxygen (O2) monitors output for a period of five years, and shall make such records readily available for District inspection upon request. [District Rules 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit

38. Compliance source testing for NOx, CO, and O2 shall be conducted at least once every 12 months under conditions representative of normal operation. [District NSR Rule and District Rule 4703, 6.3.1] Federally Enforceable Through Title V Permit

39. Compliance source testing shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

40. Source test protocol shall be submitted for District approval at least 15 days prior to test date. [District Rule 1081] Federally Enforceable Through Title V Permit

41. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

42. The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front half and back half) or 201A and 202 or CARB Method 5 (front and back half); ammonia - BAAQMD ST-1B; and O2 - EPA Method 3, 3A, or 20 or CARB Method 100. [40 CFR 60.335(a) and District Rules 2520 and 4703] Federally Enforceable Through Title V Permit

43. Exhaust stack following last economizer shall be of circular cross-section and shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods, including flow straighteners, if necessary, to minimize turbulence. [District Rule 1081] Federally Enforceable Through Title V Permit

44. Permittee shall maintain records of all fuel sulfur content testing performed. [District NSR Rule] Federally Enforceable Through Title V Permit

45. Permittee shall maintain daily records of the following: time of start-up(s) and shutdown(s), length and reason for reduced load periods, total hours of operation, and source(s) of and quantity of fuel used. [District Rules 1070 and 4703, 6.2.6] Federally Enforceable Through Title V Permit

46. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1183-1

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: SW39 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
12,012 GALLON FIXED ROOF STORAGE TANK (TANK ID GAUGE TK 2)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1184-1

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NW09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
41,580 GALLON FIXED ROOF STORAGE TANK (TANK ID T-24)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

DRAFT

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1204-2

EXPIRATION DATE: 02/28/2017

DRAFT

SECTION: NW 10 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
2922 HP EPA TIER 2 DIESEL-FIRED LIMITED-LIFE IC ENGINE

PERMIT UNIT REQUIREMENTS

1. {98} No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO-approved alternative. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
5. {1898} The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. IC engine shall not be operated longer than 4.0 hr/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Total operation of the IC engine associated with this permit unit shall not exceed 40 hours without prior District approval through issuance of an Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
8. NOx emissions (referenced as NO2) shall not exceed 4.56 g/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
9. VOC emissions (referenced as methane) shall not exceed 0.24 g/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
10. CO emissions shall not exceed 2.6 g/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The PM10 emissions rate from the engine shall not exceed 0.15 g/hp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit
12. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit
13. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit

DRAFT

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

14. The operator shall maintain records of the daily hours and cumulative hours of operation on a 12 month rolling average. These records shall be updated at least monthly. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit

16. U.S. EPA administers the requirements of 40 CFR Part 60 Subpart IIII. The owner or operator shall comply with the emission and operating limitations, testing requirements, initial and continuous compliance requirements as specified in this subpart. The owner or operator shall submit all applicable notifications, reports, and records to the administrator by the required compliance dates. [District Rule 4001] Federally Enforceable Through Title V Permit

17. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

DRAFT

ATTACHMENT B

Previous Title V Operating Permit

Facility # S-1131
CHEVRON USA INC
PO BOX 1392
BAKERSFIELD, CA 93302

Notice of Permit Issuance

The enclosed permit unit requirements authorize the operation of the equipment as described. These permit unit requirements supersede any and all previous permits for the specified equipment.* Please insert these documents into the Facility Permit to Operate, and post copies on or near the equipment as required by District Rule 2010.

Please contact any of our Small Business Assistance (SBA) staff at the numbers below if you have any questions:

Modesto:	(209) 557-6446
Fresno:	(559) 230-5888
Bakersfield:	(661) 392-5665

*Failure to comply with the permit unit requirements may result in enforcement action.

Permit to Operate

FACILITY: S-1131 **EXPIRATION DATE:** 02/28/2017

LEGAL OWNER OR OPERATOR: CHEVRON USA INC
MAILING ADDRESS: PO BOX 1392
BAKERSFIELD, CA 93302

FACILITY LOCATION: HEAVY OIL CENTRAL
KERN COUNTY, CA

FACILITY DESCRIPTION: OIL AND NATURAL GAS PRODUCTION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Seyed Sadredin
Executive Director / APCO

Arnaud Marjollet
Director of Permit Services

Jan 16 2018 10:00AM – GOMEZD

San Joaquin Valley
Air Pollution Control District

FACILITY: S-1131-0-2 **EXPIRATION DATE:** 02/28/2017

FACILITY-WIDE REQUIREMENTS

1. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
2. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. All required source testing shall conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit
4. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
5. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020. [District Rules 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
6. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.12.1] Federally Enforceable Through Title V Permit
7. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
8. Every application for a permit required under Rule 2010 (12/17/92) (Permits Required) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
9. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

10. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

11. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit

12. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with Section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit

13. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit . [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit

14. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit

15. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit

16. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit

17. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit

18. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit

19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit

20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit

21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit

22. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

23. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (11/15/01), by using EPA method 9. If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101] Federally Enforceable Through Title V Permit
24. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in the Table of Standards of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1, 5.2, 5.5, and 5.7] Federally Enforceable Through Title V Permit
25. All VOC-containing materials for architectural coatings subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
26. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
27. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
28. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
29. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR 82, Subpart B. [40 CFR 82, Subpart B] Federally Enforceable Through Title V Permit
30. Disturbances of soil related to any construction, demolition, excavation, extraction, or water mining activities shall comply with the requirements for fugitive dust control in SJVUAPCD District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 or Rule 8011. [District Rules 8021 and 8011] Federally Enforceable Through Title V Permit
31. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 or Rule 8011. [District Rules 8031 and 8011] Federally Enforceable Through Title V Permit
32. An owner/operator shall prevent or cleanup any carryout and trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 or Rule 8011. [District Rules 8041 and 8011] Federally Enforceable Through Title V Permit
33. Whenever open areas are disturbed or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 or Rule 8011. [District Rules 8051 and 8011] Federally Enforceable Through Title V Permit
34. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 or Rule 8011. [District Rules 8061 and 8011] Federally Enforceable Through Title V Permit
35. Any unpaved vehicle/equipment area that anticipates more than 75 vehicle trips per day shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 100 vehicle trips per day shall comply with the requirements of Section 5.1.2 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 or Rule 8011. [District Rules 8071 and 8011] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

36. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

37. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit

38. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit

39. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permit shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit

40. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

41. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92);2070 , section 7.0 (12/17/92); 2080 (12/17/92); 4101 (12/17/92); 4601, sections 5.1, 5.2, 5.4, 5.5, 6.1, and 6.2 (9/17/97); 8020 (4/25/96); 8030 (4/25/96); 8060 (4/25/96); A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

42. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]

43. When applicable to 40 CFR Part 68, a subject facility shall submit to the proper authority a Risk Management Plan when mandated by the regulation. [40 CFR Part 68] Federally Enforceable Through Title V Permit

44. All permits for facilities S-88, S-511 and S-1131 are included in ChevronTexaco Inc.'s Heavy Oil Central stationary source. [District Rule 2201] Federally Enforceable Through Title V Permit

45. On December 31, 2002, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin January 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-62-29 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-38; DIS# 20630-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN MODEL GLE LOW-NOX BURNER, AND NORTH AMERICAN OPTIMIZER

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.007 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit

22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit

25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit

26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-63-24 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG#60-39, DIS#20631-79) WITH NORTH AMERICAN GLE LOW-NOX BURNER, FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-64-24 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-40; DIS# 20632-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN GLE LOW-NOX BURNER AND NORTH AMERICAN OPTIMIZER

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit

22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit

25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit

26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-65-30 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-41; DIS# 20633-79) WITH NORTH AMERICAN GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 39 ppmvd CO @ 3% O2 or 0.029 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 43.5 lb-CO/day, and 15,858 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. During start-up and shutdown periods, emissions from the natural gas-fired steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 30 ppmvd NOx @ 3% O2 or 0.036 lb-NOx/MMBtu, or 39 ppmvd CO @ 3% O2 or 0.029 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. The shakedown period shall begin upon initial operation of this unit after implementation of the modification authorized by this ATC. The shakedown period shall be concluded within 60 days of initial operation and prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and all monitoring records as required by this permit starting on the date of initial operation. [District Rule 2201] Federally Enforceable Through Title V Permit

11. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 2201 and 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rules 2520 and 4320, 6.2.1] Federally Enforceable Through Title V Permit
22. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. Permittee shall maintain daily records of volume of fuel gas burned, the sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, and 4320] Federally Enforceable Through Title V Permit
29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

32. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

33. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

34. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

35. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-66-23 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-42; DIS# 20634-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN GLE LOW-NOX BURNER AND NORTH AMERICAN OPTIMIZER. (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-67-24 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO NATURAL GAS-FIRED STEAM GENERATOR (HSG# 60-43; DIS# 20635-79) WITH FLUE GAS RECIRCULATION AND A NORTH AMERICAN GLE LOW-NOX BURNER (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-68-23 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO NATURAL GAS-FIRED STEAM GENERATOR (HSG# 60-44; DIS# 20636-79) WITH FLUE GAS RECIRCULATION AND A NORTH AMERICAN GLE LOW-NOX BURNER (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-69-23 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-45; DIS# 20637-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN GLE LOW-NOX BURNER AND NORTH AMERICAN OPTIMIZER. (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 15,858 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-70-23 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-46; DIS# 20638-79) WITH A NORTH AMERICAN MAGNA FLAME GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-73-23 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-49; DIS# 20641-79) WITH A NORTH AMERICAN MAGNA FLAME GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.005 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 20,258 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-77-23 **EXPIRATION DATE:** 02/28/2017

SECTION: 19 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-67; DIS# 20611-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN, MODEL #5131-HGCR-62. 5, BURNER AND NORTH AMERICAN OPTIMIZER. (CANFIELD LEASE)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
6. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
7. Emission rates shall not exceed the following PM10: 0.108 lb/MMBtu, SOx (as SO2): 1.026 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.006 lb/MMBtu, and CO: 0.029 lb/MMBtu or 39 ppmv @ 3% O2. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
8. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the vapor recovery gas incinerated in this unit. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
9. Permittee shall measure and record the natural gas sulfur content and BTU content at the time of NOx testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
10. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

12. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

13. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

14. Compliance demonstration (source testing) shall be conducted by independent testing laboratories and shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

17. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 100 and EPA Method 19, fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans, or other test methods approved by the District. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

18. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

19. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

20. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

21. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3 and Kern County Rules 404 and 408] Federally Enforceable Through Title V Permit

22. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

27. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

29. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

36. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-78-29 **EXPIRATION DATE:** 02/28/2017

SECTION: NW05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-69; DIS# 20610-79) WITH A NORTH AMERICAN MAGNA FLAME GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION ((MONTE CRISTO 1 LEASE)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and vapor recovery gas that has a combined fuel sulfur content not exceeding 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu; or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

12. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

13. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320]

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

28. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-82-26 **EXPIRATION DATE:** 02/28/2017

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-88; DIS# 20643-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN MODEL GLE MAGNA-FLAME (OR DISTRICT APPROVED EQUIVALENT), AND NORTH AMERICAN OPTIMIZER - SJ LOWER

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and vapor recovery gas from the vapor control system listed on permit unit PTO S-1131-598 that has a combined fuel sulfur content not exceeding 5 gr S/100 scf unless SOx is reduced by 95% or to an outlet concentration not exceeding 9 ppmv via scrubbing. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu or 1.026 lb-SOx/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 39 ppmvd CO @ 3% O2 or 0.029 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. During start-up and shutdown periods, emissions from the natural gas-fired steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

15. An analysis of the fuel sulfur content may be submitted for compliance with the SOx requirement in lieu of the source test for SOx. [District Rules 2201and 4320] Federally Enforceable Through Title V Permit

16. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit

17. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Permittee shall submit an analysis showing the fuel's sulfur content or conduct a source test for SOx at least once every 12 months. [District Rule 4320, 5.7] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
26. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
27. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
28. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-94-27 **EXPIRATION DATE:** 02/28/2017

SECTION: 29 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STRUTHERS STEAM GENERATOR (HSG# 70-08; DIS# 20627-81) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN, MODEL #5131-HGCR-62. 5, BURNER AND NORTH AMERICAN OPTIMIZER (CANFIELD LEASE)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
6. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
7. Emission rates shall not exceed the following PM10: 0.108 lb/MMBtu, SOx (as SO2): 1.026 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.006 lb/MMBtu, and CO: 0.029 lb/MMBtu or 39 ppmv @ 3% O2. [District Rules 2201, 4305, 4351] Federally Enforceable Through Title V Permit
8. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the vapor recovery gas incinerated in this unit. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
9. Permittee shall measure and record the natural gas sulfur content and BTU content at the time of NOx testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
10. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2201, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

12. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

13. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

14. Compliance demonstration (source testing) shall be conducted by independent testing laboratories and shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

17. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 100 and EPA Method 19, fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans, or other test methods approved by the District. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

18. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

19. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

20. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

21. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3 and Kern County Rules 404 and 408] Federally Enforceable Through Title V Permit

22. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

27. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

29. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

36. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-95-23 **EXPIRATION DATE:** 02/28/2017

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS/GAS FIRED STRUTHERS STEAM GENERATOR (HSG# 70-31; DIS# 20642-79) WITH A NORTH AMERICAN MODEL GLE MAGNA-FLAME LOW NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM AND NORTH AMERICAN OPTIMIZER - SJ LOWER

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and vapor recovery gas from the vapor control system listed on permit unit PTO S-1131-598 that has a combined fuel sulfur content not exceeding 5 gr S/100 scf unless SOx is reduced by 95% or to an outlet concentration not exceeding 9 ppmv via scrubbing. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu or 1.026 lb-SOx/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 39 ppmvd CO @ 3% O2 or 0.029 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 43.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. During start-up and shutdown periods, emissions from the natural gas-fired steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

15. An analysis of the fuel sulfur content may be submitted for compliance with the SOx requirement in lieu of the source test for SOx. [District Rules 2201and 4320] Federally Enforceable Through Title V Permit

16. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit

17. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Permittee shall submit an analysis showing the fuel's sulfur content or conduct a source test for SOx at least once every 12 months. [District Rule 4320, 5.7] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
26. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
27. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
28. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-98-26 **EXPIRATION DATE:** 02/28/2017

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (HSG# 70-44; DIS# 20608-82) WITH A NORTH AMERICAN MODEL #GLE-4231 LOW NOX BURNER AND FLUE GAS RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and vapor recovery gas from the vapor control system listed on permit unit PTO S-1131-598 that has a combined fuel sulfur content not exceeding 5 gr S/100 scf unless SOx is reduced by 95% or to an outlet concentration not exceeding 9 ppmv via scrubbing. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu; 1.026 lb-SOx/MMBtu; or 0.006 lb-VOC/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. During start-up and shutdown periods, emissions from the natural gas/vapor recovery gas-fired steam generator shall not exceed either of the following limits: 0.1 lb/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

15. An analysis of the fuel sulfur content may be submitted for compliance with the SOx requirement in lieu of the source test for SOx. [District Rules 2201and 4320] Federally Enforceable Through Title V Permit

16. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit

17. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Permittee shall submit an analysis showing the fuel's sulfur content or conduct a source test for SOx at least once every 12 months. [District Rule 4320, 5.7] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
26. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
27. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
28. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-99-26 **EXPIRATION DATE:** 02/28/2017

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (HSG# 70-45; DIS# 20609-82) WITH A NORTH AMERICAN MODEL #GLE-4231 LOW NOX BURNER AND FLUE GAS RECIRCULATION

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and vapor recovery gas from the vapor control system listed on permit unit PTO S-1131-598 that has a combined fuel sulfur content not exceeding 5 gr S/100 scf unless SOx is reduced by 95% or to an outlet concentration not exceeding 9 ppmv via scrubbing. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu; 1.026 lb-SOx/MMBtu; or 0.006 lb-VOC/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
7. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
8. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

10. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

14. An analysis of the fuel sulfur content may be submitted for compliance with the SOx requirement in lieu of the source test for SOx. [District Rules 2201and 4320] Federally Enforceable Through Title V Permit

15. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit

16. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Permittee shall submit an analysis showing the fuel's sulfur content or conduct a source test for SOx at least once every 12 months. [District Rule 4320, 5.7] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
27. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-509-5 **EXPIRATION DATE:** 02/28/2017

SECTION: SW32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #TK3-7

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-592-4 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, S. PROCESS WASH TANK

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-594-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,530 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, SETTLING #37

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-598-45 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
43,000 BBL FIXED ROOF SURGE TANK #5 (STATION 36) WITH GAS BLANKETING AND VAPOR CONTROL SYSTEM INCLUDING SULFUR REMOVAL SYSTEM AND DISCHARGING TO INCINERATING STEAM GENERATORS, STATION 36 TVR SYSTEM AND TEOR SYSTEM S-1131-1127, OR DOGGR APPROVED VAPOR DISPOSAL WELLS

PERMIT UNIT REQUIREMENTS

1. Tank shall only be vented to vapor control system shared with crude oil processing tanks #S-1131-608, '-613, '-629, '-630, '-638, '-641, '-650, '-651, '-1097, and TEOR permit S-1131-1127; with collected vapors discharging to steam generators S-1131-82, '-95, '-98, '-98, '-99, '-859, DOGGR approved disposal well(s),or vapor control system listed on S-1131-885. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Sulfatreat system shall be located downstream of sampling point used for verification that gas processed by tank S-1131-598 contains < 10% VOC by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District NSR Rule] Federally Enforceable Through Title V Permit
4. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
5. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. Permittee shall maintain records of components exempted from counting, and the basis for exemption. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 113.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The fugitive VOC emission rate does not include piping and components handling produced fluids with API gravity less than 30 degrees. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The fugitive VOC emission rate does not include piping and components handling produced fluids having less than 10% VOC by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The fugitive VOC emission rate does not include components in water/oil service (water content of fluids handled greater than 50%). Permittee shall maintain records of annual testing to demonstrate that such fluid streams have at least 50% water by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Operator shall conduct quarterly sampling from the tank vapor control system's emergency gas exhaust header sample point to qualify for exemption from fugitive component counts for components handling fluids with less than 10% VOC by weight. If 8 consecutive quarterly samplings show compliance, then sampling frequency shall only be required annually. Such sampling is deemed representative of tanks S-1131-608, -613, -629, -630, -638, -641, -650, -651, and -1097. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. VOC content of vapor shall be determined by ASTM D1945, ASTM D1946, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201] Federally Enforceable Through Title V Permit

12. Permittee shall maintain a written record of the VOC content of the gas sampled. [District Rule 2201] Federally Enforceable Through Title V Permit

13. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit

14. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit

15. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

16. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

17. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

18. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit

19. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit

20. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

21. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit

23. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit

24. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit

25. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit

26. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit

27. When a D.O.G.G.R. disposal well is changed, or a new well is added, permittee shall provide District with a copy of D.O.G.G.R. approval for each vapor disposal well prior to use for vapor injection. [District Rules 1070; and 2520] Federally Enforceable Through Title V Permit

28. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520] Federally Enforceable Through Title V Permit

29. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

30. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

31. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

33. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

34. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

36. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

37. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

38. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

39. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-599-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED-ROOF CRUDE OIL WASH TANK #1-A AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-600-4 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,920 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #6600 S OT

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-601-4 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,920 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #6600 N OT

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-602-4 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, N. PROCESS WASH TANK

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-603-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,470 BBL FIXED-ROOF CRUDE OIL SETTLING TANK #43 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-606-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #42 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-608-23 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
10,000 BBL 55' DIA X 24' HIGH FIXED ROOF CRUDE OIL PRODUCTION TANK, SHIPPING #41 (STATION 36) VENTED TO VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. Tank is authorized to receive fluids from station 36 "Surge" tanks receiving production from steam-enhanced wells with closed well casing vents. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
4. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 6.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit

11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit

12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit

13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit

17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit
24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit
26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit
27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit
28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit
29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit
30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-610-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,530 BBL FIXED ROOF CRUDE OIL SETTLING TANK #20 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-613-21 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
10,000 BBL 55' DIA X 24' HIGH FIXED ROOF CRUDE OIL PRODUCTION TANK, SHIPPING #40 (STATION 36) VENTED TO VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. Tank is authorized to receive fluids from station 36 "Surge" tanks receiving production from steam-enhanced wells with closed well casing vents. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
4. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 5.0 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit

11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit

12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit

13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit

17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit
24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit
26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit
27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit
28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit
29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit
30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-615-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #2-B AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-619-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #1-B AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-620-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #2 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-621-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #45 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-622-4 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
52,460 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #60GK2

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-623-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #44 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-625-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #46 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-626-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-2 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-627-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-3 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-628-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-1 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-629-13 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
37,600 BBL FIXED ROOF CRUDE SURGE TANK #6 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 6.6 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit
24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit
26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit
27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit
28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit
29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit
30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-630-13 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
1,579,200 GALLON FIXED ROOF CRUDE SURGE TANK #7 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 5.9 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit
24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit
26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit
27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit
28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit
29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit
30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-631-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #1 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-632-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-5 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-633-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-6 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-634-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-4 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-635-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #2-A AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-636-4 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
10,570 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #10000 SHIP

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-638-13 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
37,600 BBL FIXED ROOF CRUDE SURGE TANK #2 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 7.4 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-641-13 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
37,600 BBL FIXED ROOF CRUDE SURGE TANK #1 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 6.1 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit

11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit

12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit

13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit

17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-650-13 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
37,600 BBL FIXED ROOF CRUDE SURGE TANK #4 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 7.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit

22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit

24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit

25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit

26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit

27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit

28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit

29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-651-13 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
37,600 BBL FIXED ROOF CRUDE SURGE TANK #3 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 7.7 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
10. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. The operator shall maintain records of the API gravity of petroleum liquids stored in this unit to determine which oils are from a common source. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
21. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
22. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
23. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit
24. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
25. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit
26. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit
27. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit
28. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit
29. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit
30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-652-4 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
54,460 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #60GK1

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-663-4 **EXPIRATION DATE:** 02/28/2017

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
250 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #TK2-4

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
3. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
4. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
5. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit
6. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
7. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
8. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-716-25 **EXPIRATION DATE:** 02/28/2017

EQUIPMENT DESCRIPTION:
TEOR OPERATION WITH 12,547 STEAM ENHANCED OIL PRODUCTION WELLS WITH CLOSED CASING VENTS PRODUCING TO TANKS WITH VAPOR CONTROL

PERMIT UNIT REQUIREMENTS

1. Permittee shall maintain a current listing of all steam-enhanced wells in the central Kern County fields heavy oil production stationary source with closed casing vents that direct fluids to uncontrolled storage tanks and a current listing of all permit numbers of front-line equipment receiving produced fluids from the wells; shall update the list whenever a well or front-line equipment is added, replaced or deleted; and shall make such listing readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Steam-enhanced production wells with closed well casing vents shall each have a visible identification number. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Total number of well casing and casing vent leaks from steam-enhanced oil production wells in this TEOR operation shall not exceed one leak detected for each 20 wells tested. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit
4. Permittee shall maintain accurate component count according to EPAs "Protocol for Equipment Leak Emission Estimate," Table 2-4, Oil and Gas Production Operations Average Emission Factors. Permittee shall update such records when new components are approved and installed. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Maximum VOC content of the gas in the wells shall not exceed 88% by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Operator shall test the VOC content of representative well gas no less than annually. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Volatile organic compound (VOC) emission rate shall not exceed 8,145.3 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Component screening shall be performed using a portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Reference Method 21. [District Rule 4401, 6.3.3] Federally Enforceable Through Title V Permit
9. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
11. The inspection requirements of Section 5.4.1 through Section 5.4.7 of Rule 4401 shall not apply to components exclusively handling gas/vapor or liquid with a VOC content of ten percent by weight (10%) or less, as determined by the test methods in Section 6.3.4 of Rule 4401. [District Rule 4401, 4.7] Federally Enforceable Through Title V Permit
12. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401, 3.20] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: (1)The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or gauge tanks as defined in Rule 4401. The well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. (2) The steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1 and 5.1] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit
15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit
16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
21. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401 5.5] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
29. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

35. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

37. Records of VOC content of gas shall be maintained and made readily available for District inspection upon request for a period of five years. [District Rule 2201] Federally Enforceable Through Title V Permit

38. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401 6.1] Federally Enforceable Through Title V Permit

39. The results of gauge tank TVP testing conducted pursuant to Section 6.2.3 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

40. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

41. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. A process system as defined in Section 3.30 of Rule 4401 is not subject to compliance source testing requirements. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

42. If approved by the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection are controlled by an internal combustion engine subject to Rule 4702, a combustion device subject to Rule 4320, 4307 or 4308, a flare subject to Rule 4311. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

43. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.0 of Rule 4401: Conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.9 of Rule 4401. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

44. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

45. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

46. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

47. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

48. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401, 6.4] Federally Enforceable Through Title V Permit

49. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401, 6.1 and 6.5] Federally Enforceable Through Title V Permit

50. Operator shall keep a list of all gauge tanks, as defined in Section 3.0 of Rule 4401. The list shall contain the size, identification number, the location of each gauge tank and specify whether the gauge tank is upstream of all front line production equipment. [District Rule 4401, 6.1 and 6.6] Federally Enforceable Through Title V Permit

51. By January 30 of each year, an operator shall submit to the APCO for approval, in writing, an annual report indicating any changes to an existing Operator Management Plan. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

52. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules 2201 and 4401, 6.1] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-724-4 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
GASOLINE DISPENSING OPERATION WITH TWO 10,000 GALLON UNDERGROUND STORAGE TANKS SERVED BY OPW PHASE I ENHANCED VAPOR RECOVERY SYSTEM (VR-102-A), AND THREE FUELING POINTS WITH THREE GASOLINE DISPENSING NOZZLES SERVED BY HEALY PHASE II ENHANCED VAPOR RECOVERY SYSTEM WITHOUT ISD (VR-201-E) (KERN RIVER)

PERMIT UNIT REQUIREMENTS

1. The permittee shall store or dispose of gasoline in closed, non-leaking containers. The containers shall remain closed at all times except when depositing or removing the contents of the containers or when the container is empty. [District Rule 4621, 5.6] Federally Enforceable Through Title V Permit
2. The vapor recovery systems and their components shall be installed, operated, and maintained in accordance with the State certification requirements. [District Rules 4621, 5.2; and 4622, 5.1] Federally Enforceable Through Title V Permit
3. The Phase I and Phase II vapor recovery systems shall be installed and maintained in accordance with the manufacturer specifications and the ARB Executive Orders specified in this permit, including applicable rules and regulations of the Division of Measurement Standards of the Department of Food and Agriculture, the Office of the State Fire Marshal of the Department of Forestry and Fire Protection, the Division of Occupational Safety and Health of the Department of Industrial Relations, and the Division of Water Quality of the State Water Resources Control Board that have been made conditions of the certification. [District Rules 4621, 5.2; and 4622, 5.1] Federally Enforceable Through Title V Permit
4. Each ARB certified vapor recovery system shall be tested within 60 days of major modification or installation, except as otherwise allowed by this permit. For this condition, a major modification is considered to be replacing, repairing, or upgrading 75% or more of the certified system. [District Rule 4622, 6.4] Federally Enforceable Through Title V Permit
5. The ARB certified vapor recovery system and all of its components shall be maintained in good repair. Any ARB certified gasoline vapor recovery system, which has been installed and has been issued a permit to operate, shall not be removed regardless of the amount of gasoline dispensed or how the gasoline is delivered to the facility. [District Rule 4622, 5.2] Federally Enforceable Through Title V Permit
6. No owner or operator shall tamper with, or permit tampering with, the ARB certified vapor recovery system in a manner that would impair the operation or effectiveness of the system. [District Rule 4622, 5.9] Federally Enforceable Through Title V Permit
7. All nozzles shall be equipped with coaxial hose configurations. [District Rule 4622, 5.1] Federally Enforceable Through Title V Permit
8. Each gasoline storage tank shall be equipped with a permanent submerged fill pipe. [District Rule 4621, 5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Each storage tank subject to this permit shall be equipped with an ARB certified Phase I vapor recovery system, which shall prevent at least 95% by weight of all gasoline vapors displaced during the filling of storage tanks from entering the atmosphere. The transfer of gasoline from any delivery vessel to any stationary storage container with 250 gallon capacity or more shall not be allowed unless the container is equipped with an ARB certified Phase 1 system and maintained and operated according to manufacturers specifications. [District Rule 4621, 5.2] Federally Enforceable Through Title V Permit
10. Each dispensing system shall be equipped with an ARB certified Phase II vapor recovery system which shall prevent at least 95% by weight of all gasoline vapors displaced during refueling of vehicles from entering the atmosphere. [District Rule 4622, 5.1] Federally Enforceable Through Title V Permit
11. This gasoline storage and dispensing equipment shall not be used in retail sales, where gasoline dispensed by the unit is subject to payment of California sales tax on gasoline sales. [District Rules 4622, 3.25; and 2520, 9.1] Federally Enforceable Through Title V Permit
12. No gasoline delivery vessel shall be operated or be allowed to operate unless valid State of California decals are displayed on the cargo tank which attest to the vapor integrity of the tank. [District Rule 4621, 5.7] Federally Enforceable Through Title V Permit
13. No person shall top off a motor vehicle fuel tank. [District Rule 4622, 5.6] Federally Enforceable Through Title V Permit
14. No gasoline shall be transferred into vehicle fuel tanks if the vapor recovery system contains any defect listed in Section 94006 of Title 17 of the California Code of Regulations or in Section 5.4 of SJVUAPCD Rule 4622 (as amended February 17, 1994) until the defect has been repaired, replaced, or adjusted as necessary to correct the defect, and the District has reinspected the system or has authorized its use pending reinspection. [District Rule 4622, 5.4] Federally Enforceable Through Title V Permit
15. No person shall operate any ARB certified Phase II vapor recovery system or any portion thereof that has a major defect or an equipment defect that is identified in any applicable ARB Executive Order until the following conditions have been met: 1) the defect has been repaired, replaced, or adjusted as necessary to correct the defect; 2) the District has been notified, and the District has reinspected the system or authorized the system for use (such authorization shall not include the authority to operate the equipment prior to the correction of the defective components); and 3) all major defects, after repair, are duly entered into the Operations and Maintenance (O&M) manual. [District Rule 4622, 5.4] Federally Enforceable Through Title V Permit
16. Any defects identified shall be tagged "Out of Order"; the tagged equipment shall be rendered inoperable and the tag(s) shall not be removed until the defect has been repaired, replaced or adjusted. In the case of defects identified by the District, tagged equipment shall be rendered inoperable and the tag shall not be removed until the District has been notified of the repairs, and/or the District has inspected and authorized the tagged equipment for use. A log containing at least the following shall be maintained: date and type of defect identified and date repaired, replaced or corrected. [District Rules 4622, 5.4] Federally Enforceable Through Title V Permit
17. A person performing installation of, or maintenance on, a certified Phase I or Phase II vapor recovery system shall be certified by the ICC for Vapor Recovery System Installation and Repair, or work under the direct and personal supervision of an individual physically present at the work site who is certified. The ICC certification shall be renewed every 24 months. [District Rules 4621, 6.3; and 4622, 5.2] Federally Enforceable Through Title V Permit
18. Proof of the ICC certification and all other certifications required by the Executive Order and installation and operation manual shall be made available onsite. [District Rules 4621, 6.3; and 4622, 5.2] Federally Enforceable Through Title V Permit
19. A person conducting testing of, or repairs to, a certified vapor recovery system shall be in compliance with District Rule 1177 (Gasoline Dispensing Facility Tester Certification). [District Rules 4621, 6.3 and 4622, 6.4] Federally Enforceable Through Title V Permit
20. The permittee shall conduct all periodic vapor recovery system performance tests specified in this permit, no more than 30 days before or after the required compliance testing date, unless otherwise required under the applicable ARB Executive Order. [District Rules 4621, 5.3; and 4622, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. The permittee shall notify the District at least 7 days prior to each performance test. The test results shall be submitted to the District no later than 30 days after the completion of each test. [District Rule 4621, 6.2] Federally Enforceable Through Title V Permit

22. The permittee shall perform and pass a Dynamic Back Pressure Test using ARB TP-201.4 at least once every 12 months. [District Rule 4622, 6.4, 6.5] Federally Enforceable Through Title V Permit

23. The permittee shall perform and pass a Static Leak Test for Underground Tanks using ARB TP-201.3 in accordance with the Executive Order specified in this permit for the Phase II Vapor Recovery System at least once every 12 months. [District Rules 4621, 5.3; and 4622, 6.4, 6.5] Federally Enforceable Through Title V Permit

24. The permittee shall perform and pass a Vapor-to-Liquid Volume Ratio Test using the test procedure defined in the Executive Order specified in this permit for the Phase II Vapor Recovery System at least once every six (6) months. [District Rule 4622, 6.4, 6.5] Federally Enforceable Through Title V Permit

25. The permittee shall perform and pass a Static Pressure Test for the Healy Clean Air Separator using the test procedure defined in the Executive Order specified in this permit for the Phase II Vapor Recovery System at least once every 12 months. [District Rule 4622, 6.4, 6.5] Federally Enforceable Through Title V Permit

26. The permittee shall perform and pass a Dispenser vapor Line Tightness test for each dispenser using the test procedure defined in the Installation, Operation and Maintenance manual of the Executive Order specified in this permit for the Phase II Vapor Recovery System at least once every 12 months. [District Rule 4622, 6.4, 6.5] Federally Enforceable Through Title V Permit

27. The permittee shall perform and pass a Pressure Integrity of Drop Tube Drain Valve Assembly Test using ARB TP-201.1C or a Pressure Integrity of Drop Tube Overfill Protection Devices Test using ARB TP-201.1D if an overfill protection device is installed, at least once every 36 months. [District Rule 4621, 5.3] Federally Enforceable Through Title V Permit

28. The permittee shall perform and pass a Static Torque of Rotatable Phase I Adaptors test using ARB procedure TP-201.1B at least once every 36 months. [District Rule 4621, 5.3] Federally Enforceable Through Title V Permit

29. The District shall be notified within 24 hours of the facility's pass/fail status after the performance of each test. [District Rule 1081] Federally Enforceable Through Title V Permit

30. The permittee shall maintain a copy of all test results. The test results shall be dated and shall contain the name, address, and telephone number of the company responsible for system installation and testing. [District Rules 4621, 6.1; and 4622, 6.2] Federally Enforceable Through Title V Permit

31. Vapor recovery systems and gasoline dispensing equipment shall be maintained leak-free as verified using EPA Test Method 21 and visual inspection. Leak testing shall be performed at least annually and within 60 days of all major modifications. For this condition, a major modification is considered to be replacing, repairing, or upgrading 75% or more of the certified system. A leak is defined as the dripping at a rate of more than three (3) drops per minute of liquid containing VOCs or a reading as methane in excess of 10,000 ppm as determined using EPA Method 21. [District Rules 4621, 3.19, 5.1, 5.6; and 4622, 3.17, 5.1, 5.6, 6.5] Federally Enforceable Through Title V Permit

32. Each operator shall maintain a leak inspection log containing, at a minimum, the following: inspector's name, location and description of component type where any leak is found; date of leak detection, emission level (ppm) if applicable, and date leak is repaired. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

33. Operator shall maintain all records of required monitoring data and support information for inspection for a period of five years. [District Rules 4621, 6.1; and 4622, 6.1, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. The operator shall implement a periodic maintenance inspection program for the certified Phase II vapor recovery system consistent with Section 5.4 of Rule 4622. The program shall be documented in an operation and maintenance (O&M) manual and shall at a minimum contain the following information: 1) All applicable ARB Executive Orders, Approval Letters, and District Permits; 2) The manufacturer's specifications and instructions for installation, operation, repair, and maintenance required pursuant to ARB Certification Procedure CP-201, and any additional instruction provided by the manufacturer; 3) System and/or component testing requirements, including test schedules and passing criteria for each of the standard tests. The owner/operator may include any non-ARB required diagnostic and other tests as part of the testing requirements; 4) Protocol for performing periodic maintenance inspections including the components to be inspected and the defects requiring repair; and 5) Additional O&M instructions, if any, that are designed to ensure compliance with the applicable rules, regulations, ARB Executive Orders, and District permit conditions, including replacement schedules for failure or wear prone components. [District Rule 4622, 6.3] Federally Enforceable Through Title V Permit

35. The operator shall conduct periodic maintenance inspections based on the amount of gasoline dispensed by the facility in a calendar month as follows: A) less than 2,500 gallons - one day per month; B) 2,500 to less than 25,000 gallons - one day per week; or C) 25,000 gallons or greater - five days per week. All inspections shall be documented within the O & M Manual. [District Rules 4621, 5.5; and 4622, 5.3] Federally Enforceable Through Title V Permit

36. Periodic maintenance inspections of the Phase I vapor recovery system shall include, at a minimum, verification that 1) the fill caps and vapor caps are not missing, damaged, or loose; 2) the fill cap gasket and vapor cap gaskets are not missing or damaged; 3) the fill adapter and vapor adapter are securely attached to the risers; 4) where applicable, the spring-loaded submerged fill tube seals properly against the coaxial tubing; 5) the dry break (poppet-valve) is not missing or damaged; and 6) the submerged fill tube is not missing or damaged. [District Rule 4621, 5.5] Federally Enforceable Through Title V Permit

37. Periodic maintenance inspections of the Phase II vapor recovery system shall include, at a minimum, verification that 1) the fueling instructions required by this permit are clearly displayed with the appropriate toll-free complaint phone number and toxic warning signs; 2) the following nozzle components are in place and in good condition as specified in ARB Executive Order as applicable: faceplate/facecone, bellows, latching device spring, vapor check valve, spout (proper diameter/vapor collection holes), insertion interlock mechanism, automatic shut-off mechanism, and hold open latch (unless prohibited by law or the local fire control authority); 3) the hoses are not torn, flattened or crimped; 4) the vapor path of the coaxial hoses associated with bellows equipped nozzles does not contain more than 100 ml of liquid if applicable; and 5) the vapor processing unit is functioning properly, for operations that are required to have or possess such a unit. [District Rule 4622, 5.3] Federally Enforceable Through Title V Permit

38. In the event of a separation due to a drive off, the permittee shall, unless otherwise specified in the applicable ARB Executive Order, conduct a visual inspection of the affected equipment and either 1) perform qualified repairs on any damaged components and conduct applicable re-verification tests pursuant to the requirements of this permit, or 2) replace the affected nozzles, coaxial hoses, breakaway couplings, and any other damaged components with new or certified rebuilt components that are ARB certified. The activities shall be documented in accordance with the requirements of this permit before placing the affected equipment back in service. [District Rule 4622, 5.4] Federally Enforceable Through Title V Permit

39. The gasoline throughput for this permit unit shall not exceed 600,000 gallons in any one calendar year. [District Rule 4622, 5.2] Federally Enforceable Through Title V Permit

40. The operator shall maintain monthly and annual gasoline throughput records. [District Rules 4621, 6.1; and 4622, 6.2] Federally Enforceable Through Title V Permit

41. The operator shall maintain on the premises a log of any repairs made to the certified Phase I or Phase II vapor recovery system. The repair log shall include the following: 1) date and time of each repair; 2) the name of the person(s) who performed the repair, and if applicable, the name, address and phone number of the person's employer; 3) description of service performed; 4) each component that was repaired, serviced, or removed; 5) each component that was installed as replacement, if applicable; and 6) receipts or other documents for parts used in the repair and, if applicable, work orders which shall include the name and signature of the person responsible for performing the repairs. [District Rule 4622, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

42. The O&M manual shall be kept at the dispensing operation and made available to any person who operates, inspects, maintains, repairs, or tests the equipment at the operation as well as to District personnel upon request. [District Rule 4622, 6.3] Federally Enforceable Through Title V Permit

43. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4621 (as amended December 20, 2007), and 4622 (as amended December 20, 2007). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

44. This unit is not associated with loading at a bulk gasoline terminal (as defined in 40 CFR 60.501). Therefore, the requirements of 40 CFR 60 Subparts XX do not apply to this permit unit. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-833-3 **EXPIRATION DATE:** 02/28/2017

SECTION: NW5 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
240 BHP DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101, 5.1] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.1] Federally Enforceable Through Title V Permit
3. The engine shall be equipped with a positive crankcase ventilation (PCV) system or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 5.7.4 and 17 CCR 93115] Federally Enforceable Through Title V Permit
5. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702, 5.7.2] Federally Enforceable Through Title V Permit
6. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801 and 17 CCR 93115] Federally Enforceable Through Title V Permit
7. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 20 hours per calendar year. [17 CCR 93115]
8. This engine shall be operated only for maintenance, testing, and required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year. [District Rule 4702, 4.2.1] Federally Enforceable Through Title V Permit
9. During periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702, 5.7.3] Federally Enforceable Through Title V Permit
10. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.), and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rules 4702, 5.7 and 2520, 9.4.2 and 17 CCR 93115] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [District Rule 2520, 9.4.2 and 17 CCR 93115] Federally Enforceable Through Title V Permit

12. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 4702, 6.2 and 2520, 9.4.2 and 17 CCR 93115] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-858-12 **EXPIRATION DATE:** 02/28/2017

SECTION: SE29 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED NATIONAL STEAM GENERATOR (HSG# 50-43; DIS# 20628-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN MODEL #5131-HGCR-62.5 BURNER, AND NORTH AMERICAN OPTIMIZER - (CANFIELD LEASE)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
5. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
6. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
7. Emission rates shall not exceed the following PM10: 0.109 lb/MMBtu, SOx (as SO2): 1.026 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.006 lb/MMBtu, and CO: 0.029 lb/MMBtu or 39 ppmv @ 3% O2. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
8. Permittee shall measure and record, at least monthly, the sulfur content and BTU content of the vapor recovery gas incinerated in this unit. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
9. Permittee shall measure and record the natural gas sulfur content and BTU content at the time of NOx testing, except for natural gas purchased from a PUC regulated utility. [District Rules 2201 and 4406] Federally Enforceable Through Title V Permit
10. Permittee shall maintain daily records of volume of natural gas burned and vapor recovery system gas incinerated. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

12. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

13. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

14. Compliance demonstration (source testing) shall be conducted by independent testing laboratories and shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

15. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

16. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

17. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 100 and EPA Method 19, fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans, or other test methods approved by the District. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

18. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

19. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

20. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

21. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3 and Kern County Rules 404 and 408] Federally Enforceable Through Title V Permit

22. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

27. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

29. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

36. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-859-13 **EXPIRATION DATE:** 02/28/2017

SECTION: SE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (HSG# 50-51; DIS# 19161- 75) WITH A NORTH AMERICAN MODEL GLE MAGNA-FLAME, LOW NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM AND NORTH AMERICAN OPTIMIZER (SAN JOAQUIN LOWER)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and vapor recovery gas from the vapor control system listed on permit unit PTO S-1131-598 that has a combined fuel sulfur content not exceeding 5 gr S/100 scf unless SOx is reduced by 95% or to an outlet concentration not exceeding 9 ppmv via scrubbing. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.108 lb-PM10/MMBtu; 1.026 lb-SOx/MMBtu; or 0.006 lb-VOC/MMBtu. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 39 ppmvd CO @ 3% O2 or 0.029 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 43.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
7. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
8. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

10. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

14. An analysis of the fuel sulfur content may be submitted for compliance with the SOx requirement in lieu of the source test for SOx. [District Rules 2201and 4320] Federally Enforceable Through Title V Permit

15. Whenever the unit is switched to scrubbed operation, compliance source testing for SOx shall be conducted within 60 days of initial scrubbing date unless source testing under scrubbed operation has occurred within the previous 12 months. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit

16. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
22. Permittee shall submit an analysis showing the fuel's sulfur content or conduct a source test for SOx at least once every 12 months. [District Rule 4320, 5.7] Federally Enforceable Through Title V Permit
23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
27. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-877-23 **EXPIRATION DATE:** 02/28/2017

SECTION: NW05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MM BTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS FIRED STRUTHERS STEAM GENERATOR #46 WITH FGR, NORTH AMERICAN MODEL GLE 4231 BURNER AND O2 CONTROLLER (MONTE CRISTO 1 LEASE)

PERMIT UNIT REQUIREMENTS

1. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
2. Permittee shall submit written notification to the District upon designating the unit as dormant or active. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, normal source testing shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
4. Upon recommencing operation of this unit, normal source testing shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
7. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-903, S-1131-909 and S-1131-1040. The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
8. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
9. Emission rates shall not exceed any of the following limits: 0.0768 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 28 ppmvd CO @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 31.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

13. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

15. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

16. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

17. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

24. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320] Federally Enforceable Through Title V Permit

25. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

26. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rule 4320] Federally Enforceable Through Title V Permit

30. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

31. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

32. No less than 4.54 miles of roads shall be paved and maintained to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

33. Only hot mix asphalt of a type conforming to Caltrans Standard Specifications shall be used in the paving or maintenance of roads used to provide particulate matter offsets for Project 62 and 95. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

35. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

36. Formerly S-1143-3.

37. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-879-24 **EXPIRATION DATE:** 02/28/2017

SECTION: SE13 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN GLE LOW-NOX BURNER WITH FGR AND AN O2 CONTROLLER (#70, CENTRAL PLANT)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.013 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

12. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

13. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, and 4320] Federally Enforceable Through Title V Permit

24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

28. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. Formerly S-1143-5.

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-880-17 **EXPIRATION DATE:** 02/28/2017

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR #140 WITH A NORTH AMERICAN MODEL #GLE-4231 LOW-NOX BURNER AND FLUE GAS RECIRCULATION (CENTRAL PLANT)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 41 ppmvd CO @ 3% O2 or 0.030 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
4. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 45.0 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Each fuel source shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
8. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
9. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

11. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

12. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

13. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit

15. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

18. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320]

19. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
21. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
27. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
28. Formerly S-1143-6.
29. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]
30. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-881-18 **EXPIRATION DATE:** 02/28/2017

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN GLE LOW-NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) AND AN O2 CONTROLLER (CENTRAL PLANT)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
8. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

10. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

11. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

12. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

13. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 2201 and 1081] Federally Enforceable Through Title V Permit

15. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

18. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier . [District Rule 4320]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

20. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, and 4320] Federally Enforceable Through Title V Permit

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

26. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

27. Formerly S-1143-6.

28. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

29. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-883-18 **EXPIRATION DATE:** 02/28/2017

SECTION: 4 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MM BTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS FIRED STRUTHERS STEAM GENERATOR (#143) WITH A NORTH AMERICAN MODEL GLE MAGNA-FLAME LOW NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM AND O2 CONTROLLER (CENTRAL PLANT)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.013 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rules 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 41 ppmvd CO @ 3% O2 or 0.03 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 45.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit
12. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
13. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
15. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit
16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

28. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. Formerly S-1143-9.

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-884-20 **EXPIRATION DATE:** 02/28/2017

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MM BTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STRUTHERS STEAM GENERATOR #144 EQUIPPED WITH NORTH AMERICAN MAGNA-FLAME GLE ULTRA LOW NOX BURNER AND FLUE GAS RECIRCULATION. (CENTRAL PLANT)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.013 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rules 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

12. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

13. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

28. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. Formerly S-1143-10.

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-885-30 **EXPIRATION DATE:** 02/28/2017

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK #3K-L75 WITH VAPOR CONTROL SYSTEM

PERMIT UNIT REQUIREMENTS

1. Well vent vapor control systems S-1131-903, S-1131-909, and S-1131-598 may discharge vapors into compressor suction of this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. Permittee shall maintain records of components exempted from counting, and the basis for exemption. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rates shall be calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 and the total number of vapor components. [District Rule 2201] Federally Enforceable Through Title V Permit
5. VOC emission rate from components associated with vapor recovery trunk-line up to and including vapor compressors and approved disposal devices shall not exceed 23.9 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
6. VOC emission rate from vapor service components associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 5.33 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The fugitive VOC emission rate does not include piping and components handling produced fluids with API gravity less than 30 degrees. [District Rule 2201] Federally Enforceable Through Title V Permit
8. The fugitive VOC emission rate does not include piping and components handling produced fluids having less than 10% VOC by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The fugitive VOC emission rate does not include components in water/oil service (water content of fluids handled greater than 50%). Permittee shall maintain records of annual testing to demonstrate that such fluid streams have at least 50% water by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Operator shall conduct quarterly sampling from the tank vapor control system's inlet header to qualify for exemption from fugitive component counts for components handling fluids with less than 10% VOC by weight. If 8 consecutive quarterly samplings show compliance, then sampling frequency shall only be required annually. Such sampling is deemed representative of tanks S-1131-608, -613, -629, -630, -638, -641, -650, -651, and -1097. [District Rule 2201] Federally Enforceable Through Title V Permit
11. VOC content of vapor shall be determined by ASTM D1945, ASTM D1946, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. Permittee shall maintain a written record of the VOC content of the gas sampled. [District Rule 2201] Federally Enforceable Through Title V Permit

13. Collected VOC vapors shall be incinerated in steam generators S-1131-82, '-95, '-98, '-99, '-859, '-877, '-879, '-880, '-881, '-883, '-884, and '908 or disposed of in Department of Oil, Gas, and Geothermal Resources (DOGGR) approved vapor disposal well(s). [District Rule 2201] Federally Enforceable Through Title V Permit

14. Fluids stored or handled by tank shall be routed exclusively to the vapor-controlled "Surge" tanks at Station 36 (S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097). [District Rule 2201] Federally Enforceable Through Title V Permit

15. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit

16. This tank shall be degassed before commencing interior cleaning by following one of the following options: 1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less, or 2) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water, or produced water derived from crude oil having a TVP less than 0.5 psia, or 3) by displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 2080] Federally Enforceable Through Title V Permit

17. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 2080] Federally Enforceable Through Title V Permit

18. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 2080] Federally Enforceable Through Title V Permit

19. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 2080] Federally Enforceable Through Title V Permit

20. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

21. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

22. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 2080] Federally Enforceable Through Title V Permit

23. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 2080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rule 2080] Federally Enforceable Through Title V Permit

25. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit

26. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit

27. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

28. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

29. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

30. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit

31. True vapor pressure of any liquid introduced in this permit unit shall be less than 0.5 psia at (or before) tank liquid inlet and at tank storage temperature. [District Rule 4623] Federally Enforceable Through Title V Permit

32. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit

33. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "Test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit

35. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit

36. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit

37. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit

38. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit

39. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit

40. Permittee shall provide District with a copy of D.O.G.G.R. approval for each vapor disposal well prior to use for vapor injection. [District Rule 1070] Federally Enforceable Through Title V Permit

41. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rules1070 and 4623] Federally Enforceable Through Title V Permit

42. Formerly S-1143-21. [District Rule 2010] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-886-22 **EXPIRATION DATE:** 02/28/2017

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK #3K-S76 WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-885

PERMIT UNIT REQUIREMENTS

1. Well vent vapor control systems S-1131-903 and S-1131-909 may discharge vapors into compressor suction of this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. VOC emission rate from vapor service components associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 5.33 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Permittee shall maintain an accurate fugitive component count and resultant emissions calculated using emission factors from U.S. EPA Publication 453/R-95-017, or other District-approved emission factors. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Steam generators authorized to incinerate collected VOC vapors are S-1131-877,'-880, '-881, '-882, '-883, and '-908. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Fluids stored or handled by tank shall be routed exclusively to the vapor-controlled "Surge" tanks at Station 36 (S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097). [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit
8. This tank shall be degassed before commencing interior cleaning by one of the following methods (1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less; or (2) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water. or produced water derived from crude oil having a TVP less than 0.5 psia; or (3) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 2080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 2080] Federally Enforceable Through Title V Permit

10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 2080] Federally Enforceable Through Title V Permit

11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 2080] Federally Enforceable Through Title V Permit

12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit

13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit

14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 2080] Federally Enforceable Through Title V Permit

15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 2080] Federally Enforceable Through Title V Permit

16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rules 2020 and 2080] Federally Enforceable Through Title V Permit

17. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit

18. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit

19. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

20. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
22. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
23. True vapor pressure of any liquid introduced in this permit unit shall be less than 0.5 psia at (or before) tank liquid inlet and at tank storage temperature. [District Rule 4623] Federally Enforceable Through Title V Permit
24. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit
25. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
26. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
27. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
28. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
29. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
30. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
31. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Permittee shall provide District with a copy of D.O.G.G.R. approval for each vapor disposal well prior to use for vapor injection. [District Rule 1070] Federally Enforceable Through Title V Permit
33. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rules 1070 and 4623] Federally Enforceable Through Title V Permit
34. Formerly S-1143-22. [District Rule 2010] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-891-21 **EXPIRATION DATE:** 02/28/2017

SECTION: SE04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-885

PERMIT UNIT REQUIREMENTS

1. Well vent vapor control systems S-1131-903 and S-1131-909 may discharge vapors into compressor suction of this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. VOC emission rate from vapor service components associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 5.33 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Permittee shall maintain an accurate fugitive component count and resultant emissions calculated using emission factors from U.S. EPA Publication 453/R-95-017, or other District-approved emission factors. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Steam generators authorized to incinerate collected VOC vapors are S-1131-877,'-880, '-881, '-882, '-883, and '-908. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Fluids stored or handled by tank shall be routed exclusively to the vapor-controlled "Surge" tanks at Station 36 (S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097). [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit
8. This tank shall be degassed before commencing interior cleaning by one of the following methods (1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less; or (2) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water. or produced water derived from crude oil having a TVP less than 0.5 psia; or (3) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 2080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 2080] Federally Enforceable Through Title V Permit
10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 2080] Federally Enforceable Through Title V Permit
11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 2080] Federally Enforceable Through Title V Permit
12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit
13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit
14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 2080] Federally Enforceable Through Title V Permit
15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 2080] Federally Enforceable Through Title V Permit
16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rules 2020 and 2080] Federally Enforceable Through Title V Permit
17. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
18. All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit
19. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
22. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
23. True vapor pressure of any liquid introduced in this permit unit shall be less than 0.5 psia at (or before) tank liquid inlet and at tank storage temperature. [District Rule 4623] Federally Enforceable Through Title V Permit
24. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit
25. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
26. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
27. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
28. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
29. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
30. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
31. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Permittee shall provide District with a copy of D.O.G.G.R. approval for each vapor disposal well prior to use for vapor injection. [District Rule 1070]
33. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rules 1070 and 4623] Federally Enforceable Through Title V Permit
34. Formerly S-1143-27. [District Rule 2010] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-892-21 **EXPIRATION DATE:** 02/28/2017

SECTION: SE04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-885

PERMIT UNIT REQUIREMENTS

1. Well vent vapor control systems S-1131-903 and S-1131-909 may discharge vapors into compressor suction of this operation. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
3. VOC emission rate from vapor service components associated with this tank, up to the tie-in with the vapor recovery unit trunk-line, shall not exceed 5.33 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Permittee shall maintain an accurate fugitive component count and resultant emissions calculated using emission factors from U.S. EPA Publication 453/R-95-017, or other District-approved emission factors. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Steam generators authorized to incinerate collected VOC vapors are S-1131-877,'-880, '-881, '-882, '-883, and '-908. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Fluids stored or handled by tank shall be routed exclusively to the vapor-controlled "Surge" tanks at Station 36 (S-1131-598, '-629, '-630, '-638, '-641, '-650, '-651, and '-1097). [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall notify the APCO in writing at least three (3) days prior to performing tank degassing and interior tank cleaning activities. Written notification shall include the following: 1) the Permit to Operate number and physical location of the tank being degassed, 2) the date and time that tank degassing and cleaning activities will begin, 3) the degassing method, as allowed in this permit, to be used, 4) the method to be used to clean the tank, including any solvents to be used, and 5) the method to be used to dispose of any removed sludge, including methods that will be used to control emissions from the receiving vessel and emissions during transport. [District Rule 2080] Federally Enforceable Through Title V Permit
8. This tank shall be degassed before commencing interior cleaning by one of the following methods (1) exhausting VOCs contained in the tank vapor space to an APCO-approved vapor recovery system until the organic vapor concentration is 5,000 ppmv or less, or is 10 percent or less of the lower explosion limit (LEL), whichever is less; or (2) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable liquid until 90 percent or more of the maximum operating level of the tank is filled. Suitable liquids are organic liquids having a TVP of less than 0.5 psia, water, clean produced water. or produced water derived from crude oil having a TVP less than 0.5 psia; or (3) displacing VOCs contained in the tank vapor space to an APCO-approved vapor recovery system by filling the tank with a suitable gas. Degassing shall continue until the operator has achieved a vapor displacement equivalent to at least 2.3 times the tank capacity. Suitable gases are air, nitrogen, carbon dioxide, or natural gas containing less than 10 percent VOC by weight. [District Rule 2080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. During tank degassing, the operator shall discharge or displace organic vapors contained in the tank vapor space to an APCO-approved vapor recovery system. [District Rule 2080] Federally Enforceable Through Title V Permit
10. To facilitate connection to an external APCO-approved recovery system, a suitable tank fitting, such as a manway, may be temporarily removed for a period of time not to exceed 1 hour. [District Rule 2080] Federally Enforceable Through Title V Permit
11. After a tank has been degassed pursuant to the requirements of this permit, vapor control requirements are not applicable until an organic liquid having a TVP of 0.5 psia or greater is placed, held, or stored in this tank. [District Rule 2080] Federally Enforceable Through Title V Permit
12. While performing tank cleaning activities, operators may only use the following cleaning agents: diesel, solvents with an initial boiling point of greater than 302 degrees F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams of VOC per liter or less. [District Rule 2080] Federally Enforceable Through Title V Permit
13. Steam cleaning shall only be allowed at locations where wastewater treatment facilities are limited, or during the months of December through March. [District Rule 2080] Federally Enforceable Through Title V Permit
14. During sludge removal, the operator shall control emissions from the sludge receiving vessel by operating an APCO-approved vapor control device that reduces emissions of organic vapors by at least 95%. [District Rule 2080] Federally Enforceable Through Title V Permit
15. Permittee shall only transport removed sludge in closed, liquid leak-free containers. [District Rule 2080] Federally Enforceable Through Title V Permit
16. Permittee shall store removed sludge, until final disposal, in vapor leak-free containers, or in tanks complying with the vapor control requirements of District Rule 4623. Sludge that is to be used to manufacture roadmix, as defined in District Rule 2020, is not required to be stored in this manner. Roadmix manufacturing operations exempt pursuant to District Rule 2020 shall maintain documentation of their compliance with Rule 2020, and shall readily make said documentation available for District inspection upon request. [District Rules 2020 and 2080] Federally Enforceable Through Title V Permit
17. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Heavy Oil Tank Inspection and Maintenance: All piping, fittings, and valves shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the provisions of this permit. If any of the tank components are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If no tank components are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2050, 9.3.2] Federally Enforceable Through Title V Permit
19. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours of detecting the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
20. Upon detection of a leak, permittee shall tag the leak with a uniquely numbered tag, and shall record the leak location, component leaking, identification tag number, leak magnitude, date of leak detection, date of repair, method of repair, and post-repair monitoring measurement. Such records of leaks shall be maintained current and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Components not accessible for EPA Method 21 inspection shall be visually and auditorily checked for leaks at least weekly and shall be monitored using EPA Method 21 at least annually. Any leak detected visually or auditorially shall be recorded and the leak shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. Any leak detected using EPA Method 21 shall be repaired according the leak magnitude as described above and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit
22. In addition to the requirements above, pressure relief devices shall be inspected and monitored for leaks within 3 days of any known, likely, or suspected venting of such devices. [District Rule 2201] Federally Enforceable Through Title V Permit
23. True vapor pressure of any liquid introduced in this permit unit shall be less than 0.5 psia at (or before) tank liquid inlet and at tank storage temperature. [District Rule 4623] Federally Enforceable Through Title V Permit
24. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit
25. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
26. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
27. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
28. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
29. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
30. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
31. The permittee shall keep accurate records of the dates of inspection and monitoring and the components inspected and monitored. [District Rule 2201] Federally Enforceable Through Title V Permit
32. Permittee shall provide District with a copy of D.O.G.G.R. approval for each vapor disposal well prior to use for vapor injection. [District Rule 1070] Federally Enforceable Through Title V Permit
33. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rules 1070 and 4623] Federally Enforceable Through Title V Permit
34. Formerly S-1143-28. [District Rule 2010] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-908-21 **EXPIRATION DATE:** 02/28/2017

SECTION: 4 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MM BTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS FIRED STRUTHERS STEAM GENERATOR (#71) WITH A NORTH AMERICAN GLE LOW-NOX BURNER, A FLUE GAS RECIRCULATION SYSTEM (FGR), AND O2 CONTROLLER

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040 . The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.013 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. The fuel combusted in this unit shall be tested monthly for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which monthly testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

12. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

13. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

16. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

18. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

21. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

28. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. Formerly S-1143-90.

30. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

31. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-912-7 **EXPIRATION DATE:** 02/28/2017

SECTION: SE04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR WITH A NORTH AMERICAN GLE LOW-NOX BURNER AND A FLUE GAS RECIRCULATION (FGR) SYSTEM (RASMUSSEN LEASE)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 1.0 gr S/100 scf. [District Rules 2201; and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201; and 4320, 5.2] Federally Enforceable Through Title V Permit
3. Emissions from the steam generator shall not exceed any of the following limits: 0.014 lb-PM10/MMBtu or 0.003 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 50 ppmvd CO @ 3% O2 or 0.037 lb-CO/MMBtu. [District Rules 2201; 4305, 5.1; 4306, 5.1; and 4320, 5.2] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Maximum emissions from the steam generator, including start-up and shutdown periods, shall not exceed any of the following limits: 54.0 lb-NOx/day, 9,855 lb-NOx/year, 55.5 lb-CO/day, and 14,235 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
27. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
28. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit
29. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-943-19 **EXPIRATION DATE:** 02/28/2017

SECTION: 25 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR GAS-FIRED STEAM GENERATOR (FEE A 2), WITH NORTH AMERICAN GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR)

PERMIT UNIT REQUIREMENTS

1. This steam generator shall operate only as a replacement standby unit for units S-1131-941. [District Rule 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
2. Annual fuel use shall not exceed 90 billion Btu. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
3. The operator shall fire the unit only on natural gas and vapor recovery gas that has a combined fuel sulfur content not exceeding 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
4. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
5. Emission rates shall not exceed any of the following limits: 0.075 lb-PM10/MMBtu; or 0.007 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 45 ppmvd CO @ 3% O2 or 0.033 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. During start-up and shutdown periods, emissions from the natural gas/vapor recovery gas-fired steam generator shall not exceed either of the following limits: 0.1 lb/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 54.0 lb-NOx/day, 1,620 lb-NOx/year, 49.5 lb-CO/day, and 2,340 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
11. During the initial "shakedown" period emissions from the steam generator shall not exceed any of the following limits: 30 ppmvd NOx @ 3% O2 or 0.036 lb-NOx/MMBtu, and 45 ppmvd CO @ 3% O2 or 0.033 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. The shakedown period shall begin upon initial operation of this unit after implementation of the modification authorized by this ATC. The shakedown period shall be concluded within 60 days of initial operation and prior to the applicable Rule 4320 compliance deadline selected for this unit. Permittee shall maintain a record of the date of initial operation and all monitoring records as required by this permit starting on the date of initial operation. [District Rule 2201] Federally Enforceable Through Title V Permit

13. Each fuel source shall be tested semi-annually for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which semi-annual testing may resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

14. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contacts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit

15. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

16. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

20. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

21. A source test to demonstrate compliance with NOx and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

23. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

26. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM 6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

30. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

31. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

32. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

33. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

34. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

35. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

36. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

37. Formerly permit number S-1133-21-11 and S-1109-682-0.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-966-13 **EXPIRATION DATE:** 02/28/2017

SECTION: 30 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT EMISSIONS UNIT: 27.5 MMBTU/HR THERMOTICS VAPOR CONTROL/NATURAL GAS-FIRED STEAM GENERATOR #24 WITH FLUE GAS RECIRCULATION AMETEK THERMOX O2 CONTROLLER (FEE C LEASE)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. All combustion equipment shall be operated to maintain emission standards. [District Rule 2201] Federally Enforceable Through Title V Permit
5. All wells producing from strata steamed by this unit shall be connected to a District-approved emissions control system, have District-approved closed casing vents or be District-approved uncontrolled cyclic wells. [District Rule 4401] Federally Enforceable Through Title V Permit
6. Emission rates for this unit shall not exceed any of the following: PM-10: 0.070 lb/MMBTU, SOx (as SO2): 0.184 lb/MMBTU, NOx (as NO2): 0.036 lb/MMBTU or 30 ppmvd @3% O2, VOC: 0.007 lb/MMBTU, or CO: 0.033 lb/MMBTU or 45 ppmvd @3% O2. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
7. Compliance with the sulfur emissions limit (as SO2) may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 4301] Federally Enforceable Through Title V Permit
8. Fuel hhv for source test purposes shall be certified by a third party fuel supplier or determined using ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 1081] Federally Enforceable Through Title V Permit
9. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit
10. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit
12. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 2520, 9.3.2, 4305 and 4351] Federally Enforceable Through Title V Permit
13. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
14. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
15. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
16. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2201 and 4305] Federally Enforceable Through Title V Permit
17. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
18. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
19. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(Last Amended December 19,1993). [District Rule 1081, and Kern County Rule 108.1] Federally Enforceable Through Title V Permit
20. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
22. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
23. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

27. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

29. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rule 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

30. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

31. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

33. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

35. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

36. Formerly permit number S-1133-3-14 and S-1109-673-0.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-976-10 **EXPIRATION DATE:** 02/28/2017

SECTION: SE19 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 23 MMBTU/HR STRUTHERS GAS-FIRED STEAM GENERATOR WITH FLUE GAS RECIRCULATION AND OXYGEN CONTROLLER/ANALYZER (#13, DIS # 27537-66)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed: PM10; 0.009 lb/MMBtu, SOx (as SO2); 0.005 lb/MMBtu, NOx (as NO2); 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC; 0.003 lb/MMBtu, or CO; 0.002 lb/MMBtu or 2.7 ppmv @ 3% O2. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
5. Except during periods of steam generator startup/shutdown, steam generator shall not be operated unless flue gas recirculation system is operating. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
6. Steam generator may be equipped with a programmable logic controller (PLC). [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
7. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
8. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2, 9.4.2 and 4305] Federally Enforceable Through Title V Permit
9. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
10. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit

12. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit

13. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit

14. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, and stack gas oxygen - EPA Method 3 or 3A or ARB Method 100. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

15. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

16. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

17. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

18. The permittee shall maintain records of fuel type and quantity for each day of operation, in the format approved by the District. [District Rule 2201] Federally Enforceable Through Title V Permit

19. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

20. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1, 5.2.3 and Kern County Rules 404 and 408] Federally Enforceable Through Title V Permit

21. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

22. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

23. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

24. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

25. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2, 4305, 6.2.1, and 4351, 6.2.1] Federally Enforceable Through Title V Permit

26. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

27. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

29. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

30. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

31. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

33. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

34. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

36. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

37. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

38. Formerly S-1109-2.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-987-13 **EXPIRATION DATE:** 02/28/2017

SECTION: SE19 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR THERMOTICS GAS/CASING GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL GLE MAGNA-FLAME LOW NOX BURNER, OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (FGR) SYSTEM (R-3, DIS# 27474-81)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas, recovered vapors and gas from the vapor control system listed on PTO S-1131-885, S-1131-903, S-1131-909 and S-1131-1040. The combined fuel sulfur content from these units shall not exceed 5 gr S/100 scf. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with an operational gas volume flowmeter that measures the combined fuel gas and vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.044 lb-PM10/MMBtu or 0.005 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 31 ppmvd CO @ 3% O2 or 0.023 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the natural gas/vapor recovery gas-fired steam generator shall not exceed either of the following limits: 0.1 lb/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 34.5 lb-CO/day and 12,593 lb-CO/yr. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit
19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit
22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit
24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit
25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit
26. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
27. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
28. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit
29. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Formerly S-1143-90.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-992-15 **EXPIRATION DATE:** 02/28/2017

SECTION: NE29 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR THERMOTICS GAS/CASING GAS-FIRED STEAM GENERATOR WITH OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (PRICEWELL, #P-9, DIS# 27472-81)

PERMIT UNIT REQUIREMENTS

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. The operator shall fire the unit only on PUC-quality natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.029 lb-PM10/MMBtu or 0.005 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 31 ppmvd CO @ 3% O2 or 0.023 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. During start-up and shutdown periods, emissions from the natural gas/vapor recovery gas-fired steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 34.5 lb-CO/day, and 12,593 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

19. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

21. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

32. Formerly S-1109-97.

33. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-993-14 **EXPIRATION DATE:** 02/28/2017

SECTION: NE29 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH OXYGEN CONTROLLER/ANALYZER, FLUE GAS RECIRCULATION (PRICEWELL, P-3, DIS# 28773-85)

PERMIT UNIT REQUIREMENTS

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201,4406, and 4320] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.0063 lb-PM10/MMBtu or 0.0042 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. During start-up and shutdown periods, emissions from the natural gas/vapor recovery gas-fired steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 2201 and 1081] Federally Enforceable Through Title V Permit

19. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

32. Formerly S-1109-104.

33. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-994-10 **EXPIRATION DATE:** 02/28/2017

SECTION: SE09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH LO-NOX BURNER, OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (MCMANUS, PL-8, DIS# 4322-78)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rule 4306] Federally Enforceable Through Title V Permit
4. Unit shall be exclusively gas/casing gas-fired and have no provisions for oil firing. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Testing for fuel gas and casing gas sulfur and BTU content shall be conducted no less than monthly. [District Rule 1081] Federally Enforceable Through Title V Permit
6. Emission rates shall not exceed: PM10; 0.045 lb/MMBtu, SOx (as SO2); 0.062 lb/MMBtu, NOx (as NO2); 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC; 0.005 lb/MMBtu, or CO; 26.7 ppmv @ 3% O2. [District Rules 2201, 4305 and 4351] Federally Enforceable Through Title V Permit
7. Except during periods of steam generator startup/shutdown, steam generator shall not be operated unless flue gas recirculation system is operating. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
8. Steam generator may be equipped with a programmable logic controller (PLC). [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
9. The stack concentration of NOx (as NO2), CO and O2 shall be measured at least on a monthly basis using district approved portable analyzers in any calendar month in which the unit operates. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
10. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2 and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range. These records shall be retained at the facility for a period of no less than five years and shall be made readily available for district inspection upon request. [District Rules 2520, 9.3.2, 9.4.2 and 4305] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after one (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
12. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
13. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
14. If permittee fails any compliance demonstration for NOx and CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
15. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 2520, 9.3.2 and 4305] Federally Enforceable Through Title V Permit
16. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, SOx (lb/MMBtu) - ARB Method 100 and EPA Method 19, fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans, or other test methods approved by the District. [District Rules 1081, 4305 and 4351] Federally Enforceable Through Title V Permit
17. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit
18. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
20. Permittee shall maintain daily records of volume of fuel gas and casing gas burned, monthly fuel gas and casing gas sulfur content and BTU content, and source of casing gas. [District Rules 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. All required source testing shall conform to the compliance testing procedures described in District Rule 1081(Last Amended December 19,1993). [District Rules 1081 and Kern County Rule 108.1] Federally Enforceable Through Title V Permit
22. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
24. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rules 2520, 9.3.2 and 4301, 5.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

25. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

26. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6, 6A, 6B, 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

27. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

28. If fuel analysis is used to demonstrate compliance with the conditions of this permit, the fuel higher heating value for each fuel shall be certified by third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 9.3.2, 4305, 6.2.1 and 4351, 6.2.1] Federally Enforceable Through Title V Permit

29. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period [Kern County Rule 407]. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement.) [District Rules 2520, 9.3.2, 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. Nitrogen oxide (NOx) emission concentrations in ppmv shall be referenced at dry stack gas conditions, and shall be calculated to 3.00 percent by volume stack gas oxygen and averaged over 60 minutes, and lb/MMBtu rates shall be calculated as lb NO2/MMBtu of heat input (hhv). [District Rules 2520, 9.3.2, 4305, 5.0, 8.2 and/or 4351, 8.1] Federally Enforceable Through Title V Permit

36. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

37. Nitrogen oxide (NOx) emissions shall not exceed 140 lb/hr, calculated as NO2. [District Rules 4301, 5.2.2 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

38. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.3] Federally Enforceable Through Title V Permit

39. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

40. Formerly S-1109-108.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-997-12 **EXPIRATION DATE:** 02/28/2017

SECTION: SE13 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR THERMOTICS NATURAL GAS/CASING GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL GLE MAGNA-FLAME BURNER WITH FLUE GAS RECIRCULATION (FGR) AND AN OXYGEN CONTROLLER/ANALYZER (ANGUS 2, DIS# 4509-81)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 gr S/100 scf. [District Rules 2201,4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.045 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 27 ppmvd CO @ 3% O2 or 0.02 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 30.0 lb-CO/day, and 10,950 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6]

12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

13. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 2201 and 1081] Federally Enforceable Through Title V Permit

17. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rules 4320]

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5 (both filterable and condensible), SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. Formerly S-1109-118.

31. This Authority to Construct shall be implemented according to the date proposed in the District approved Rule 4320 Emission Control Plan. [District Rule 2201 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320]

33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-998-14 **EXPIRATION DATE:** 02/28/2017

SECTION: SE25 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN GLE LOW-NOX BURNERS, OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (HOPCO, H-2, DIS# 39454-87)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.007 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

13. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 2201 and 1081] Federally Enforceable Through Title V Permit

17. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320] Federally Enforceable Through Title V Permit
20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
21. Permittee shall submit an analysis showing the fuel sulfur content (as H2S) by either EPA Method 11, 15, or ASTM D6228; total fuel sulfur content by either ASTM D1072, D3246, D6228 or double GC with mercaptans; or conduct a source test for SOx at least once 12 months. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
23. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
26. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
27. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
28. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
29. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
30. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
31. Formerly S-1109-121.

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-999-9 **EXPIRATION DATE:** 02/28/2017

SECTION: SE19 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN MODEL GLE MAGNA-FLAME (OR DISTRICT APPROVED EQUIVALENT), OXYGEN CONTROLLER/ANALYZER, FLUE GAS RECIRCULATION (RAMBLER, R-7, DIS# 12466-82)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 gr S/100 scf. [District Rules 2201 and 4320, 5.4] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.007 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 25 ppmvd CO @ 3% O2 or 0.0185 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. During start-up and shutdown periods, emissions from the natural gas/vapor recovery gas-fired steam generator shall not exceed either of the following limits: 0.1 lb/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. Permittee shall maintain records of duration of each start-up and shutdown. [District Rules 4305, 5.5, 6.1; 4306, 5.3, 6.1; and 4320, 5.6, 6.1] Federally Enforceable Through Title V Permit
8. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, 3.21, 3.25; 4306, 3.22, 3.25; and 4320, 3.25, 3.29] Federally Enforceable Through Title V Permit
9. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

11. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, 6.3; and 4306, 6.3] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. Each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be quarterly. If a quarterly fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 4320, 5.2 and 5.7] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by test methods referenced in this permit. [District Rule 2520, 9.3] Federally Enforceable Through Title V Permit

15. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100; NOx (lb/MMBtu) - EPA Method 19; CO (ppmv) - EPA Method 10 or ARB Method 100; SOx (lb/MMBtu) - EPA Method 6, 6C, 8 or ARB Method 100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, fuel gas sulfur content and EPA Method 19 to calculated emissions; Fuel Gas Sulfur Content - EPA Method 11 or EPA Method 15 or ASTM D1072, D3246, D4084, D6228, or grab sample analysis by double GC; Fuel Gas HHV - ASTM D1826 or D1945 in conjunction with ASTM D3588. PM10 (lb/scf) - EPA Methods 5 (both filterable and condensible), 201A and 202, or CARB Method 5; Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100; Stack Gas Velocity (ft/min) - EPA Method 2; Stack Gas Moisture Content (%) - EPA Method 4. [District Rules 1081; 4305, 6.2; 4306, 6.2; and 4320, 6.2] Federally Enforceable Through Title V Permit

16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit-to-Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 5.4; and 4306, 5.4] Federally Enforceable Through Title V Permit

19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320, 6.2] Federally Enforceable Through Title V Permit

22. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081; 2201; 4305, 5.5; 4306, 5.5; and 4320, 5.8] Federally Enforceable Through Title V Permit

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 6.1; and 4306, 6.1] Federally Enforceable Through Title V Permit

24. Permittee shall maintain daily records of volume of fuel gas burned, sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201; and 4320, 5.2, 5.7] Federally Enforceable Through Title V Permit

25. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; 4305, 6.1; 4306, 6.1; and 4320, 6.1] Federally Enforceable Through Title V Permit

26. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements of District Rule 4201 (as amended December 17, 1992), 4301 (as amended December 17, 1992), 4351 (as amended August 21, 2003), 4406 (as amended December 17, 1992), and 4801 (as amended December 17, 1992). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

27. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

28. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320, 5.1, 5.3] Federally Enforceable Through Title V Permit

29. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070; and 4320, 5.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. Formerly S-1109-127.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1000-14 **EXPIRATION DATE:** 02/28/2017

SECTION: SE25 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN GLE LOW-NOX BURNERS, OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (RAMBLER, R-8, DIS# 12468-82)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.0065 lb-PM10/MMBtu or 0.004 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

13. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

17. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. Formerly S-1109-128.

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1001-15 **EXPIRATION DATE:** 02/28/2017

SECTION: SE09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR W/OXYGEN CONTROLLER/ANALYZER, FLUE GAS RECIRCULATION (CHINA 3, DIS#12467-82

PERMIT UNIT REQUIREMENTS

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-1040. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.006 lb-PM10/MMBtu or 0.0041 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. During start-up and shutdown periods, emissions from the natural gas/vapor recovery gas-fired steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas and the outlet H2S concentration from Sulfa Check unit of on S-1131-1040 at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rule 2201 and 1081] Federally Enforceable Through Title V Permit

19. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

21. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

32. Formerly S-1109-129.

33. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1002-15 **EXPIRATION DATE:** 02/28/2017

SECTION: SE31 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (HOPCO, H-3, DIS# 39455-87)

PERMIT UNIT REQUIREMENTS

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. The operator shall fire the unit only on natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeter that measures the fuel gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.005 lb-SOx/MMBtu, 0.006 lb-PM10/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4320, and 4406] Federally Enforceable Through Title V Permit
5. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.0 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
7. During start-up and shutdown periods, emissions from the natural gas/vapor recovery gas-fired steam generator shall not exceed either of the following limits: 0.1 lb/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520 and Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520 and Rule 4320] Federally Enforceable Through Title V Permit

12. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit

13. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520 and 4320] Federally Enforceable Through Title V Permit

14. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

18. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

19. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

20. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

27. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit

28. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

29. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

30. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

31. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the sulfur content as determined by analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

33. Formerly S-1109-135-14

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1003-14 **EXPIRATION DATE:** 02/28/2017

SECTION: SE25 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN GLE LOW-NOX BURNERS, OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (HOPCO, H-3, DIS# 39455-87)

PERMIT UNIT REQUIREMENTS

1. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
2. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
3. Emission rates shall not exceed any of the following limits: 0.007 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Except during startup and shutdown, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
5. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.4 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
8. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit
9. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

10. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

11. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

13. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

14. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

17. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

20. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

21. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

22. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

23. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

29. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

30. Formerly S-1109-136.

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

32. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1004-14 **EXPIRATION DATE:** 02/28/2017

SECTION: NE29 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR W/ OXYGEN CONTROLLER/ANALYZER, FLUE GAS RECIRCULATION (PRICEWELL, H-4)

PERMIT UNIT REQUIREMENTS

1. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
2. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.007 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Except during startup, shutdown, and the shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 19 ppmvd CO @ 3% O2 or 0.014 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. During start-up and shutdown periods, emissions from the natural gas/vapor recovery gas-fired steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 21.4 lb-CO/day, and 7,665 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

19. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320] Federally Enforceable Through Title V Permit

21. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

24. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC for H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

30. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

32. Formerly S-1109-137.

33. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

34. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1016-15 **EXPIRATION DATE:** 02/28/2017

SECTION: SE13 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR NORTH AMERICAN BURNER (MODEL NA 5131GCR-62.5) AND FLUE GAS RECIRCULATION (ANGUS)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
2. The operator shall fire the unit only on natural gas and gas from the following permit units: PTO S-1131-598, '-885, '-932; '-958, '-996, '-1007, and '-1008. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5.0 gr S/100 scf. [District Rules 2201, 4406, and 4320] Federally Enforceable Through Title V Permit
3. Steam generator shall be equipped with operational gas volume flowmeters that measures each the fuel gas and the vapor recovery gas volume sent to the steam generator. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit
4. Emission rates shall not exceed any of the following limits: 0.045 lb-PM10/MMBtu or 0.006 lb-VOC/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Except during startup and shutdown emissions shall not exceed any of the following limits: 15 ppmvd NOx @ 3% O2 or 0.018 lb-NOx/MMBtu and 27 ppmvd CO @ 3% O2 or 0.02 lb-CO/MMBtu. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
6. During start-up and shutdown periods, emissions from the natural gas/vapor recovery gas-fired steam generator shall not exceed either of the following limits: 0.1 lb/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Including startup and shutdown periods, maximum emissions from the steam generator shall not exceed any of the following limits: 0.1 lb-NOx/MMBtu, 54.0 lb-NOx/day, 9,855 lb-NOx/year, 0.084 lb-CO/MMBtu, 30 lb-CO/day, and 10,950 lb-CO/year. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Duration of startup or shutdown shall not exceed two hours each per occurrence. The emissions control system shall be in operation and emissions shall be minimized insofar as technologically possible during startup and shutdown. [District Rules, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
9. Permittee shall maintain records of duration of each start-up and shutdown. Startup is defined as the period of time to reach operating temperature and pressure once fuel is supplied, including the time required by the emission control system to reach full operation. Shutdown is defined as the period of time taken from operating temperature and pressure until the fuel supply is completely turned off. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
10. When incinerating vapor recovery gas in this unit, permittee shall measure and record the sulfur content and higher heating value of the vapor recovery gas at least monthly using the test methods referenced in this permit. [District Rules 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. When pipeline quality natural gas is used to fuel this unit, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

12. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rule 2520, 9.3.2 and Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

13. If the unit is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320, 5.7.6] Federally Enforceable Through Title V Permit

14. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by: ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 2520, 9.3.2 and 4320, 6.2.1] Federally Enforceable Through Title V Permit

15. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

17. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

18. Exhaust gas stack shall be equipped with adequate provisions facilitating the collection of gas samples consistent with EPA Test Methods. [District Rules 2201 and 1081] Federally Enforceable Through Title V Permit

19. A source test to demonstrate compliance with NOx and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

20. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2520, 9.3.2, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. Source testing shall be conducted using the methods and procedures approved by the District. Source testing for compliance demonstration shall be conducted by independent testing laboratories, and shall be witnessed, or authorized by the District personnel. Sample collection shall be by ARB certified testing laboratory. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

22. Permittee shall submit an analysis to the District demonstrating compliance with the fuel sulfur content and higher heating value within 60 days of startup and at least once every 12 months. The sulfur content and higher heating value of the fuel shall be determined using the test methods referenced in this permit or certified by a third party fuel supplier. [District Rule 4320] Federally Enforceable Through Title V Permit

23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

24. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

25. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture - EPA Method 4, PM10 - EPA Method 5, SOx (lb/MMBtu) - EPA Method 6C or 8 or ARB Method 100, or fuel gas sulfur content analysis (as H2S) - EPA Method 11 or 15 or ASTM D6228 and (as total sulfur) - ASTM D1072, D3246, or D6228, or grab sample analysis by double GC foR H2S and mercaptans or GC FPTD/TCD, performed in the laboratory, fuel hhv (MMBtu) - ASTM D 1826 or D 1945 (as methane) in conjunction with ASTM D 3588. [District Rules 1081, 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

27. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 1081, 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

28. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

29. Permittee shall maintain daily records of total combined volume of fuel gas and vapor recovery gas burned, the dates of any fuel type switching, the monthly NOx and CO emissions limit determinations, the sulfur content and higher heat value as determined by periodic analytical testing or fuel supplier invoices/certifications, and permit number(s) of systems providing gas for incineration. [District Rules 2201, 2520, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

30. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

31. Compliance with permit conditions in the Title V permit shall be deemed compliance with the requirements of District Rules 4201, 4301 and 4801. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

33. Formerly S-1109-221-15.

34. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

35. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and Rule 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1036-12 **EXPIRATION DATE:** 02/28/2017

EQUIPMENT DESCRIPTION:
TEOR OPERATION WITH 885 THERMALLY ENHANCED WELLS WITH CLOSED CASING VENTS

PERMIT UNIT REQUIREMENTS

1. When the number of wells in operation exceeds 485, before any ground disturbance activities on the project site, a qualified registered biologist shall conduct a focused survey to determine the presence/absence of potential impacts on sensitive species on-site and riparian habitat. The survey shall be conducted in accordance with the standard protocol of California Department of Fish & Game (CDFG) and/or California Department of Fish & Game (CDFG). Chevron U.S.A., Inc will notify CDFG and the US Fish and Wildlife Service (USFWS) in the event a State or Federally listed species is encountered. Results of the survey shall be made available for District inspection upon request. [Public Resources Code 21000-21177: California Environmental Quality Act]
2. When the number of wells in operation exceeds 485, before any ground disturbance activities on the project site, a qualified registered biologist shall conduct a focused survey to determine the presence/absence of potential impacts on the movement of any native resident or migratory fish or wildlife species, corridors, or nursery sites. Chevron U.S.A., Inc will notify California Department of Fish & Game and the US Fish and Wildlife Service in the event a State or Federally listed species is encountered. Results of the survey shall be made available for District inspection upon request. [Public Resources Code 21000-21177: California Environmental Quality Act]
3. When the number of wells in operation exceeds 485, Chevron U.S.A., Inc shall notify the US Fish and Wildlife Service (USFWS) and the California Department of Fish & Game (CDFG) immediately in the event that the Project avoidance measures fail and there is a take of a threatened or endangered species. No activities shall occur until Incidental Take authorization has been obtained from USFWS and CDFG. Documentation demonstrating authorization shall be made available for District inspection upon request. [Public Resources Code 21000-21177: California Environmental Quality Act]

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

4. When the number of wells in operation exceeds 485, for Western Pond Turtle and American Badger: A qualified biological monitor will be present during project implementation. The biological monitor shall be notified immediately should the western pond turtle enter the project area and work shall be halted until there is no longer a potential to adversely impact the species. All vehicles and equipment entering the project area will be in good working condition and free from leaks. In the event that a vehicle or equipment item is found to be leaking fluid, operation of the vehicle or equipment item shall be terminated and it shall be repaired or replaced. If possible, repairs should be conducted in a contained area. All contaminated soil will be collected and properly disposed off the project site. To reduce the potential for direct and indirect impacts to American badger to a less-than-significant level, a qualified biologist will be retained prior to ground disturbing activities to conduct a pre-construction survey of the project area. The pre-construction survey would be conducted within the proposed project boundary and a buffer of 200 feet outside of the project footprint. If the preactivity survey indicates the presence of badger dens, they shall be classified as inactive, potentially active, or definitely active. (a) Inactive dens will be excavated by hand and backfilled to prevent reuse by badgers. (b) Potentially and definitely active dens will be monitored for three consecutive nights using a tracking medium (such as diatomaceous earth or fire clay) at the entrance. If no tracks or other sign are observed in the tracking medium at the conclusion of the three nights, the den will be excavated and backfilled by hand under the direction and supervision of a qualified biologist. If tracks are observed, the den will be progressively blocked with natural materials (dirt, sticks, and vegetation piled in front of the entrance) for the next three to five nights to discourage the badger from continued use. When a qualified biologist has determined that the den is no longer active, the den will be excavated and backfilled by hand to ensure that no badgers are trapped in the den. Results of the survey shall be made available for District inspection upon request. [Public Resources Code 21000-21177: California Environmental Quality Act]
5. When the number of wells in operation exceeds 485, Chevron U.S.A., Inc shall purchase sufficient credit from the Kern Water Bank Authority (KWBA) to mitigate for permanent and temporary habitat impacts. Documentation demonstrating the purchase shall be made available for District inspection upon request. [Public Resources Code 21000-21177: California Environmental Quality Act]
6. Total fugitive emission of volatile organic compounds (VOC) from entire operation shall not exceed 146.6 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Permittee shall maintain with the permit accurate fugitive component counts for well vent vapor control systems and resulting emissions calculated using CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c(Feb 1999) Screening Range emission factors. [District Rule 2201] Federally Enforceable Through Title V Permit
8. Fluids produced from these steam-enhanced wells with closed well casing vents shall be introduced only to tanks vented to a District approved vapor collection and control system, or to permit exempt storage equipment as defined by Rule 2020, Section 6.6 (Amended August 18, 2011). [District Rule 2201] Federally Enforceable Through Title V Permit
9. Well casing vents shall remain closed at all times except during periods of actual service or repair when wells are not producing. [District Rule 2201] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit
11. The inspection requirements of Section 5.4.1 through Section 5.4.7 of Rule 4401 shall not apply to components exclusively handling gas/vapor or liquid with a VOC content of ten percent by weight (10%) or less, as determined by the test methods in Section 6.3.4 of Rule 4401. [District Rule 4401, 4.7] Federally Enforceable Through Title V Permit
12. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401, 3.20] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1 and 5.1] Federally Enforceable Through Title V Permit
14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit
15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit
16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit
19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
21. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401 5.5] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
29. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

35. The operator shall maintain an inspection log that has been signed and dated by the facility operator responsible for the inspection, certifying the accuracy of the information recorded in the log. The inspection log shall contain, at a minimum, all of the following information: 1) The total number of components inspected, and the total number and percentage of leaking components found by component types; 2) The location, type, name or description of each leaking component and the description of any unit where the leaking component is found; 3) Date of the leak detection and method of the leak detection; 4) For gaseous leaks, record the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak; 5) The date of repair, replacement, or removal from operation of the leaking component(s); 6) The identification and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes first; 7) The method(s) used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier; 8) The date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced; 9) The inspector's name, business mailing address, and business telephone number. [District Rule 4401, 6.4] Federally Enforceable Through Title V Permit

36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

37. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401 6.1] Federally Enforceable Through Title V Permit

38. The results of gauge tank TVP testing conducted pursuant to Section 6.2.3 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

39. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

40. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. A process system as defined in Section 3.30 of Rule 4401 is not subject to compliance source testing requirements. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

41. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection are controlled by an internal combustion engine subject to Rule 4702, a combustion device subject to Rule 4320, 4307 or 4308, a flare subject to Rule 4311. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

42. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.0 of Rule 4401: Conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.9 of Rule 4401. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

43. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

44. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

45. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

46. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

47. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401, 6.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

48. The operator shall maintain an APCO approved Operator Management Plan (OMP). The OMP shall include, at a minimum, a description of all wells and all associated VOC collection and control systems subject to this rule, and all wells and all associated VOC collection and control systems that are exempt; an identification and description of any known hazard that might affect the safety of an inspector; except for pipes, the number of components that are subject to this rule by component type; except for pipes, the number and types of major components, inaccessible components, unsafe-to-monitor components, critical components, and essential components that are subject to this rule and the reason(s) for such designation; except for pipes, the location of components subject to the rule (components may be grouped together functionally by process unit or facility description); except for pipes, components exempt pursuant to Section 4.8 (except for components buried below ground) may be described in the OMP by grouping them functionally by process unit or facility description (the results of any laboratory testing or other pertinent information to demonstrate compliance with the applicable exemption criteria for components for which an exemption is being claimed pursuant to Sections 4.8 shall be submitted with the OMP); a detailed schedule of an operator's inspections of components to be conducted as required by this rule and whether the operator inspections of components required by this rule will be performed by a qualified contractor or by an in-house team; a description of the training standards for personnel that inspect and repair components; and a description of the leak detection training for conducting the test method specified in Section 6.3.3 for new operators, and for experienced operators, as necessary. [District Rule 4401, 6.6] Federally Enforceable Through Title V Permit

49. Operator shall keep a list of all gauge tanks, as defined in Section 3.0 of Rule 4401. The list shall contain the size, identification number, the location of each gauge tank and specify whether the gauge tank is upstream of all front line production equipment. [District Rule 4401, 6.1 and 6.6] Federally Enforceable Through Title V Permit

50. By January 30 of each year, an operator shall submit to the APCO for approval, in writing, an annual report indicating any changes to an existing Operator Management Plan. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

51. Records of wells constructed when wells in operation exceed 485 shall be maintained including location, construction start date and documentation required by California Environmental Quality Act conditions listed on this permit for a minimum of 5 years. [Public Resources Code 21000-21177: California Environmental Quality Act]

52. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

53. Formerly permit number S-1109-361-1.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1037-9 **EXPIRATION DATE:** 02/28/2017

SECTION: NW10 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
249.0 MMBTU/HR (NOMINAL RATING), 20 MW GENERAL ELECTRIC GAS-FIRED TURBINE ENGINE COGENERATION SYSTEM WITH SCR, AMMONIA STORAGE AND DISTRIBUTION SYSTEM, CO CATALYTIC CONVERTER AND CEM SYSTEM FOR NOX, CO AND O2

PERMIT UNIT REQUIREMENTS

1. Cogeneration system shall include General Electric model LM-2500PE gas turbine, generator set rated at 22.89 MW, turbine combustor and compressor water injection systems, SCR, CO catalyst, and CEM's for NOx, CO, & O2. [40 CFR 64 and District Rule 2201] Federally Enforceable Through Title V Permit
2. Lube oil cooler/accumulator shall be equipped with device to prevent detectable emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
3. Ammonia injection rate shall be controlled to maintain ammonia breakthrough to less than 20 ppmv. [District Rule 4102]
4. If water injection, SCR, or CO catalyst is inoperative, turbine shall be shut down. [District Rule 2201] Federally Enforceable Through Title V Permit
5. All turbine exhaust shall flow through both catalyst beds. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Gas turbine engine exhaust may be diverted to bypass stack during cold engine startup. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Gas turbine engine exhaust may be diverted to bypass stack under Rule 1100 (Equipment Breakdown), provided all applicable record keeping and reporting requirements of Rule 1100 are fulfilled. [District Rule 1100] Federally Enforceable Through Title V Permit
8. CEM equipment shall be maintained and calibrated according to EPA guidelines specified in CFR Part 60, Appendix B. [40 CFR 60.334 (b); 40 CFR 60; and District Rule 1080] Federally Enforceable Through Title V Permit
9. Except days with periods of startup/shutdown, emission rates shall not exceed any of the following: PM10: 77.7 lb/day, SOx (as SO2): 29.9 lb/day, NOx (as NO2): 110.0 lb/day, VOC: 239.0 lb/day, or CO: 160.8 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
11. Except during periods of startup/shutdown, emission rates shall not exceed any of the following: PM10: 0.013 lb/MMBTU, SOx (as SO2): 0.005 lb/MMBTU, or VOC: 0.040 lb/MMBTU. [40 CFR 60.333(a) and (b) and District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during periods of startup/shutdown, emission rates (3-hour rolling average) shall not exceed any of the following: NOx (as NO2): 0.018 lb/MMBTU or 5 ppmvd @ 15% O2, or CO: 12 ppmvd @ 15% O2. [District Rules 2201; and 4703, 5.1, 5.2, 5.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. NOx emission rate (one hour average) shall not exceed the NSPS standard of 150 ppmvd @ 15% O2. [40 CFR 60.332(a)] Federally Enforceable Through Title V Permit
14. Except during periods of gas turbine engine startup/shutdown, water injection rate shall be maintained at water-to-fuel ratio documented to achieve compliance with emission limits. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Except during periods of gas turbine engine startup/shutdown, inlet gas temperature to both catalyst beds shall be maintained within the range as recommended by catalyst manufacturer. [District Rule 2201] Federally Enforceable Through Title V Permit
16. The duration of each startup or shutdown shall not exceed two hours. [40 CFR 60.2; and District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. [District Rule 4703, 3.29] Federally Enforceable Through Title V Permit
18. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4703, 3.26] Federally Enforceable Through Title V Permit
19. Bypass transition period is defined as the duration of time that a gas turbine's operation transitions between the heat recovery steam generator and bypass exhaust stacks, provided that the SCR catalyst is not within the required temperature range or the required ammonia saturation level has not yet been achieved; and NOx emissions shall not exceed 15 ppmvd @ 15% O2 averaged over 2 hours; and the duration of a bypass transition period shall not exceed two hours except during black start period. [District Rule 4703, 3.2] Federally Enforceable Through Title V Permit
20. Reduced load period is defined as the time during which a gas turbine is operated at less than rated capacity in order to change the position of the exhaust gas diverter gate. Each reduced load period shall not exceed one hour. [District Rule 4703, 3.23] Federally Enforceable Through Title V Permit
21. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rule 4703, 5.3] Federally Enforceable Through Title V Permit
22. The owner or operator shall certify, maintain, operate, and quality-assure a continuous emission monitor system (CEMS) which continuously measures and records the exhaust gas NOx, CO, and O2 concentrations. Continuous emissions monitors shall be capable of monitoring emissions during normal operating conditions and during startups and shutdowns, provided that CEMS pass the relative accuracy requirements and performance specifications of: 40 CFR Part 60, Appendix B and F; 40 CFR Part 51, Appendix P; Performance Specification 2 (PS-2); and District approved protocol for startups. If relative accuracy of CEMS cannot be demonstrated during the startup, CEMS results during startup and shutdown events shall be replaced with startup emission rates obtained from the source test conducted by the facility to determine compliance with emission limits contained in this document. [40 CFR 60.334(b)(1); 40 CFR 64; and District Rules 1080, 6.7; and 4703, 6.2] Federally Enforceable Through Title V Permit
23. The owner or operator shall maintain all records of required monitoring data and support information for a period of five years from the date of data entry and shall make such records available to the District upon request. [District Rule 4703, 6.2] Federally Enforceable Through Title V Permit
24. The owner or operator shall maintain a stationary gas turbine system operating log that includes, on a daily basis, the actual local startup and stop time, length and reason for reduced load periods, total hours of operation, the type and quantity of fuel used, duration of each start-up (or black start), shutdown, and bypass transition time period. [District Rule 4703, 6.2] Federally Enforceable Through Title V Permit
25. Compliance source testing for NOx, CO, VOC, NH3 and fuel gas sulfur content shall be conducted at least once every 12 months. [40 CFR 60.335(a) and District Rules 1081; and 4703, 3.6, 6.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

26. The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front and back half) or 201 and 202a; Ammonia - BAAQMD ST-1B; O2 - EPA Method 3, 3A, or 20 or CARB Method 100; and HHV and LHV - ASTM D3588-91, ASTM 1826-88, or ASTM 1945-81. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.335(a) and (b)(1) and District Rules 1081; and 4703, 6.4] Federally Enforceable Through Title V Permit

27. CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

28. Results of continuous emission monitoring shall be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(b)(3) and 40 CFR 64] Federally Enforceable Through Title V Permit

29. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit

30. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, then a fuel sample shall be collected during the source test to determine the sulfur content of the fuel combusted in the turbine. The fuel sample shall be analyzed for the total sulfur content using ASTM D1072; D3246; D4084; D4468; D6228; or D6667; or double GC for H2S and mercaptans. The applicable ranges of some ASTM methods are not adequate to measure the levels of sulfur in some fuel gases. Dilution o10)f samples before analysis (with verification of dilution ratio) may be used after getting a prior approval from the District. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

31. Monitor downtime for NOx shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOX concentration or diluent O2 (or both). [40 CFR 60.334(j)1)(iii)(B)] Federally Enforceable Through Title V Permit

32. The owner or operator shall submit a written report of CEMS operations for each calendar quarter to the District. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j)(5); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

33. The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit

34. Permittee shall report the following emission exceedences to the District: emission rates of NOx & CO on a three-hour rolling average, and NSPS emission rate on a four hour average. [District Rule 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

35. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 2201] Federally Enforceable Through Title V Permit

36. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [District Rule 1081] Federally Enforceable Through Title V Permit

37. The sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D4084, D5504, D6228, Gas Processors Association Standard 2377 or double GC for H2S and mercaptans. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

38. The sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(h)(3)] Federally Enforceable Through Title V Permit

39. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080] Federally Enforceable Through Title V Permit

40. Results of continuous emission monitoring must be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(j),(j)(5); 40 CFR 64; and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

41. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.335(a), (b)(7); and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

42. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [40 CFR 60.7 (b); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

43. Permittee shall maintain accurate records of ammonia consumption and all maintenance activities related to this unit. [District Rule 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

44. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx and CO daily emission limitations by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District Rule 2201] Federally Enforceable Through Title V Permit

45. Audits of monitors shall be conducted annually by independent testing lab in accordance with EPA guidelines, witnessed or authorized by the District, and reports shall be submitted to the District within 60 days of audit. [District Rule 1080] Federally Enforceable Through Title V Permit

46. Operator shall submit a semiannual report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)(3)(D)] Federally Enforceable Through Title V Permit

47. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit

48. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [40 CFR 64 and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit

49. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

50. Formerly S-1109-362-18.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1038-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NW10 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
DORMANT 58.2 MMBTU/HR (NOMINAL RATING), 4.0 MW ALLISON MODEL 501-KB5 GAS-FIRED TURBINE ENGINE COGENERATION SYSTEM WITH WATER INJECTION, HEAT RECOVERY STEAM GENERATOR, AND CEM SYSTEMS FOR NOX, CO, AND O2

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4703] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4703 and all other applicable District regulations. [District Rule 4703] Federally Enforceable Through Title V Permit
4. Either conventional or pilotless fuel nozzles may be used. [District Rule 2010] Federally Enforceable Through Title V Permit
5. Lube oil cooler/accumulator shall be equipped with device to prevent detectable emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
6. If water injection is inoperative, turbine shall be shut down. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Turbine shall not burn more than 1.33 MMscf/day of natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
8. All turbine exhaust shall flow to heat recovery steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
9. CEM equipment shall be maintained and calibrated according to EPA guidelines specified in CFR Part 60, Appendix B. [40 CFR 60.334 (b); 40 CFR 60; and District Rule 1080] Federally Enforceable Through Title V Permit
10. Unit shall be equipped with continuously recording fuel gas flowmeter. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Gas turbine engine exhaust may be diverted to bypass stack under Rule 1100 (Equipment Breakdown), provided all applicable record keeping and reporting requirements of Rule 1100 are fulfilled. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Emission rates shall not exceed any of the following: PM10: 17.9 lb/day, SOx (as SO2): 8.4 lb/day, NOx (as NO2): 180.2 lb/day, VOC: 48.9 lb/day, or CO: 125.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Except during periods of startup/shutdown, emission rates (3-hour rolling average) shall not exceed any of the following: PM10: 0.0128 lb/MMBTU, SOx (as SO2): 0.006 lb/MMBTU, NOx (as NO2): 0.129 lb/MMBTU or 38 ppmvd @ 15% O2, VOC: 0.035 lb/MMBTU, or CO: 40 ppmvd @ 15% O2. [40 CFR 60.333(a) and (b) and District Rules 2201; and 4703] Federally Enforceable Through Title V Permit
14. NOx emission rate (one hour average) shall not exceed the NSPS standard of 150 ppmvd @ 15% O2. [40 CFR 60.332(a)] Federally Enforceable Through Title V Permit
15. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
16. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Except during periods of gas turbine engine startup/shutdown, gas turbine water injection rate shall be maintained at water-to-fuel ratio documented to achieve compliance with emission limits. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Reduced load period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.16] Federally Enforceable Through Title V Permit
19. Thermal stabilization period shall be defined as the start-up or shutdown time necessary to bring the heat recovery steam generator to proper temperature, not exceeding two hours. [District Rule 4703, 3.21] Federally Enforceable Through Title V Permit
20. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx and CO daily emission limitations by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Compliance source testing for NOx, CO, fuel gas sulfur content, and demonstrated percent efficiency of gas turbine engine shall be conducted at least once every 12 months. [District Rules 2201; and 4703] Federally Enforceable Through Title V Permit
22. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Permittee shall submit to the APCO the information correlating the control system operating parameters to the associated measured NOx output. [District Rule 4703, 6.2.3] Federally Enforceable Through Title V Permit
24. Except during periods of thermal stabilization or reduced loads, NOx emission rate shall not exceed 35 ppmv at 15% O2 on a 3 hour rolling average basis. [District Rule 4703, 5.1.2 and 7.2.1] Federally Enforceable Through Title V Permit
25. Permittee shall report the following emission exceedences to the District: emission rates of NOx & CO on a three-hour rolling average, NSPS emission rate on one hour average, and DEL of NOx & CO during days of gas turbine engine startup/shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
26. For units equipped with continuous emissions monitors (CEMs), CEM records shall be used in place of calculated emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
27. If monitoring provisions fail, the emissions shall be calculated on operational data (steam production rate, inlet air and exhaust gas flowrates, etc.) or, if such data is not available, for the four days of operation preceding the breakdown. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Audits of monitors shall be conducted at least once every 12 months by independent testing lab in accordance with EPA guidelines, witnessed by District, and reports shall be submitted to District within 60 days of audit. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Kern County Rule 108.1; District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(h)(3) and (i)(3)(i)] Federally Enforceable Through Title V Permit

31. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, then a fuel sample shall be collected during the source test to determine the sulfur content of the fuel combusted in the turbine. The fuel sample shall be analyzed for the total sulfur content using ASTM D1072; D3246; D4084; D4468; D6228; or D6667; or double GC for H2S and mercaptans. The applicable ranges of some ASTM methods are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of dilution ratio) may be used after getting a prior approval from the District. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

32. The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front and back half) or 201 and 202a; Ammonia - BAAQMD ST-1B; O2 - EPA Method 3, 3A, or 20 or CARB Method 100; and HHV and LHV - ASTM D3588-91, ASTM 1826-88, or ASTM 1945-81. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.335(a) and (b)(1) and District Rules 1081; and 4703, 6.4] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of quantity of fuel used per day, all maintenance activities related to this unit, and date and time of fuel nozzle replacement, and type of fuel nozzle installed. [District Rule 2201] Federally Enforceable Through Title V Permit

34. Operator shall install, operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, and the exhaust gas NOx concentration at 15% O2 on a dry basis. [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit

35. The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit

36. The owner or operator shall certify, maintain, operate, and quality-assure a continuous emission monitor system (CEMS) which continuously measures and records the exhaust gas NOx, CO, and O2 concentrations. Continuous emissions monitors shall be capable of monitoring emissions during normal operating conditions and during startups and shutdowns, provided that CEMS pass the relative accuracy requirements and performance specifications of: 40 CFR Part 60, Appendix B and F; 40 CFR Part 51, Appendix P; Performance Specification 2 (PS-2); and District approved protocol for startups. If relative accuracy of CEMS cannot be demonstrated during the startup, CEMS results during startup and shutdown events shall be replaced with startup emission rates obtained from the source test conducted by the facility to determine compliance with emission limits contained in this document. [40 CFR 60.334(b)(1); 40 CFR 64; and District Rules 1080, 6.7; and 4703, 6.2] Federally Enforceable Through Title V Permit

37. Should the applicant decide to conduct performance evaluation of CEMS with the initial performance test, a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load shall be performed. The test data obtained during these run can be used to demonstrate compliance with the applicable NOx emission limit and to provide reference method data for the RATA of the CEMS. The requirement to test at three additional load levels is waived under this option. [40 CFR 60.335(b)(2)] Federally Enforceable Through Title V Permit

38. Monitor downtime for NOx shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOX concentration or diluent O2 (or both). [40 CFR 60.334(j)1)(iii)(B)] Federally Enforceable Through Title V Permit

39. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [40 CFR 60.7 (b); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

41. Results of continuous emission monitoring shall be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(b)(3) and 40 CFR 64] Federally Enforceable Through Title V Permit

42. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit

43. Operator shall submit a semiannual report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)(3)(D)] Federally Enforceable Through Title V Permit

44. CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

45. The owner or operator shall submit a written report of CEMS operations for each calendar quarter to the District. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j)(5); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

46. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit

47. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [40 CFR 64 and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit

48. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

49. Formerly S-1109-373-15.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1039-8 **EXPIRATION DATE:** 02/28/2017

SECTION: NW10 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
DORMANT 58.2 MMBTU/HR (NOMINAL RATING), 4.0 MW ALLISON MODEL 501-KB5 GAS-FIRED TURBINE ENGINE COGENERATION SYSTEM WITH WATER INJECTION, HEAT RECOVERY STEAM GENERATOR, AND CEM SYSTEMS FOR NOX, CO, AND O2

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rule 4703] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4703 and all other applicable District regulations. [District Rule 4703] Federally Enforceable Through Title V Permit
4. Either conventional or pilotless fuel nozzles may be used. [District Rule 2010] Federally Enforceable Through Title V Permit
5. Lube oil cooler/accumulator shall be equipped with device to prevent detectable emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
6. If water injection is inoperative, turbine shall be shut down. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Turbine shall not burn more than 1.33 MMscf/day of natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
8. All turbine exhaust shall flow to heat recovery steam generator. [District Rule 2201] Federally Enforceable Through Title V Permit
9. CEM equipment shall be maintained and calibrated according to EPA guidelines specified in CFR Part 60, Appendix B. [40 CFR 60.334 (b); 40 CFR 60; and District Rule 1080] Federally Enforceable Through Title V Permit
10. Unit shall be equipped with continuously recording fuel gas flowmeter. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Gas turbine engine exhaust may be diverted to bypass stack under Rule 1100 (Equipment Breakdown), provided all applicable record keeping and reporting requirements of Rule 1100 are fulfilled. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Emission rates shall not exceed any of the following: PM10: 17.9 lb/day, SOx (as SO2): 8.4 lb/day, NOx (as NO2): 180.2 lb/day, VOC: 48.9 lb/day, or CO: 125.2 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Except during periods of startup/shutdown, emission rates (3-hour rolling average) shall not exceed any of the following: PM10: 0.0128 lb/MMBTU, SOx (as SO2): 0.006 lb/MMBTU, NOx (as NO2): 0.129 lb/MMBTU or 38 ppmvd @ 15% O2, VOC: 0.035 lb/MMBTU, or CO: 40 ppmvd @ 15% O2. [40 CFR 60.333(a) and (b) and District Rules 2201; and 4703] Federally Enforceable Through Title V Permit
14. NOx emission rate (one hour average) shall not exceed the NSPS standard of 150 ppmvd @ 15% O2. [40 CFR 60.332(a)] Federally Enforceable Through Title V Permit
15. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201] Federally Enforceable Through Title V Permit
16. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Except during periods of gas turbine engine startup/shutdown, gas turbine water injection rate shall be maintained at water-to-fuel ratio documented to achieve compliance with emission limits. [District Rule 2201] Federally Enforceable Through Title V Permit
18. Reduced load period shall be defined as the time during which a gas turbine is operated at less than rated capacity in order to change the exhaust gas diverter gate not exceeding one hour. [District Rule 4703, 3.16] Federally Enforceable Through Title V Permit
19. Thermal stabilization period shall be defined as the start-up or shutdown time necessary to bring the heat recovery steam generator to proper temperature, not exceeding two hours. [District Rule 4703, 3.21] Federally Enforceable Through Title V Permit
20. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx and CO daily emission limitations by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District Rule 2201] Federally Enforceable Through Title V Permit
21. Compliance source testing for NOx, CO, fuel gas sulfur content, and demonstrated percent efficiency of gas turbine engine shall be conducted at least once every 12 months. [District Rules 2201; and 4703] Federally Enforceable Through Title V Permit
22. Compliance source testing shall be conducted under conditions representative of normal operation. [District Rule 1081] Federally Enforceable Through Title V Permit
23. Permittee shall submit to the APCO the information correlating the control system operating parameters to the associated measured NOx output. [District Rule 4703, 6.2.3] Federally Enforceable Through Title V Permit
24. Except during periods of thermal stabilization or reduced loads, NOx emission rate shall not exceed 35 ppmv at 15% O2 on a 3 hour rolling average basis. [District Rule 4703, 5.1.2 and 7.2.1] Federally Enforceable Through Title V Permit
25. Permittee shall report the following emission exceedences to the District: emission rates of NOx & CO on a three-hour rolling average, NSPS emission rate on one hour average, and DEL of NOx & CO during days of gas turbine engine startup/shutdown. [District Rule 2201] Federally Enforceable Through Title V Permit
26. For units equipped with continuous emissions monitors (CEMs), CEM records shall be used in place of calculated emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
27. If monitoring provisions fail, the emissions shall be calculated on operational data (steam production rate, inlet air and exhaust gas flowrates, etc.) or, if such data is not available, for the four days of operation preceding the breakdown. [District Rule 2201] Federally Enforceable Through Title V Permit
28. Audits of monitors shall be conducted at least once every 12 months by independent testing lab in accordance with EPA guidelines, witnessed by District, and reports shall be submitted to District within 60 days of audit. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Kern County Rule 108.1; District Rule 1081] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(h)(3) and (i)(3)(i)] Federally Enforceable Through Title V Permit

31. If the turbine is not fired on PUC-regulated or FERC-regulated natural gas, then a fuel sample shall be collected during the source test to determine the sulfur content of the fuel combusted in the turbine. The fuel sample shall be analyzed for the total sulfur content using ASTM D1072; D3246; D4084; D4468; D6228; or D6667; or double GC for H2S and mercaptans. The applicable ranges of some ASTM methods are not adequate to measure the levels of sulfur in some fuel gases. Dilution of samples before analysis (with verification of dilution ratio) may be used after getting a prior approval from the District. [40 CFR 60.335(b)(10)] Federally Enforceable Through Title V Permit

32. The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front and back half) or 201 and 202a; Ammonia - BAAQMD ST-1B; O2 - EPA Method 3, 3A, or 20 or CARB Method 100; and HHV and LHV - ASTM D3588-91, ASTM 1826-88, or ASTM 1945-81. EPA approved alternative test methods as approved by the District may also be used to address the source testing requirements of this permit. [40 CFR 60.335(a) and (b)(1) and District Rules 1081; and 4703, 6.4] Federally Enforceable Through Title V Permit

33. Permittee shall maintain records of quantity of fuel used per day, all maintenance activities related to this unit, and date and time of fuel nozzle replacement, and type of fuel nozzle installed. [District Rule 2201] Federally Enforceable Through Title V Permit

34. Operator shall install, operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, and the exhaust gas NOx concentration at 15% O2 on a dry basis. [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit

35. The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit

36. The owner or operator shall certify, maintain, operate, and quality-assure a continuous emission monitor system (CEMS) which continuously measures and records the exhaust gas NOx, CO, and O2 concentrations. Continuous emissions monitors shall be capable of monitoring emissions during normal operating conditions and during startups and shutdowns, provided that CEMS pass the relative accuracy requirements and performance specifications of: 40 CFR Part 60, Appendix B and F; 40 CFR Part 51, Appendix P; Performance Specification 2 (PS-2); and District approved protocol for startups. If relative accuracy of CEMS cannot be demonstrated during the startup, CEMS results during startup and shutdown events shall be replaced with startup emission rates obtained from the source test conducted by the facility to determine compliance with emission limits contained in this document. [40 CFR 60.334(b)(1); 40 CFR 64; and District Rules 1080, 6.7; and 4703, 6.2] Federally Enforceable Through Title V Permit

37. Should the applicant decide to conduct performance evaluation of CEMS with the initial performance test, a minimum of 9 reference method runs, with a minimum time per run of 21 minutes, at a single load level, between 90 and 100 percent of peak (or the highest physically achievable) load shall be performed. The test data obtained during these run can be used to demonstrate compliance with the applicable NOx emission limit and to provide reference method data for the RATA of the CEMS. The requirement to test at three additional load levels is waived under this option. [40 CFR 60.335(b)(2)] Federally Enforceable Through Title V Permit

38. Monitor downtime for NOx shall be any unit operating hour in which sufficient data are not obtained to validate the hour for either NOX concentration or diluent O2 (or both). [40 CFR 60.334(j)1)(iii)(B)] Federally Enforceable Through Title V Permit

39. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [40 CFR 64 and District Rule 1080] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [40 CFR 60.7 (b); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

41. Results of continuous emission monitoring shall be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(b)(3) and 40 CFR 64] Federally Enforceable Through Title V Permit

42. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit

43. Operator shall submit a semiannual report listing any daily period during which the sulfur content of the fuel being fired in the gas turbine exceeds 0.8% by weight. [40 CFR 60.334(i)(3)(D)] Federally Enforceable Through Title V Permit

44. CEMS shall complete a minimum of one cycle of operation (sampling, analyzing, and data recording) for each 15-minute quadrant of the hour or shall meet equivalent specifications established by mutual agreement of the District, the ARB and the EPA. [40 CFR 60.334(b)(2); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

45. The owner or operator shall submit a written report of CEMS operations for each calendar quarter to the District. The report is due on the 30th day following the end of the calendar quarter and shall include the following: Time intervals, data and magnitude of excess NOx emissions, nature and the cause of excess (if known), corrective actions taken and preventive measures adopted; Averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; Applicable time and date of each period during which the CEM was inoperative, except for zero and span checks, and the nature of system repairs and adjustments; A negative declaration when no excess emissions occurred. [40 CFR 60.334(j)(5); 40 CFR 64; and District Rule 1080] Federally Enforceable Through Title V Permit

46. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [District Rule 1080, 9.0] Federally Enforceable Through Title V Permit

47. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [40 CFR 64 and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit

48. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

49. Formerly S-1109-374-15.

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1084-3 **EXPIRATION DATE:** 02/28/2017

SECTION: NE05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
83 BHP FORD MODEL CGS-649 4.9 LITER 6-CYLINDER NATURAL GAS-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.0] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 5.7] Federally Enforceable Through Title V Permit
3. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702, 3.15] Federally Enforceable Through Title V Permit
4. During or before periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702, 5.7] Federally Enforceable Through Title V Permit
5. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 100 hours per calendar year, as determined by an operational nonresettable elapsed operating time meter. [District Rule 4702, 3.15] Federally Enforceable Through Title V Permit
6. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702, 3.15] Federally Enforceable Through Title V Permit
7. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702, 5.7] Federally Enforceable Through Title V Permit
8. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 6.2] Federally Enforceable Through Title V Permit
9. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 6.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1085-8 **EXPIRATION DATE:** 02/28/2017

SECTION: 19 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
83.3 MMBTU/HR AIR-ASSISTED STANDBY FLARE WITH AUTOMATIC ELECTRONIC IGNITOR, NATURAL GAS AUXILIARY FUEL, AND NATURAL GAS OR PROPANE PILOT ASSEMBLY (RAMBLER LEASE)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modifications, except for changes specified in the conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. This unit may be designated as a dormant emissions unit or an active emissions unit. Permittee shall notify the District's Compliance Division in writing (US Mail, Fax or Email) within 7 days after re-designating this unit as a dormant or active emissions unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing and monitoring shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing and monitoring shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
8. Flare shall only operate when steam generators S-1131-999, S-1131-065, S-1131-066 and S-1131-067 are not operating. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Thermally Enhanced Oil Recovery (TEOR)/ vapor control gas, natural gas, pilot gas, and purge gas lines to flare shall be equipped with volumetric flow rate indicator. [District Rules 2201; and 4311, 5.10, 6.7] Federally Enforceable Through Title V Permit
10. A flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit
11. Flare shall be equipped with a natural gas or propane fired pilot and an automatic re-ignition system. [District Rules 2201; and 4311, 5.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. Flare shall be equipped with a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an equivalent device capable of continuously detecting at least one pilot flame or the flare flame is present. The flame detection device shall be kept operational at all times except during flare maintenance when the flare is isolated from gas flow. During essential planned power outages when the flare is operating, the pilot monitor is allowed to be non-functional if the flare flame is clearly visible to onsite operators. Effective on and after July 1, 2012, all pilot monitor downtime shall be reported annually pursuant to Rule 4311, section 6.2.3.6. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit
13. Only PUC quality natural gas or propane shall be used as pilot fuel. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Only PUC-quality gas with sulfur content less than or equal to 1 grain sulfur per 100 scf of gas shall be used to supplement gas to the flare. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum volume of gas incinerated in this flare shall not exceed the following: 500,000 scf/day vapor recovery gas and 302,160 scf/day PUC quality natural gas (includes 2,160 scf/day natural gas pilot fuel). [District Rule 2201] Federally Enforceable Through Title V Permit
16. The vapor recovery gas sulfur compound concentration shall not exceed 600 ppmv (35.4 grains S/100scf). [District Rule 2201] Federally Enforceable Through Title V Permit
17. Emission rates shall not exceed any of the following in lb/MMBtu: PM10 - 0.026, NOx (as NO2) - 0.068, VOC - 0.063, and CO - 0.370. [District Rule 2201] Federally Enforceable Through Title V Permit
18. If the flare uses a flow-sensing automatic ignition system and does not use a continuous flame pilot, the flare shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit
19. Open flares in which the flare gas pressure is less than 5 psig shall be operated in such a manner that meets the provisions of 40 CFR 60.18. [District Rule 4311, 5.6] Federally Enforceable Through Title V Permit
20. Operator shall monitor vent gas composition using one of the five following methods: 1) Sampling vent gas pursuant to Rule 4311 Section 6.6.1, 2) Integrated sampling pursuant to Rule 4311 Section 6.6.2, 3) Operate continuous analyzers that meet the requirements of Rule 4311 Section 6.6.3, 4) Operate continuous analyzers employing gas chromatography pursuant to Rule 4311 Section 6.6.4, or 5) Monitor sulfur content using a colorimetric tube system, and monitor vent gas hydrocarbons pursuant to Rule 4311 Section 6.6.5. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit
21. Operator shall monitor the volumetric flows of purge and pilot gases. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit
22. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. The operator shall provide the APCO with access to the monitoring system to collect vent gas samples to verify the analysis required by Rule 4311 Section 5.11. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit
23. Operator shall report periods of monitor inoperation greater than 24 continuous hours by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit
24. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Rule 4311 Section 6.3.4. During periods of inoperation of flow monitors, flow shall be calculated using good engineering practices. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

25. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

26. All in-line continuous analyzer and flow monitoring data must be continuously recorded by an electronic data acquisition system capable of one-minute averages. Flow monitoring data shall be recorded as one-minute averages. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

27. Permit holder shall document compliance with vapor recovery gas sulfur concentration limit on a monthly basis by sample collection and independent laboratory analysis using ASTM method 3246. [District Rule 1081] Federally Enforceable Through Title V Permit

28. The operator shall notify the District of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, whichever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

29. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that summarizes all reportable flaring events during the previous 12-month period. The report shall include the following: 1) The results of an investigation to determine the primary cause and contributing factors of the flaring event; 2) Any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; 3) If appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and 4) The date, time, and duration of the flaring event. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

30. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that includes the following: 1) The total volumetric flow of vent gas in standard cubic feet for each day; 2) Hydrogen sulfide content, methane content, and hydrocarbon content of vent gas composition pursuant to Section 6.6; 3) If vent gas composition is monitored by a continuous analyzer or analyzers pursuant to Section 5.11, average total hydrocarbon content by volume, average methane content by volume, and depending upon the analytical method used pursuant to Section 6.3.4, total reduced sulfur content by volume or hydrogen sulfide content by volume of vent gas flared for each hour of the month; 4) If the flow monitor used pursuant to Section 5.10 measures molecular weight, the average molecular weight for each hour of each month; 5) For any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month, and the means used to determine flow; 6) Flare monitoring system downtime periods, including dates and times; 7) For each day and for each month provide calculated sulfur dioxide emissions; and 8) A flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing pursuant to Section 6.3.5. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

31. Vent gas composition shall be monitored using one of the methods outlined in Rule 4311, Section 6.6.1 through 6.6.5. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. [District Rule 4311, 6.6] Federally Enforceable Through Title V Permit

32. Periods of flare monitoring system inoperation greater than 24 continuous hours shall be reported by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

33. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Section 6.3.4. During periods of inoperation of flow monitors required by Section 5.10, flow shall be calculated using good engineering practices. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

34. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device in question. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

35. The permittee shall keep accurate daily records of volume, type, & location of gas flared and operational status of steam generators S-1131-999, S-1131-065, S-1131-066 and S-1131-067, for a period of five years, and shall make such records available for District inspection upon request. [District Rules 1070; 2520, 9.4.2; and 4311, 6.1] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1086-3 **EXPIRATION DATE:** 02/28/2017

SECTION: SW34 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
83.3 MMBTU/HR AIR-ASSISTED STANDBY FLARE WITH AUTOMATIC ELECTRONIC IGNITOR, AND NATURAL GAS OR PROPANE PILOT ASSEMBLY, OPERATED AT VARIOUS UNSPECIFIED LOCATIONS WITHIN THE KERN RIVER OIL FIELD

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modifications, except for changes specified in the conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. This unit may be designated as a dormant emissions unit or an active emissions unit. Permittee shall notify the District's Compliance Division in writing (US Mail, Fax or Email) within 7 days after re-designating this unit as a dormant or active emissions unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing and monitoring shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing and monitoring shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
8. This flare shall not operate within 1,000 feet of any K-12 school. [District Rule 4102]
9. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made in writing no later than 48 hours after starting operation at the location. [District Rule 1070]
10. Flare shall only operate when steam generators S-1131-064, S-1131-998 and S-1131-1003 are not operating. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Thermally Enhanced Oil Recovery (TEOR)/ vapor control gas, natural gas, pilot gas, and purge gas lines to flare shall be equipped with volumetric flow rate indicator. [District Rules 2201; and 4311, 5.10, 6.7] Federally Enforceable Through Title V Permit
12. A flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Flare shall be equipped with a natural gas or propane fired pilot and an automatic re-ignition system. [District Rules 2201; and 4311, 5.3] Federally Enforceable Through Title V Permit

14. Flare shall be equipped with a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an equivalent device capable of continuously detecting at least one pilot flame or the flare flame is present. The flame detection device shall be kept operational at all times except during flare maintenance when the flare is isolated from gas flow. During essential planned power outages when the flare is operating, the pilot monitor is allowed to be non-functional if the flare flame is clearly visible to onsite operators. Effective on and after July 1, 2012, all pilot monitor downtime shall be reported annually pursuant to Rule 4311, section 6.2.3.6. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit

15. Only PUC quality natural gas or propane shall be used as pilot fuel. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit

16. Maximum volume of gas incinerated in this flare shall not exceed the following: 210,000 scf/day TEOR/ vapor control gas and 202,160 scf/day PUC quality natural gas (includes 2,160 scf/day pilot fuel). [District Rule 2201] Federally Enforceable Through Title V Permit

17. Sulfur compound concentration (as H2S) of TEOR/ vapor control gas shall not exceed 360 ppmv. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit

18. Emission rates shall not exceed any of the following in lb/MMBtu: PM10 - 0.0202, NOx (as NO2) - 0.068, VOC - 0.006, and CO - 0.370. [District Rule 2201] Federally Enforceable Through Title V Permit

19. If the flare uses a flow-sensing automatic ignition system and does not use a continuous flame pilot, the flare shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit

20. Open flares in which the flare gas pressure is less than 5 psig shall be operated in such a manner that meets the provisions of 40 CFR 60.18. [District Rule 4311, 5.6] Federally Enforceable Through Title V Permit

21. Operator shall monitor vent gas composition using one of the five following methods: 1) Sampling vent gas pursuant to Rule 4311 Section 6.6.1, 2) Integrated sampling pursuant to Rule 4311 Section 6.6.2, 3) Operate continuous analyzers that meet the requirements of Rule 4311 Section 6.6.3, 4) Operate continuous analyzers employing gas chromatography pursuant to Rule 4311 Section 6.6.4, or 5) Monitor sulfur content using a colorimetric tube system, and monitor vent gas hydrocarbons pursuant to Rule 4311 Section 6.6.5. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

22. Operator shall monitor the volumetric flows of purge and pilot gases. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

23. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. The operator shall provide the APCO with access to the monitoring system to collect vent gas samples to verify the analysis required by Rule 4311 Section 5.11. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

24. Operator shall report periods of monitor inoperation greater than 24 continuous hours by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

25. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Rule 4311 Section 6.3.4. During periods of inoperation of flow monitors, flow shall be calculated using good engineering practices. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

26. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

27. All in-line continuous analyzer and flow monitoring data must be continuously recorded by an electronic data acquisition system capable of one-minute averages. Flow monitoring data shall be recorded as one-minute averages. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

28. At least once per month, the permittee shall document compliance with TEOR/ vapor control gas sulfur concentration limit by sample collection and independent laboratory analysis using ASTM method 3246. [District Rule 1081] Federally Enforceable Through Title V Permit

29. Permittee shall maintain accurate daily records of type and volume of gas flared and H2S concentration. [District Rules 1070; and 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. The operator shall notify the District of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, whichever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

31. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that summarizes all reportable flaring events during the previous 12-month period. The report shall include the following: 1) The results of an investigation to determine the primary cause and contributing factors of the flaring event; 2) Any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; 3) If appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and 4) The date, time, and duration of the flaring event. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

32. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that includes the following: 1) The total volumetric flow of vent gas in standard cubic feet for each day; 2) Hydrogen sulfide content, methane content, and hydrocarbon content of vent gas composition pursuant to Section 6.6; 3) If vent gas composition is monitored by a continuous analyzer or analyzers pursuant to Section 5.11, average total hydrocarbon content by volume, average methane content by volume, and depending upon the analytical method used pursuant to Section 6.3.4, total reduced sulfur content by volume or hydrogen sulfide content by volume of vent gas flared for each hour of the month; 4) If the flow monitor used pursuant to Section 5.10 measures molecular weight, the average molecular weight for each hour of each month; 5) For any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month, and the means used to determine flow; 6) Flare monitoring system downtime periods, including dates and times; 7) For each day and for each month provide calculated sulfur dioxide emissions; and 8) A flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing pursuant to Section 6.3.5. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

33. Vent gas composition shall be monitored using one of the methods outlined in Rule 4311, Section 6.6.1 through 6.6.5. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. [District Rule 4311, 6.6] Federally Enforceable Through Title V Permit

34. Periods of flare monitoring system inoperation greater than 24 continuous hours shall be reported by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

35. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Section 6.3.4. During periods of inoperation of flow monitors required by Section 5.10, flow shall be calculated using good engineering practices. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

36. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device in question. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

37. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4311, 6.1] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1087-2 **EXPIRATION DATE:** 02/28/2017

SECTION: SW28 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
83.3 MMBTU/HR AIR-ASSISTED STANDBY FLARE WITH AUTOMATIC ELECTRONIC IGNITOR, AND NATURAL GAS OR PROPANE PILOT ASSEMBLY OPERATED AT VARIOUS SPECIFIED LOCATIONS WITHIN THE KERN RIVER OIL FIELD.

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modifications, except for changes specified in the conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. This unit may be designated as a dormant emissions unit or an active emissions unit. Permittee shall notify the District's Compliance Division in writing (US Mail, Fax or Email) within 7 days after re-designating this unit as a dormant or active emissions unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing and monitoring shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing and monitoring shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
8. Approved locations of operation are Sections 25, 28, 30, 31, 32, and 36 of T28S, R28W and Sec 5, 6, 7, and 8 of T29S, R28E. [District Rule 4102]
9. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made in writing no later than 48 hours after starting operation at the location. [District Rule 1070]
10. Flare shall only operate when steam generators S-1131-997 and S-1131-1016 are not operating. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Thermally Enhanced Oil Recovery (TEOR)/ vapor control gas, natural gas, pilot gas, and purge gas lines to flare shall be equipped with volumetric flow rate indicator. [District Rules 2201; and 4311, 5.10, 6.7] Federally Enforceable Through Title V Permit
12. A flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. Flare shall be equipped with a natural gas or propane fired pilot and an automatic re-ignition system. [District Rules 2201; and 4311, 5.3] Federally Enforceable Through Title V Permit

14. Flare shall be equipped with a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an equivalent device capable of continuously detecting at least one pilot flame or the flare flame is present. The flame detection device shall be kept operational at all times except during flare maintenance when the flare is isolated from gas flow. During essential planned power outages when the flare is operating, the pilot monitor is allowed to be non-functional if the flare flame is clearly visible to onsite operators. Effective on and after July 1, 2012, all pilot monitor downtime shall be reported annually pursuant to Rule 4311, section 6.2.3.6. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit

15. Only PUC quality natural gas or propane shall be used as pilot fuel. [District Rules 2201, 4102] Federally Enforceable Through Title V Permit

16. Maximum volume of gas incinerated in this flare shall not exceed the following: 200,000 scf/day vapor recovery gas and 37,160 scf/day PUC quality natural gas (includes 2,160 scf/day pilot fuel). [District Rule 2201] Federally Enforceable Through Title V Permit

17. Emission rates shall not exceed any of the following in lb/MMBtu: PM10 - 0.0202, NOx (as NO2) - 0.068, VOC - 0.004, and CO - 0.370. [District Rule 2201] Federally Enforceable Through Title V Permit

18. Sulfur compound concentration (as H2S) of vapor recovery gas shall not exceed 810 ppmv. [District Rule 2201] Federally Enforceable Through Title V Permit

19. If the flare uses a flow-sensing automatic ignition system and does not use a continuous flame pilot, the flare shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit

20. Open flares in which the flare gas pressure is less than 5 psig shall be operated in such a manner that meets the provisions of 40 CFR 60.18. [District Rule 4311, 5.6] Federally Enforceable Through Title V Permit

21. Operator shall monitor vent gas composition using one of the five following methods: 1) Sampling vent gas pursuant to Rule 4311 Section 6.6.1, 2) Integrated sampling pursuant to Rule 4311 Section 6.6.2, 3) Operate continuous analyzers that meet the requirements of Rule 4311 Section 6.6.3, 4) Operate continuous analyzers employing gas chromatography pursuant to Rule 4311 Section 6.6.4, or 5) Monitor sulfur content using a colorimetric tube system, and monitor vent gas hydrocarbons pursuant to Rule 4311 Section 6.6.5. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

22. Operator shall monitor the volumetric flows of purge and pilot gases. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

23. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. The operator shall provide the APCO with access to the monitoring system to collect vent gas samples to verify the analysis required by Rule 4311 Section 5.11. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

24. Operator shall report periods of monitor inoperation greater than 24 continuous hours by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

25. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Rule 4311 Section 6.3.4. During periods of inoperation of flow monitors, flow shall be calculated using good engineering practices. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

26. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

27. All in-line continuous analyzer and flow monitoring data must be continuously recorded by an electronic data acquisition system capable of one-minute averages. Flow monitoring data shall be recorded as one-minute averages. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

28. At least once per month, the permittee shall document compliance with TEOR/ vapor control gas sulfur concentration limit by sample collection and independent laboratory analysis using ASTM method 3246. [District Rule 1081] Federally Enforceable Through Title V Permit

29. The results of sample analysis, conducted for startup, shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

30. Permittee shall maintain accurate daily records of type and volume of gas flared and H2S concentration. [District Rules 1070 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

31. The operator shall notify the District of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, whichever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

32. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that summarizes all reportable flaring events during the previous 12-month period. The report shall include the following: 1) The results of an investigation to determine the primary cause and contributing factors of the flaring event; 2) Any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; 3) If appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and 4) The date, time, and duration of the flaring event. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

33. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that includes the following: 1) The total volumetric flow of vent gas in standard cubic feet for each day; 2) Hydrogen sulfide content, methane content, and hydrocarbon content of vent gas composition pursuant to Section 6.6; 3) If vent gas composition is monitored by a continuous analyzer or analyzers pursuant to Section 5.11, average total hydrocarbon content by volume, average methane content by volume, and depending upon the analytical method used pursuant to Section 6.3.4, total reduced sulfur content by volume or hydrogen sulfide content by volume of vent gas flared for each hour of the month; 4) If the flow monitor used pursuant to Section 5.10 measures molecular weight, the average molecular weight for each hour of each month; 5) For any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month, and the means used to determine flow; 6) Flare monitoring system downtime periods, including dates and times; 7) For each day and for each month provide calculated sulfur dioxide emissions; and 8) A flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing pursuant to Section 6.3.5. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

34. Vent gas composition shall be monitored using one of the methods outlined in Rule 4311, Section 6.6.1 through 6.6.5. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. [District Rule 4311, 6.6] Federally Enforceable Through Title V Permit

35. Periods of flare monitoring system inoperation greater than 24 continuous hours shall be reported by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Section 6.3.4. During periods of inoperation of flow monitors required by Section 5.10, flow shall be calculated using good engineering practices. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

37. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device in question. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

38. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4311, 6.1] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1091-3 **EXPIRATION DATE:** 02/28/2017

EQUIPMENT DESCRIPTION:
1,650 GALLON TRANSPORTABLE CHEMICAL STORAGE TANK

PERMIT UNIT REQUIREMENTS

1. The equipment shall not be operated within 1000 feet of any K-12 school. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 1.5 psia under all storage conditions. [District Rule 4623] Federally Enforceable Through Title V Permit
4. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. This tank shall be equipped with a pressure-vacuum (PV) relief valve set to within 10% of the maximum allowable working pressure of the tank, permanently labeled with the operating pressure settings, properly maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in gas-tight condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623] Federally Enforceable Through Title V Permit
12. This tank shall be in a gas-tight condition. A gas-tight condition is defined as a condition without a gas leak. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623. [District Rule 4623] Federally Enforceable Through Title V Permit
13. All piping, fittings, and valves on this tank shall be inspected annually by the facility operator in accordance with EPA Method 21, with the instrument calibrated with methane, to ensure compliance with the leaking provisions of this permit. [District Rule 4623] Federally Enforceable Through Title V Permit
14. Any component found to be leaking on two consecutive annual inspections is in violation of the District Rule 4623, even if it is under the voluntary inspection and maintenance program. [District Rule 4623] Federally Enforceable Through Title V Permit
15. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date and time of leak detection, and method of detection; 3) Date and time of leak repair, and emission level of recheck after leak is repaired; 4) Method used to minimize the leak to lowest possible level within 8 hours after detection. [District Rule 4623] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1097-9 **EXPIRATION DATE:** 02/28/2017

SECTION: NW05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
43,000 BBL FIXED ROOF CRUDE OIL SURGE TANK #8 SERVED BY VAPOR RECOVERY SYSTEM LISTED ON S-1131-598

PERMIT UNIT REQUIREMENTS

1. The overall efficiency of the tank vapor collection and control system shall be maintained at no less than 99%. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Tank shall be equipped with an operational and calibrated stored liquid temperature indicator. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
4. Fugitive VOC emission rate, calculated using the Oil and Gas Production Operations Average Emission Factors, U.S. EPA Protocol for Equipment Leak Emission Estimates, Table 2-4 (EPA-453/R-95-017) November 1995 from the total number of vapor components associated with tank and vapor control system shall not exceed 6.4 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Permittee shall maintain records of number and type of components in gas service installed. Permittee shall update such records when new gas handling components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Tank seams, welds, joints, piping, valves and fittings shall be inspected for gas leaks. [District Rule 2201] Federally Enforceable Through Title V Permit
7. A visible mist, liquid dripping at the rate of more than 3 drops per minute, and vapor leaks of 50,000 ppm or greater VOC as methane shall be repaired as expeditiously as possible but in no case beyond 24 hours after detection of the leak and shall be re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 10,000 ppm and less than 50,000 ppm VOC as methane shall be repaired within 5 days of detecting the leak and re-monitored using EPA Method 21 upon completion of the repair. Vapor leaks equal to or greater than 1,000 ppm and less than 10,000 ppm VOC as methane shall be repaired within 14 days of leak detection and shall be re-monitored using EPA Method 21 upon completion of the repair. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. All piping, fittings, valves, and tank gauging or sampling devices shall be inspected annually by the facility operator to ensure compliance with the provisions of this permit. However, if two (2) percent or more of the components of any type subject to the requirements of this permit are found to leak during an annual inspection, the inspection frequency for that component type shall be changed from annual to quarterly. If less than two percent of the components of that type are subsequently found to be leaking during five consecutive inspections, the inspection frequency may be changed from quarterly to annual. Components located in inaccessible (over 15 feet above ground when access is required from the ground or over 6 feet away from a platform when access is required from the platform) locations shall be inspected at least annually and components located in unsafe areas shall be inspected and repaired at the next process unit turnaround (the scheduled shutdown of a unit for maintenance and repair work). [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

9. Operator shall determine the presence of VOC leaks by EPA Method 21. The instrument shall be calibrated before use each day of its use by the procedures specified in Method 21 using the following calibration gases; 1.) Zero air (less than 10 ppm of hydrocarbon in air); and 2.) A mixture of methane or n-hexane and air at a concentration of about, but less than, 10,000 ppm methane or n-hexane [40 CFR 60.112b(a)(3)(i)] Federally Enforceable Through Title V Permit

10. A facility operator, upon detection of a leaking component, shall affix to that component a weatherproof readily visible tag bearing the date on which the leak is detected. The tag shall remain in place until the leaking component is repaired, reinspected, and found to be in compliance with the requirements of this permit. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. Operator shall maintain an inspection log containing the following 1) Type of component leaking; 2) Date of leak detection, and method of detection; 3) Date and emission level of recheck after leak is repaired; 4) Identification and location of essential parts of critical process units found leaking that cannot be repaired until the next process unit turnaround; and 5) Method used to minimize the leak from essential parts of critical process units which cannot be repaired until the next process unit turnaround. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

12. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1 of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit

13. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

14. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

15. True Vapor Pressure (TVP) of any organic liquid, except for crude oil with an API gravity of 20 degrees or less, shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323, and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in Appendix B. Appendix B is an excerpt from the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit

16. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

17. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
18. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
19. Operator shall maintain a record showing the dimension of the storage vessel and an analysis showing the capacity of the storage vessel. [40 CFR 60.116b(b)] Federally Enforceable Through Title V Permit
20. The operator shall ensure that the vapor recovery system is functional and is operating as designed at all times. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
21. Compliance with permit conditions in the Title V permit shall be deemed compliance with 40 CFR 60 Subpart Kb (except 60.113b(c)). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
22. Permittee shall conduct tank cleaning and maintenance operations in accordance with District approved procedure as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
23. Tank may be disconnected from vapor control system during District approved cleaning and maintenance procedures as described in this permit. [District Rule 2010] Federally Enforceable Through Title V Permit
24. Permittee shall notify the District Compliance division at least 48 hours before tank cleaning and vapor control system disconnection and within 72 hours after restoring crude oil flow to the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
25. Permittee shall maintain records of each period of cleaning and maintenance when the tank is disconnected or isolated from the vapor control system. Records shall include the date that tank cleaning was initiated, the date tank cleaning was completed, the method of tank cleaning used, and a description of internal and external tank repairs and maintenance performed. Such records shall be retained for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 2010] Federally Enforceable Through Title V Permit
26. Prior to taking the vapor control systems off-line, the water removal rate shall be controlled to maximize the fluid level in the tank and minimize the thickness of the oil pad. The liquid level shall be raised to displace at least 90% of the tank liquid capacity using water. The inflow of crude oil and water shall be stopped and the vapor control system shall continue to operate for at least 24 hours prior to opening the tank. [District Rule 2010] Federally Enforceable Through Title V Permit
27. After the inflow of crude oil and water has stopped and the vapor control system has operated for at least 24 hours, the tank shall be isolated or disconnected from the vapor control system, the tank drain shall be opened, the pressure-vacuum relief valve shall be opened or bypassed, and the tank shall be drained. [District Rule 2010] Federally Enforceable Through Title V Permit
28. The tank shall be cleaned using water, hot water, solvents with an initial boiling point of greater than 302 F, solvents with a vapor pressure of less than 0.5 psia, or solvents with 50 grams VOC per liter or less. The tank sediment shall be used for road mix as allowed by Section 6.17 of District Rule 2020. [District Rule 2010] Federally Enforceable Through Title V Permit
29. Steam Cleaning shall be allowed only during December through March, or at locations where wastewater treatment facilities are limited. [District Rule 2010] Federally Enforceable Through Title V Permit
30. Prior to reintroducing crude oil/water to the tank, the tank shall be filled to the maximum possible level with water, the tank vapor control system shall be reactivated and pressure/relief valves closed, and the liquid level shall be adjusted as necessary. [District Rule 2010] Federally Enforceable Through Title V Permit
31. Within 48 hours after refilling the tank, the pressure relief valve seats and hatch seals shall be inspected for leaks using EPA method 21 and the regular tank maintenance and inspection program shall resume. [District Rule 2010] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1106-18 **EXPIRATION DATE:** 02/28/2017

SECTION: 25/36 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:
TEOR OPERATION CONSISTING OF 140 STEAM-ENHANCED CRUDE OIL PRODUCTION WELLS WITH VAPOR CONTROL SYSTEM INCLUDING ELECTRIC COMPRESSOR(S) AND HIGH POINT SEPARATOR(S) CONNECTED TO STATION 36 PRODUCTION LINE (S-1131-598), FLARE S-1131-1086, FLARE S-1131-1087 OR FLARE S-1131-1108

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. Operator shall maintain all components of a well vent vapor collection and control system in good repair. Components of the well vent vapor collection and control system shall include all piping, valves, fittings, pumps, compressors, tanks, etc. used to collect, control, store, or dispose of VOC condensate or non-condensable VOCs prior to blending of VOC condensate with crude oil or blending of non-condensable VOCs with gases to be used as a fuel. [District Rule 4401, 5.3 and 5.3.2] Federally Enforceable Through Title V Permit
3. Except for fluids from the well casing, fluids produced from these steam-enhanced wells shall be introduced only to tanks vented to a District approved vapor collection and control system, or to permit exempt storage equipment as defined by Rule 2020, Section 6.6. [District Rule 2201] Federally Enforceable Through Title V Permit
4. The well casing vents shall either be (1) connected to the well casing vapor collection system that serves this permit unit; (2) connected to the Station 36 production pipeline; (3) connected to the Station 36 tank vapor control system listed on S-1131-598; or (4) connected to flare S-1131-1086, flare S-1131-1087 or flare S-1131-1108. [District Rule 2201] Federally Enforceable Through Title V Permit
5. High point separators shall vent only to flares S-1131-1086, '-1087, and '-1108 and/or to tank vapor control system S-1131-598. [District Rule 2201] Federally Enforceable Through Title V Permit
6. Permittee shall maintain a map of the high point separators and it shall be kept at the facility, updated annually, and made readily available to the District upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
7. The crude oil production from wells associated with this permit unit shall not lie within 1,000 feet of an air injection well used for in-situ combustion. [District Rule 4407, 2.0, 3.4, and 3.5] Federally Enforceable Through Title V Permit
8. The VOC content of the casing gas shall not exceed 10% by weight. [District Rule 2201] Federally Enforceable Through Title V Permit
9. Operator shall conduct quarterly sampling of the well casing gas. If the gas sampled is 10% or less VOC by weight for eight consecutive quarterly samplings, the sampling frequency shall only be required annually. If a test shows noncompliance with the percent VOC requirement, the source must return to quarterly testing until eight consecutive quarters show compliance. [District Rule 2201] Federally Enforceable Through Title V Permit
10. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401, 4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. The inspection requirements of Section 5.4.1 through Section 5.4.7 of Rule 4401 shall not apply to components exclusively handling gas/vapor or liquid with a VOC content of ten percent by weight (10%) or less, as determined by the test methods in Section 6.3.4 of Rule 4401. [District Rule 4401, 4.7] Federally Enforceable Through Title V Permit

12. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401, 3.20] Federally Enforceable Through Title V Permit

13. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 5.1 and 5.1] Federally Enforceable Through Title V Permit

14. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit

15. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401, 5.2] Federally Enforceable Through Title V Permit

16. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit

17. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit

18. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401, 5.3] Federally Enforceable Through Title V Permit

19. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit

20. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
22. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
23. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
24. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401, 5.4] Federally Enforceable Through Title V Permit
25. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
26. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401 5.5] Federally Enforceable Through Title V Permit
27. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
28. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
29. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
30. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit
31. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401, 5.5] Federally Enforceable Through Title V Permit

33. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

34. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

35. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

36. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

37. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401 6.1] Federally Enforceable Through Title V Permit

38. The results of gauge tank TVP testing conducted pursuant to Section 6.2.3 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

39. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

40. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. A process system as defined in Section 3.30 of Rule 4401 is not subject to compliance source testing requirements. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

41. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection are controlled by an internal combustion engine subject to Rule 4702, a combustion device subject to Rule 4320, 4307 or 4308, a flare subject to Rule 4311. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

42. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.0 of Rule 4401: Conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.9 of Rule 4401. [District Rule 4401, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

43. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

44. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

45. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

46. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401, 6.3] Federally Enforceable Through Title V Permit

47. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401, 6.4] Federally Enforceable Through Title V Permit

48. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401, 6.1 and 6.5] Federally Enforceable Through Title V Permit

49. Operator shall keep a list of all gauge tanks, as defined in Section 3.0 of Rule 4401. The list shall contain the size, identification number, the location of each gauge tank and specify whether the gauge tank is upstream of all front line production equipment. [District Rule 4401, 6.1 and 6.6] Federally Enforceable Through Title V Permit

50. By January 30 of each year, an operator shall submit to the APCO for approval, in writing, an annual report indicating any changes to an existing Operator Management Plan. [District Rule 4401, 6.7] Federally Enforceable Through Title V Permit

51. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4401, 6.1] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1108-2 **EXPIRATION DATE:** 02/28/2017

EQUIPMENT DESCRIPTION:
83.0 MMBTU/HR AIR ASSISTED LOW USE FLARE WITH AUTOMATIC IGNITION AND NATURAL GAS PILOT ASSEMBLY OPERATED AT MULTIPLE SPECIFIED LOCATIONS WITHIN CHEVRON USA'S HEAVY OIL CENTRAL STATIONARY SOURCE

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modifications, except for changes specified in the conditions below. [District Rule 2010] Federally Enforceable Through Title V Permit
2. This unit may be designated as a dormant emissions unit or an active emissions unit. Permittee shall notify the District's Compliance Division in writing (US Mail, Fax or Email) within 7 days after re-designating this unit as a dormant or active emissions unit. [District Rule 2080] Federally Enforceable Through Title V Permit
3. While dormant, the fuel line shall be physically disconnected from the unit. [District Rule 2080] Federally Enforceable Through Title V Permit
4. While dormant, normal source testing and monitoring shall not be required. [District Rule 2080] Federally Enforceable Through Title V Permit
5. Upon recommencing operation of this unit, normal source testing and monitoring shall resume. [District Rule 2080] Federally Enforceable Through Title V Permit
6. Any source testing required by this permit shall be performed within 60 days of recommencing operation of this unit, regardless of whether the unit remains active or is again designated as dormant. [District Rule 2080] Federally Enforceable Through Title V Permit
7. Records of all dates and times that this unit is designated as dormant or active, and copies of all corresponding notices to the District, shall be maintained, retained for a period of at least five years, and made available for District inspection upon request. [District Rule 1070]
8. Flare is authorized to operate only at Sections 25, 30, 31, 32, and 36 in T28S/R28E and Sections 5, 6, 7, and 8 in T29S/R28E. [District Rule 2201] Federally Enforceable Through Title V Permit
9. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made in writing no later than 48 hours after starting operation at the location. [District Rule 1070]
10. Thermally Enhanced Oil Recovery (TEOR)/ vapor control gas, natural gas, pilot gas, and purge gas lines to flare shall be equipped with volumetric flow rate indicator. [District Rules 2201; and 4311, 5.10, 6.7] Federally Enforceable Through Title V Permit
11. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark or darker than Ringelmann 1/4 or 5% opacity. [District Rule 2201] Federally Enforceable Through Title V Permit
12. The Thermally Enhanced Oil Recovery (TEOR)/vapor control gas line to the flare shall be equipped with a non-resettable totalizing volumetric flow meter. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. A flame shall be present at all times when combustible gases are vented through the flare. [District Rule 4311, 5.2] Federally Enforceable Through Title V Permit

14. Flare shall be equipped with a natural gas-fired pilot and an automatic re-ignition system. [District Rules 2201; and 4311, 5.3] Federally Enforceable Through Title V Permit

15. Flare shall be equipped with a heat sensing device such as a thermocouple, ultraviolet beam sensor, infrared sensor, or an equivalent device capable of continuously detecting at least one pilot flame or the flare flame is present. The flame detection device shall be kept operational at all times except during flare maintenance when the flare is isolated from gas flow. During essential planned power outages when the flare is operating, the pilot monitor is allowed to be non-functional if the flare flame is clearly visible to onsite operators. Effective on and after July 1, 2012, all pilot monitor downtime shall be reported annually pursuant to Rule 4311, section 6.2.3.6. [District Rule 4311, 5.4] Federally Enforceable Through Title V Permit

16. Only PUC quality natural gas shall be used as pilot fuel. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit

17. Maximum amount of flared gas and pilot gas combusted shall not exceed 199.177 MMBtu/day nor 53,943.8 MMBtu/yr. [District Rule 2201] Federally Enforceable Through Title V Permit

18. Emissions from the flare shall not exceed any of the following limits (based on total gas combusted): NOx (as NO2): 0.068 lb/MMBtu; PM10: 0.008 lb/MMBtu; CO: 0.37 lb/MMBtu; or VOC: 0.063 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

19. Sulfur content of flared gas and pilot gas shall not exceed 1.0 gr/100scf. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit

20. If the flare uses a flow-sensing automatic ignition system and does not use a continuous flame pilot, the flare shall use purge gas for purging. [District Rule 4311, 5.5] Federally Enforceable Through Title V Permit

21. Open flares in which the flare gas pressure is less than 5 psig shall be operated in such a manner that meets the provisions of 40 CFR 60.18. [District Rule 4311, 5.6] Federally Enforceable Through Title V Permit

22. Operator shall monitor vent gas composition using one of the five following methods: 1) Sampling vent gas pursuant to Rule 4311 Section 6.6.1, 2) Integrated sampling pursuant to Rule 4311 Section 6.6.2, 3) Operate continuous analyzers that meet the requirements of Rule 4311 Section 6.6.3, 4) Operate continuous analyzers employing gas chromatography pursuant to Rule 4311 Section 6.6.4, or 5) Monitor sulfur content using a colorimetric tube system, and monitor vent gas hydrocarbons pursuant to Rule 4311 Section 6.6.5. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

23. Operator shall monitor the volumetric flows of purge and pilot gases. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

24. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. The operator shall provide the APCO with access to the monitoring system to collect vent gas samples to verify the analysis required by Rule 4311 Section 5.11. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

25. Operator shall report periods of monitor inoperation greater than 24 continuous hours by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

26. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Rule 4311 Section 6.3.4. During periods of inoperation of flow monitors, flow shall be calculated using good engineering practices. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

27. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

28. All in-line continuous analyzer and flow monitoring data must be continuously recorded by an electronic data acquisition system capable of one-minute averages. Flow monitoring data shall be recorded as one-minute averages. [District Rule 4311, 5.11, 6.9] Federally Enforceable Through Title V Permit

29. Measured heating value and quantity of flared gas shall be used to determine compliance with heat input limits. [District Rule 2201] Federally Enforceable Through Title V Permit

30. Flared gas and pilot gas shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a flared gas and pilot gas, then the testing frequency shall be quarterly. If a quarterly testing fails to show compliance, weekly testing shall resume. [District Rule 1070]

31. Sulfur content of flared gas and pilot gas shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD, double GC for H2S and mercaptans, performed in the laboratory. Should the applicant decided to use different methodology, the methodology must be approved by the District prior to its use. [District Rule 1070]

32. Higher heating value of flared gas and pilot gas shall be determined using ASTM D 1826 or D 1945 in conjunction with ASTM D 3588. [District Rule 1070]

33. The flare shall be operated according to the manufacturer's specifications, a copy of which shall be maintained on site. [District Rule 2201] Federally Enforceable Through Title V Permit

34. Permittee shall maintain accurate records of types of pilot gas and flared gas, sulfur contents of flared gas and pilot gas, higher heating values of flared and pilot gas, and daily and annual quantities of flared gas and pilot gas combusted in the flare. [District Rule 2201] Federally Enforceable Through Title V Permit

35. The operator shall notify the District of an unplanned flaring event within 24 hours after the start of the next business day or within 24 hours of their discovery, whichever occurs first. The notification shall include the flare source identification, the start date and time, and the end date and time. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

36. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that summarizes all reportable flaring events during the previous 12-month period. The report shall include the following: 1) The results of an investigation to determine the primary cause and contributing factors of the flaring event; 2) Any prevention measures considered or implemented to prevent recurrence together with a justification for rejecting any measures that were considered but not implemented; 3) If appropriate, an explanation of why the flaring was an emergency and necessary to prevent accident, hazard or release of vent gas to the atmosphere, or where, due to a regulatory mandate to vent a flare, it cannot be recovered, treated and used as a fuel gas at the facility; and 4) The date, time, and duration of the flaring event. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

37. Effective on and after July 1, 2012, and annually thereafter, an operator shall submit a report to the District within 30 days following the end of each 12-month period that includes the following: 1) The total volumetric flow of vent gas in standard cubic feet for each day; 2) Hydrogen sulfide content, methane content, and hydrocarbon content of vent gas composition pursuant to Section 6.6; 3) If vent gas composition is monitored by a continuous analyzer or analyzers pursuant to Section 5.11, average total hydrocarbon content by volume, average methane content by volume, and depending upon the analytical method used pursuant to Section 6.3.4, total reduced sulfur content by volume or hydrogen sulfide content by volume of vent gas flared for each hour of the month; 4) If the flow monitor used pursuant to Section 5.10 measures molecular weight, the average molecular weight for each hour of each month; 5) For any pilot and purge gas used, the type of gas used, the volumetric flow for each day and for each month, and the means used to determine flow; 6) Flare monitoring system downtime periods, including dates and times; 7) For each day and for each month provide calculated sulfur dioxide emissions; and 8) A flow verification report for each flare subject to this rule. The flow verification report shall include flow verification testing pursuant to Section 6.3.5. [District Rule 4311, 6.2] Federally Enforceable Through Title V Permit

38. Vent gas composition shall be monitored using one of the methods outlined in Rule 4311, Section 6.6.1 through 6.6.5. If flares share a common header, a sample from the header will be deemed representative of vent gas composition for all flares served by the header. [District Rule 4311, 6.6] Federally Enforceable Through Title V Permit

39. Periods of flare monitoring system inoperation greater than 24 continuous hours shall be reported by the following working day, followed by notification of resumption of monitoring. Periods of inoperation of monitoring equipment shall not exceed 14 days per any 18-consecutive-month period. Periods of flare monitoring system inoperation do not include the periods when the system feeding the flare is not operating. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

40. During periods of inoperation of continuous analyzers or auto-samplers installed pursuant to Section 6.6, operators responsible for monitoring shall take one sample within 30 minutes of the commencement of flaring, from the flare header or from an alternate location at which samples are representative of vent gas composition and have samples analyzed pursuant to Section 6.3.4. During periods of inoperation of flow monitors required by Section 5.10, flow shall be calculated using good engineering practices. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

41. Operator shall maintain and calibrate all required monitors and recording devices in accordance with the applicable manufacturer's specifications. In order to claim that a manufacturer's specification is not applicable, the person responsible for emissions must have, and follow, a written maintenance policy that was developed for the device in question. The written policy must explain and justify the difference between the written procedure and the manufacturer's procedure. [District Rule 4311, 6.9] Federally Enforceable Through Title V Permit

42. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4311, 6.1] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1117-2 **EXPIRATION DATE:** 02/28/2017

EQUIPMENT DESCRIPTION:
480 HP CATERPILLAR MODEL C9 DIESEL-FIRED EMERGENCY IC ENGINE POWERING AN ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201, 3.0] Federally Enforceable Through Title V Permit
2. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 5.7; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
3. This engine shall be equipped with either a positive crankcase ventilation (PCV) system that recirculates crankcase emissions into the air intake system for combustion, or a crankcase emissions control device of at least 90% control efficiency. [District Rule 2201] Federally Enforceable Through Title V Permit
4. An emergency situation is an unscheduled electrical power outage caused by sudden and reasonably unforeseen natural disasters or sudden and reasonably unforeseen events beyond the control of the permittee. [District Rule 4702, 3.15] Federally Enforceable Through Title V Permit
5. During or before periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702, 5.7] Federally Enforceable Through Title V Permit
6. This engine shall be operated only for testing and maintenance of the engine, required regulatory purposes, and during emergency situations. Operation of the engine for maintenance, testing, and required regulatory purposes shall not exceed 50 hours per calendar year. [District Rule 4702, 3.15; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
7. This engine shall not be used to produce power for the electrical distribution system, as part of a voluntary utility demand reduction program, or for an interruptible power contract. [District Rule 4702, 3.15] Federally Enforceable Through Title V Permit
8. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
9. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201; 4801, 3.1; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
10. This engine shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702, 5.7; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

11. Emissions from this IC engine shall not exceed any of the following limits: 2.61 g-NOx/bhp-hr, 2.31 g-CO/bhp-hr, or 0.15 g-VOC/bhp-hr. [District Rule 2201; 13 CCR 2423; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
12. Emissions from this IC engine shall not exceed 0.11 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201; 4102; 13 CCR 2423; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
13. The permittee shall maintain monthly records of emergency and non-emergency operation. Records shall include the number of hours of emergency operation, the date and number of hours of all testing and maintenance operations, the purpose of the operation (for example: load testing, weekly testing, rolling blackout, general area power outage, etc.) and records of operational characteristics monitoring. For units with automated testing systems, the operator may, as an alternative to keeping records of actual operation for testing purposes, maintain a readily accessible written record of the automated testing schedule. [District Rule 4702, 6.2; and 17 CCR 93115] Federally Enforceable Through Title V Permit
14. The permittee shall maintain monthly records of the type of fuel purchased, the amount of fuel purchased, date when the fuel was purchased, signature of the permittee who received the fuel, and signature of the fuel supplier indicating that the fuel was delivered. [17 CCR 93115] Federally Enforceable Through Title V Permit
15. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 6.2; and 17 CCR 93115] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1119-5 **EXPIRATION DATE:** 02/28/2017

EQUIPMENT DESCRIPTION:
EPA-TIER 3 CERTIFIED DIESEL-FIRED TRANSPORTABLE IC ENGINE UPTO 532 HP POWERING MECHANICAL PUMP, COMPRESSOR, OR ELECTRICAL GENERATOR

PERMIT UNIT REQUIREMENTS

1. Permittee shall provide written notification to the District within 48 hours of operating an engine under this permit (if an engine is located onsite longer than 24 hours). Such notification shall include the date the unit was brought onsite, the manufacturer, model number, maximum rating, and emissions information that documents that the unit meets the emission limits and requirements specified in the permit. [District Rule 1070]
2. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
3. The exhaust stack of any IC engine utilized for this permit unit shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
4. Any IC engine utilized for this permit unit shall not be located within 1000 feet of any receptor or any K-12 school. [District Rule 4102; and CH&SC 42301.6]
5. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used in any IC engine utilized for this permit unit. [District Rules 2201; 4801, 3.1; 17 CCR 93116; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
6. Emissions from any IC engine utilized for this permit unit shall not exceed any of the following limits: 2.80 g-NOx/bhp-hr, 2.60 g-CO/bhp-hr, or 0.20 g-VOC/bhp-hr. [District Rule 2201; 17 CCR 93115; and 40 CFR Part 60 Subpart IIII] Federally Enforceable Through Title V Permit
7. Emissions from any IC engine utilized for this permit shall not exceed 0.15 g-PM10/bhp-hr based on USEPA certification using ISO 8178 test procedure. [District Rules 2201; 4102; 13 CCR 2423; 17 CCR 93116; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
8. Total operation of this permit unit shall not exceed 300 hours per year on a rolling month average. [District Rules 2201; and 4102] Federally Enforceable Through Title V Permit
9. Any IC engine utilized for this permit unit shall not be operated at any single location (as defined in Rule 4701) for more than 12 consecutive months. [District Rule 4701, 3.24; and 40 CFR Part 89] Federally Enforceable Through Title V Permit
10. Any IC engine utilized for this permit unit shall be operated in accordance with the requirements of the Code of Federal Regulations [District Rule 2201; and 40 CFR Part 89] Federally Enforceable Through Title V Permit
11. Any IC engine utilized for this permit unit shall be operated and maintained in proper operating condition as recommended by the engine manufacturer or emissions control system supplier. [District Rule 4702, 5.7; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

12. During or before periods of operation for maintenance, testing, and required regulatory purposes, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702, 5.7] Federally Enforceable Through Title V Permit
13. Any IC engine utilized for this permit unit shall be equipped with an operational non-resettable elapsed time meter or other APCO approved alternative. [District Rule 4702, 5.7; 17 CCR 93115; and 40 CFR 60 Subpart IIII] Federally Enforceable Through Title V Permit
14. The permittee shall maintain a permit unit operating log that shall include the following: a record of the cumulative annual hours of operation of the engine, the quantity of diesel fuel used, and a record of maintenance or modifications performed on any IC engine utilized for this permit unit. These records shall be updated on a monthly basis. [District Rule 4702, 6.2; and 17 CCR 93115] Federally Enforceable Through Title V Permit
15. The permittee shall maintain records of each location where the permit unit is operated, including dates and duration of residency at each location, and shall update those records each time any IC engine utilized for this permit unit is moved . [District Rule 2201; 40 CFR 89; and 17 CCR 93116] Federally Enforceable Through Title V Permit
16. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rule 4702, 6.2; and 17 CCR 93115] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1120-1 **EXPIRATION DATE:** 02/28/2017

SECTION: 5 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
1000 GALLON OIL TREATMENT CHEMICAL TANK

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 1.5 psia under all storage conditions. [District Rules 2201] Federally Enforceable Through Title V Permit
2. VOC emission rate from the tank shall not exceed 0.3 lb/day, [District Rule 2201] Federally Enforceable Through Title V Permit
3. The tank shall be equipped with a fixed roof with no holes or openings. [District Rule 2201] Federally Enforceable Through Title V Permit
4. Fluid throughput shall not exceed 55 gallons per day. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Permittee shall maintain daily records of fluid throughput and shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, and TVP. [District Rule 2201] Federally Enforceable Through Title V Permit
6. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1127-2 **EXPIRATION DATE:** 02/28/2017

SECTION: NE 18 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
THERMALLY ENHANCED OIL RECOVERY OPERATION (TEOR) SERVING UP TO 60 STEAM ENHANCED WELLS WITH WELL VENT COLLECTION AND CONTROL SYSTEM VENTED TO STATION 36 TVR SYSTEM S-1131-598 (MCWORTER LEASE)

PERMIT UNIT REQUIREMENTS

1. A current and complete listing of all steam enhanced wells connected to this system shall be maintained with the Permit to Operate. [District Rule 2201] Federally Enforceable Through Title V Permit
2. All steam enhanced wells shall be equipped with a vapor loss prevention system consisting of vapor and condensate collection systems with a control device capable of reducing VOC emissions by at least 99%. [District Rules 2201 and 4401] Federally Enforceable Through Title V Permit
3. An operator shall not operate a steam-enhanced crude oil production well unless the operator complies with either of the following requirements: The steam-enhanced crude oil production well vent is closed and the front line production equipment downstream of the wells that carry produced fluids (crude oil or mixture of crude oil and water) is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401, the well vent may be temporarily opened during periods of attended service or repair of the well provided such activity is done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere, or the steam-enhanced crude oil production well vent is open and the well vent is connected to a VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
4. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of an open-ended line or a valve located at the end of the line that is not sealed with a blind flange, plug, cap, or a second closed valve that is not closed at all times, except during attended operations as defined by Section 5.2.2.1 of Rule 4401 requiring process fluid flow through the open-ended lines, a component with a major liquid leak, or a component with a gas leak greater than 50,000 ppmv. [District Rule 4401] Federally Enforceable Through Title V Permit
5. An operator shall be in violation of this rule if any District inspection demonstrates or if any operator inspection conducted pursuant to Section 5.4 of Rule 4401 demonstrates the existence of any combination of components with minor liquid leaks, minor gas leaks, or a gas leaks greater than 10,000 ppmv up to 50,000 ppmv that totals more than number of leaks allowed by Table 2 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
6. An operator shall not use any component with a leak as defined in Section 3.0 of Rule 4401, or that is found to be in violation of the provisions of Section 5.2.2 of Rule 4401. However, components that were found leaking may be used provided such leaking components have been identified with a tag for repair, are repaired, or awaiting re-inspection after being repaired within the applicable time frame specified in Section 5.5 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
7. Each hatch shall be closed at all times except during sampling or adding of process material through the hatch, or during attended repair, replacement, or maintenance operations, provided such activities are done as expeditiously as possible with minimal spillage of material and VOC emissions to the atmosphere. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. An operator shall comply with the requirements of Section 6.7 of Rule 4401 if there is any change in the description of major components or critical components. [District Rule 4401] Federally Enforceable Through Title V Permit
9. Fugitive VOC emissions from components in vapor and condensate service shall not exceed 2.5 lb/day [District Rule 2201] Federally Enforceable Through Title V Permit
10. VOC content of gas shall be determined by ASTM D1945, EPA Method 18 referenced as methane, or equivalent test method with prior District approval. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Permittee shall determine sulfur content of scrubbed TEOR gas weekly for eight consecutive weeks. After demonstrating compliance for eight consecutive weeks testing may be conducted on a quarterly basis. Weekly sulfur testing shall resume if quarterly testing does not indicate compliance. Weekly gas analysis shall be performed using Draeger tubes and quarterly analysis using ASTM method D3246 or double GC for H2S and mercaptans. First of the weekly gas analyses shall be done using laboratory analysis. [District Rules 1081 and 2201] Federally Enforceable Through Title V Permit
12. There shall be no leaks in excess of 10,000 ppmv from components in vapor service when measured with a portable hydrocarbon detection instrument calibrated with methane in accordance with EPA Method 21. [District Rule 2201] Federally Enforceable Through Title V Permit
13. During the time any steam-enhanced crude oil production well is undergoing service or repair while the well is not producing, it shall be exempt from the emission control requirements of District Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
14. Permittee shall inspect all components service quarterly for leaks with a portable hydrocarbon detection instrument to ensure compliance with the provisions of this permit. [District Rule 2201 and 4401] Federally Enforceable Through Title V Permit
15. The inspection requirements of Section 5.4.1 through Section 5.4.7 of Rule 4401 shall not apply to components exclusively handling gas/vapor or liquid with a VOC content of ten percent by weight (10%) or less, as determined by the test methods in Section 6.3.4 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
16. Gas and liquid leaks are as defined in Section 3.20 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
17. Except for pipes and unsafe-to-monitor components, an operator shall inspect all other components pursuant to the requirements of Section 6.3.3 of Rule 4401 at least once every year. [District Rule 4401] Federally Enforceable Through Title V Permit
18. An operator shall visually inspect all pipes at least once every year. Any visual inspection of pipes that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected within 24 hours after detecting the leak. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
19. In addition to the inspections required by Section 5.4.1 of Rule 4401, an operator shall inspect for leaks all accessible operating pumps, compressors, and PRDs in service as follows: An operator shall audio-visually (by hearing and by sight) inspect for leaks all accessible operating pumps, compressors, and PRDs in service at least once each calendar week. Any audio-visual inspection of an accessible operating pump, compressor, and PRD performed by an operator that indicates a leak that cannot be immediately repaired to meet the leak standards of this rule shall be inspected not later than 24 hours after conducting the audio-visual inspection. If a leak is found, the leak shall be repaired as soon as practicable but not later than the time frame specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. In addition to the inspections required by Sections 5.4.1, 5.4.2 and 5.4.3 of Rule 4401, operator shall perform the following: initially inspect a PRD that releases to the atmosphere as soon as practicable but not later than 24 hours after the discovery of the release, re-inspect the PRD not earlier than 24 hours after the initial inspection but not later than 15 calendar days after the initial inspection, inspect all new, replaced, or repaired fittings, flanges, and threaded connections within 72 hours of placing the component in service. Except for PRDs subject to the requirements of Section 5.4.4.1 of Rule 4401, an operator shall inspect a component that has been repaired or replaced not later than 15 calendar days after the component was repaired or replaced. [District Rule 4401] Federally Enforceable Through Title V Permit
21. An operator shall inspect all unsafe-to-monitor components during each turnaround. [District Rule 4401] Federally Enforceable Through Title V Permit
22. District inspection in no way fulfills any of the mandatory inspection requirements that are placed upon operators and cannot be used or counted as an inspection required of an operator. [District Rule 4401] Federally Enforceable Through Title V Permit
23. An operator shall affix a readily visible weatherproof tag to a leaking component upon detection of the leak and shall include the following information on the tag: date and time of leak detection, date and time of leak measurement, for a gaseous leak, the leak concentration in ppmv, for a liquid leak, whether it is a major liquid leak or a minor liquid leak, whether the component is an essential component, an unsafe-to monitor component, or a critical component. [District Rule 4401] Federally Enforceable Through Title V Permit
24. An operator shall keep the tag affixed to the component until an operator has met all of the following conditions: repaired or replaced the leaking component, re-inspected the component using the test method in Section 6.3.3, and the component is found to be in compliance with the requirements of this rule. [District Rule 4401] Federally Enforceable Through Title V Permit
25. An operator shall minimize a component leak in order to stop or reduce leakage to the atmosphere immediately to the extent possible, but not later than one (1) hour after detection of the leak. [District Rule 4401] Federally Enforceable Through Title V Permit
26. Except for leaking critical components or leaking essential components subject to the requirements of Section 5.5.7 of Rule 4401, if an operator has minimized a leak but the leak still exceeds the applicable leak limits as defined in Section 3.0 of Rule 4401, an operator shall comply with at least one of the following requirements as soon as practicable but not later than the time period specified in Table 3 of Rule 4401: Repair or replace the leaking component; or vent the leaking component to a VOC collection and control system as defined in Section 3.0 of Rule 4401, or remove the leaking component from operation. [District Rule 4401] Federally Enforceable Through Title V Permit
27. The repair period in calendar days shall not exceed 14 days for minor gas leaks, 5 days for major gas leaks less than or equal to 50,000 ppmv, 2 days for gas leak greater than 50,000 ppmv, 3 days for minor liquid leaks, 2 days for major liquid leaks. [District Rule 4401] Federally Enforceable Through Title V Permit
28. The leak rate measured after leak minimization has been performed shall be the leak rate used to determine the applicable repair period specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
29. The time of the initial leak detection shall be the start of the repair period specified in Table 3 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit
30. If the leaking component is an essential component or a critical component that cannot be immediately shut down for repairs, and if the leak has been minimized but the leak still exceeds the applicable leak standard of this rule, the operator shall repair or replace the essential component or critical component to eliminate the leak during the next process unit turnaround, but in no case later than one year from the date of the original leak detection, whichever comes earlier. [District Rule 4401] Federally Enforceable Through Title V Permit
31. An operator shall maintain copies at the facility of the training records of the training program operated pursuant to Section 6.5 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. An operator that discovers that a PRD has released shall record the date that the release was discovered, and the identity and location of the PRD that released. An operator shall submit such information recorded during the calendar year to the APCO no later than 60 days after the end of the calendar year. [District Rule 4401] Federally Enforceable Through Title V Permit

33. Leak inspection, other than audio-visual, and measurements of gaseous leak concentrations shall be conducted according to EPA Method 21 using an appropriate portable hydrocarbon detection instrument calibrated with methane. The instrument shall be calibrated in accordance with the procedures specified in EPA Method 21 or the manufacturer's instruction, as appropriate, not more than 30 days prior to its use. The operator shall record the calibration date of the instrument. Where safety is a concern, such as measuring leaks from compressor seals or pump seals when the shaft is rotating, a person shall measure leaks by placing the instrument probe inlet at a distance of one (1) centimeter or less from the surface of the component interface. [District Rule 4401] Federally Enforceable Through Title V Permit

34. The results of gauge tank TVP testing conducted pursuant to Section 6.2.3 shall be submitted to the APCO within 60 days after the completion of the testing. [District Rule 4401] Federally Enforceable Through Title V Permit

35. An operator shall source test annually all vapor collection and control systems used to control emissions from steam-enhanced crude oil production well vents to determine the control efficiency of the device(s) used for destruction or removal of VOC. Compliance testing shall be performed annually by source testers certified by ARB. Testing shall be performed during June, July, August, or September of each year if the system's control efficiency is dependent upon ambient air temperature. A process system as defined in Section 3.30 of Rule 4401 is not subject to compliance source testing requirements. [District Rule 4401] Federally Enforceable Through Title V Permit

36. If approved by EPA, ARB, and the APCO, an operator need not comply with the annual testing requirement of Section 6.2.1 if all uncondensed VOC emissions collected by a vapor collection are controlled by an internal combustion engine subject to Rule 4702, a combustion device subject to Rule 4320, 4307 or 4308, a flare subject to Rule 4311. [District Rule 4401] Federally Enforceable Through Title V Permit

37. An operator shall comply with the following requirements for each gauge tank, as defined in Section 3.0 of Rule 4401: Conduct periodic TVP testing of each gauge tank at least once every 24 months during summer (July - September), and whenever there is a change in the source or type of produced fluid in the gauge tank. The TVP testing shall be conducted at the actual storage temperature of the produced fluid in the gauge tank using the applicable TVP test method specified in Section 6.4 of Rule 4623 (Storage of Organic Liquids). The operator shall submit the TVP testing results to the APCO as specified in Section 6.1.9 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

38. The control efficiency of any VOC control device, measured and calculated as carbon, shall be determined by EPA Method 25, except when the outlet concentration must be below 50 ppm in order to meet the standard, in which case EPA Method 25a may be used. EPA Method 18 may be used in lieu of EPA Method 25 or EPA Method 25a provided the identity and approximate concentrations of the analytes/compounds in the sample gas stream are known before analysis with the gas chromatograph and the gas chromatograph is calibrated for each of those known analyte/compound to ensure that the VOC concentrations are neither under- or over-reported. [District Rule 4401] Federally Enforceable Through Title V Permit

39. The VOC content by weight percent (wt.%) shall be determined using American Society of Testing and Materials (ASTM) D1945 for gases and South Coast Air Quality Management District (SCAQMD) Method 304-91 or the latest revision of ASTM Method E168, E169 or E260 for liquids. [District Rule 4401] Federally Enforceable Through Title V Permit

40. VOC content shall be analyzed by using the latest revision of ASTM Method E168, E169, or E260 as applicable. Analysis of halogenated exempt compounds shall be performed by using ARB Method 432. [District Rule 4401] Federally Enforceable Through Title V Permit

41. Operator shall keep a copy of the APCO-approved Operator Management Plan at the facility. [District Rule 4401] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

42. Permittee shall maintain with the permit accurate fugitive component counts for vapor control system according to CAPCOA's "California Implementation Guidelines for Estimating Mass Emissions of Fugitive Hydrocarbon Leaks at Petroleum Facilities," Table IV-2c (Feb 1999), Screening Range emission factors. [District Rule 2201] Federally Enforceable Through Title V Permit

43. Permittee shall maintain records of number and type of components installed and calculated fugitive emissions. Permittee shall update such records when new components are installed. [District Rule 2201] Federally Enforceable Through Title V Permit

44. Permittee shall maintain records of quarterly inspections including measured leaks greater than 10,000 ppm. [District Rule 2201] Federally Enforceable Through Title V Permit

45. By January 30 of each year, an operator shall submit to the APCO for approval, in writing, an annual report indicating any changes to an existing Operator Management Plan. [District Rule 4401] Federally Enforceable Through Title V Permit

46. Operator of any steam-enhanced crude oil production well shall keep an inspection log maintained pursuant to Section 6.4 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

47. Operator shall maintain an inspection log in which an operator records, at a minimum, all of the following information for each inspection performed: The total number of components inspected, total number and percentage of leaking components found by component type, location, type, and name or description of each leaking component and description of any unit where the leaking component is found, date of leak detection and the method of leak detection. For gaseous leaks, the leak concentration in ppmv, and for liquid leaks record whether the leak is a major liquid leak or a minor liquid leak. the date of repair, replacement, or removal from operation of leaking components, identify and location of essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, methods used to minimize the leak from essential components and critical components found leaking that cannot be repaired until the next process unit turnaround or not later than one year after leak detection, whichever comes earlier, the date of re-inspection and the leak concentration in ppmv after the component is repaired or is replaced, the inspector's name, business mailing address, and business telephone number, date and signature of the facility operator responsible for the inspection and repair program certifying the accuracy of the information recorded in the log. [District Rule 4401] Federally Enforceable Through Title V Permit

48. Operator shall keep a list of all gauge tanks, as defined in Section 3.0 of Rule 4401. The list shall contain the size, identification number, the location of each gauge tank and specify whether the gauge tank is upstream of all front line production equipment. [District Rule 4401] Federally Enforceable Through Title V Permit

49. The operator of any steam-enhanced crude oil production well shall maintain records of the date and well identification where steam injection or well stimulation occurs. [District Rule 4401] Federally Enforceable Through Title V Permit

50. An operator of any steam-enhanced crude oil production well shall keep source test records which demonstrate compliance with the control efficiency requirements of the VOC collection and control system as defined in Section 3.0 of Rule 4401. [District Rule 4401] Federally Enforceable Through Title V Permit

51. Records of each calibration of the portable hydrocarbon detection instrument utilized for inspecting components, including a copy of current calibration gas certification from the vendor of said calibration gas cylinder, the date of calibration, concentration of calibration gas, instrument reading of calibration gas before adjustment, instrument reading of calibration gas after adjustment, calibration gas expiration date, and calibration gas cylinder pressure at the time of calibration shall be maintained. [District Rule 4401] Federally Enforceable Through Title V Permit

52. All records of required monitoring data and support information shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4401] Federally Enforceable Through Title V Permit

53. All records required by this permit shall be maintained and retained on-site for a minimum of five (5) years and made available for District, ARB, and EPA inspection upon request. [District Rule 1070]

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1134-0 **EXPIRATION DATE:** 02/28/2017

EQUIPMENT DESCRIPTION:
85 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN MODEL 4231-85-GLE LOW-NOX BURNER ASSEMBLY, OR EQUIVALENT LOW-NOX BURNER, WITH FLUE GAS RECIRCULATION, APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. This generator is permitted to operate at the following locations: SE ¼, Section 25, Township 28E, Range 27E, the SE ¼, Section 13, Township 28E, Range 28E, and the SE ¼, Section 31, Township 28E, Range 28E(MDBM). [District Rule 2201] Federally Enforceable Through Title V Permit
2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The permittee's request for approval of equivalent equipment shall include the make, model, manufacturer's maximum rating, manufacturer's guaranteed emission rates, equipment drawing(s), and other relevant operational characteristics. [District Rule 2201] Federally Enforceable Through Title V Permit
4. A burner is not equivalent if any of the emission factors or the maximum heat input rating is greater than those authorized in this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. This unit shall be fired on PUC quality natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Fuel gas shall not contain more than 1 grain of total sulfur per 100 standard cubic feet or 0.00285 lb/MMBtu. [District Rule 2201, 4320 and 4801] Federally Enforceable Through Title V Permit
8. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
9. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
10. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102] Federally Enforceable Through Title V Permit
11. During the 60-day shakedown period, the operator shall operate the burner with the maximum FGR setting that can be accommodated by the specific commissioning activity being undertaken, perform expeditious completion of commissioning activities, and shall use good work practice standards to minimize emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during startup and shutdown periods, and the 60-day shakedown period, emissions shall not exceed either of the following limits: 7 ppmvd NOx (as NO2) @ 3% O2 (0.0085 lb/MMBtu), 0.003 lb PM10/MMBtu, 25 ppmvd CO @ 3% O2 (0.0185 lb/MMBtu) or 12 ppmvd VOC @ 3% O2 (0.0055 lb VOC/MMBtu). [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. During the 60-day shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx (as NO2) @ 3% O2 (0.018 lb/MMBtu), 0.0032 lb PM10/MMBtu, 50 ppmvd CO @ 3% O2 (0.037 lb/MMBtu) or 12 ppmvd VOC @ 3% O2 (0.0055 lb VOC/MMBtu). [District Rule 2201] Federally Enforceable Through Title V Permit

14. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit

16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit

17. The permittee shall monitor and record the stack concentration of NOX, CO, and O2 at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

18. If either the NOx or CO concentrations corrected to 3%, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

19. All NOx, CO, and O2 emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The NOx, CO, and O2 analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute sample period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

20. The permittee shall maintain records of: (1) the date and time of NOx, CO and O2 measurements, (2) the O2 concentration in percent by volume and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

21. A source test to demonstrate compliance with NOx and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

26. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

27. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100, Stack Gas Velocity (ft/min) - EPA Method 2, Stack Gas Moisture Content (%) - EPA Method 4, SOx (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6A, 6B, 6C or fuel gas sulfur content analysis and EPA Method 19, Fuel Gas Sulfur Content - EPA Method 11 or 15, ASTM D1072, D3031, D4084 D3246 or grab sample analysis by GC-FPD/TCD or double GC for H2S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588, PM10 - EPA Methods 5, 201A, and/or 202, CARB Method 5, or any combination of these PM10 methods with both filterable and condensable PM10 measured. [District Rules 1081, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

28. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

29. Each fuel source shall be tested semi-annually for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which semi-annual testing may resume. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1135-0 **EXPIRATION DATE:** 02/28/2017

EQUIPMENT DESCRIPTION:
85 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN MODEL 4231-85-GLE LOW-NOX BURNER ASSEMBLY, OR EQUIVALENT LOW-NOX BURNER, WITH FLUE GAS RECIRCULATION, APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS

PERMIT UNIT REQUIREMENTS

1. This generator is permitted to operate at the following locations: SE ¼, Section 25, Township 28E, Range 27E, the SE ¼, Section 13, Township 28E, Range 28E, and the SE ¼, Section 31, Township 28E, Range 28E(MDBM). [District Rule 2201] Federally Enforceable Through Title V Permit
2. The permittee shall notify the District Compliance Division of each location at which the operation is located in excess of 24 hours. Such notification shall be made no later than 48 hours after starting operation at the location. [District Rule 2201] Federally Enforceable Through Title V Permit
3. The permittee's request for approval of equivalent equipment shall include the make, model, manufacturer's maximum rating, manufacturer's guaranteed emission rates, equipment drawing(s), and other relevant operational characteristics. [District Rule 2201] Federally Enforceable Through Title V Permit
4. A burner is not equivalent if any of the emission factors or the maximum heat input rating is greater than those authorized in this Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
5. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102] Federally Enforceable Through Title V Permit
6. This unit shall be fired on PUC quality natural gas. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Fuel gas shall not contain more than 1 grain of total sulfur per 100 standard cubic feet or 0.00285 lb/MMBtu. [District Rule 2201, 4320 and 4801] Federally Enforceable Through Title V Permit
8. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
9. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
10. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102] Federally Enforceable Through Title V Permit
11. During the 60-day shakedown period, the operator shall operate the burner with the maximum FGR setting that can be accommodated by the specific commissioning activity being undertaken, perform expeditious completion of commissioning activities, and shall use good work practice standards to minimize emissions. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during startup and shutdown periods, and the 60-day shakedown period, emissions shall not exceed either of the following limits: 7 ppmvd NOx (as NO2) @ 3% O2 (0.0085 lb/MMBtu), 0.003 lb PM10/MMBtu, 25 ppmvd CO @ 3% O2 (0.0185 lb/MMBtu) or 12 ppmvd VOC @ 3% O2 (0.0055 lb VOC/MMBtu). [District Rules 2201, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

13. During the 60-day shakedown period, emissions shall not exceed any of the following limits: 15 ppmvd NOx (as NO2) @ 3% O2 (0.018 lb/MMBtu), 0.0032 lb PM10/MMBtu, 50 ppmvd CO @ 3% O2 (0.037 lb/MMBtu) or 12 ppmvd VOC @ 3% O2 (0.0055 lb VOC/MMBtu). [District Rule 2201] Federally Enforceable Through Title V Permit

14. During start-up and shutdown periods, emissions from the steam generator shall not exceed either of the following limits: 0.1 lb-NOx/MMBtu or 0.084 lb-CO/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods. [District Rules 4305, 5.5.6 and 4306, 5.3] Federally Enforceable Through Title V Permit

16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rule 4306, 3.25 and 3.22] Federally Enforceable Through Title V Permit

17. The permittee shall monitor and record the stack concentration of NOX, CO, and O2 at least once every month (in which a source test is not performed) using a portable analyzer that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

18. If either the NOx or CO concentrations corrected to 3%, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of performing the notification and testing required by this condition. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

19. All NOx, CO, and O2 emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The NOx, CO, and O2 analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute sample period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive minute period. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

20. The permittee shall maintain records of: (1) the date and time of NOx, CO and O2 measurements, (2) the O2 concentration in percent by volume and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

21. A source test to demonstrate compliance with NOx and CO emission limits shall be performed within 60 days of startup of this unit. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

22. Source testing to measure NOx and CO emissions from this unit shall be conducted at least once every twelve (12) months (no more than 30 days before or after the required annual source test date). After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months (no more than 30 days before or after the required 36-month source test date). If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 2201, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

23. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. Unless otherwise specified in the Permit to Operate, no determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4320. For the purposes of permittee-performed alternate monitoring, emissions measurements may be performed at any time after the unit reaches conditions representative of normal operation. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

25. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit [District Rules 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

26. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit

27. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, Stack Gas Oxygen - EPA Method 3 or 3A or ARB Method 100, Stack Gas Velocity (ft/min) - EPA Method 2, Stack Gas Moisture Content (%) - EPA Method 4, SOx (lb/MMBtu) - ARB Method 100 or EPA Method 6, 6A, 6B, 6C or fuel gas sulfur content analysis and EPA Method 19, Fuel Gas Sulfur Content - EPA Method 11 or 15, ASTM D1072, D3031, D4084 D3246 or grab sample analysis by GC-FPD/TCD or double GC for H2S and mercaptans performed in a laboratory, fuel gas hhv - ASTM D1826 or D1945 in conjunction with ASTM D3588, PM10 - EPA Methods 5, 201A, and/or 202, CARB Method 5, or any combination of these PM10 methods with both filterable and condensable PM10 measured. [District Rules 1081, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

28. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

29. Each fuel source shall be tested semi-annually for sulfur content and higher heating value. If a fuel content test fails to show compliance, weekly testing is required until compliance is demonstrated for 8 consecutive weeks, after which semi-annual testing may resume. [District Rules 2201 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1140-0 **EXPIRATION DATE:** 02/28/2017

SECTION: SW3 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (34-3, DIS #43006-74) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520, 9.3.2 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
7. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
9. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
11. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
12. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
15. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
16. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
17. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
20. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
22. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
24. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
25. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
29. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

31. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

35. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

36. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

37. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

39. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

40. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit

41. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

42. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

43. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1141-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 40-32, DIS# 43001-75)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

15. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

17. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

18. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520. 9.3.2] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

23. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

24. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

25. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

26. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

27. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

28. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

29. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

30. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit

32. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

33. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

34. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

35. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

36. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

37. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

39. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

40. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

41. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

42. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

43. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

44. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1142-0 **EXPIRATION DATE:** 02/28/2017

SECTION: NW09 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (43-9, DIS# 43010-75) WITH NORTH AMERICAN MODEL #GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 4305, 4351, 4306 and 4320] Federally Enforceable Through Title V Permit
7. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

37. Permittee shall maintain records of duration of each start-up and shutdown for a period of five years and make such records readily available for District inspection upon request. [District Rules 4306, 6.1 and 4320] Federally Enforceable Through Title V Permit

38. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

39. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
42. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
43. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
44. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1, and 4320] Federally Enforceable Through Title V Permit
45. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
46. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1143-0 **EXPIRATION DATE:** 02/28/2017

SECTION: NW09 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR 44-9, DIS #43007-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Flue gas recirculation shall be utilized, as needed, in conjunction with low-NOx burner to maintain ongoing compliance with permitted emission limits. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
3. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
7. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit

9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit

11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit

13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

17. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit

18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
25. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

36. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

37. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

39. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

41. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

42. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

43. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

44. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1144-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 9 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (45-9, DIS #43008-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Flue gas recirculation shall be utilized, as needed, in conjunction with low-NOx burner to maintain ongoing compliance with permitted emission limits. [District NSR Rule] Federally Enforceable Through Title V Permit
2. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
3. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
4. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520] Federally Enforceable Through Title V Permit
7. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
9. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, 4306, and 4320] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

37. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

39. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

40. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

41. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

42. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit

43. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

44. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

45. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1145-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 9 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (46-9, DIS #43009-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
3. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
7. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
25. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

36. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

37. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

39. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

41. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit

42. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

43. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

44. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1146-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (49-5, DIS# 43003-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, and 4351] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
9. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit
10. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
12. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
13. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
15. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

37. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

39. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

41. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

42. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

43. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

44. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

45. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

46. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1147-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 5 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (50-5, DIS# 4005-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, 4320, and 4351] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
9. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit
10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

22. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit

26. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

30. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

37. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

39. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

40. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

41. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

42. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

43. All records shall be maintained for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306 and 4320] Federally Enforceable Through Title V Permit

44. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

45. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1148-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 05 **TOWNSHIP:** 29S **RANGE:** 28

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (51-5, DIS #43004-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
3. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
6. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
7. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit

9. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

10. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit

11. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

12. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit

13. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit

14. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit

15. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

16. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

17. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit

18. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

19. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
25. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
26. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit
30. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

36. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

37. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

39. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

41. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit

42. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

43. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

44. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1149-0 **EXPIRATION DATE:** 02/28/2017

SECTION: SW03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (35-3, DIS# 43007-74) A NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, 4351, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
9. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
14. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
15. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
19. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
21. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
24. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
26. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
27. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

37. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

39. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

40. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

41. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

42. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

43. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

44. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1150-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID #36-3, DIS# 43008-74)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

15. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

17. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

19. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520. 9.3.2] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

22. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rules 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

23. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

24. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

25. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

26. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

27. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

28. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

29. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

30. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

31. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit

32. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

33. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

34. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

35. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

36. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

37. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

39. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

40. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

41. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

42. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

43. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

44. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1151-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 42-3, DIS# 43003-75)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

15. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

17. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. If the NOx or CO concentrations, as measured by the portable analyzer, exceed the permitted emission limits, the permittee or third party shall notify the District and return the NOx and CO concentrations to the permitted emission limits as soon as possible but no longer than one (1) hour after detection. If the portable analyzer readings continue to exceed the permitted emission limits after (1) hour, the permittee shall conduct a source test within 60 days, of the first exceedance to demonstrate compliance with the permitted emission limits. [District Rule 4305] Federally Enforceable Through Title V Permit
19. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
20. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
21. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
22. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
23. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. The permittee shall keep daily records of the sulfur content of the natural gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted and shall make records available for inspection upon request. [District NSR Rule] Federally Enforceable Through Title V Permit
27. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

31. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

32. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

33. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

34. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

35. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit

36. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

37. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

38. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

39. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit

40. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

41. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

42. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

43. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

44. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

45. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

46. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1152-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 65-3, DIS# 43006-80)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

15. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

17. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

18. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rule 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit
20. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rule 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit
21. NOx, and CO emissions shall be measured with annual source testing conducted by independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
22. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O2, NOx concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520, 9.5.1] Federally Enforceable Through Title V Permit
25. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
27. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
28. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

31. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

32. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

33. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit

34. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

35. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

36. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

37. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

39. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520, 6.4.2] Federally Enforceable Through Title V Permit

40. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

41. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

42. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

43. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

44. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1153-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (67-3, DIS# 43008-80) WITH NORTH AMERICAN GLE 1 LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, 4351, and Rule 4306] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
9. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
10. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
11. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
12. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520] Federally Enforceable Through Title V Permit
13. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
15. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit
27. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

37. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

39. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

41. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

42. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

43. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1, and 4320] Federally Enforceable Through Title V Permit

44. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

45. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1154-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (64-9, DIS# 43005-80) WITH NORTH AMERICAN GLE LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rules 2520, 4305, 4351, 4306, and 4320] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rule 1081 and 2520] Federally Enforceable Through Title V Permit
8. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O2, NOx concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
10. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
12. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
13. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
15. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit

27. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

37. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

39. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
41. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
42. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
43. Permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070] Federally Enforceable Through Title V Permit
44. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 6.1, 4306, 6.1, and 4320] Federally Enforceable Through Title V Permit
45. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
46. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1155-0 **EXPIRATION DATE:** 02/28/2017

SECTION: NW5 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (81-4, DIS# 43013-82) WITH NORTH AMERICAN GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM (MONTE CRISTO 1 LEASE)

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the unit is fired on PUC-regulated natural gas, valid purchase contracts, supplier certifications, tariff sheets, or transportation contracts may be used to satisfy the fuel sulfur content analysis, provided they establish the fuel sulfur concentration and higher heating value. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
4. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rules 2520 and 4320] Federally Enforceable Through Title V Permit
5. If the steam generator is not fired on PUC-regulated natural gas and compliance is achieved through fuel sulfur content limitations, then the sulfur content of the fuel shall be determined by testing sulfur content at a location after all fuel sources are combined prior to incineration, or by performing mass balance calculations based on monitoring the sulfur content and volume of each fuel source. The sulfur content of the fuel shall be determined using the test methods referenced in this permit. [District Rule 4320] Federally Enforceable Through Title V Permit
6. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 4305, and 4351] Federally Enforceable Through Title V Permit
7. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by a District-approved independent laboratory on an annual basis. Sample collection for such determination shall be District-witnessed or approved. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit
8. Permittee shall keep weekly records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted. [District Rule 1070 and 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
10. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
11. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
12. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
13. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
14. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
15. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
16. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
17. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
19. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
20. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

21. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

22. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

23. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

26. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit

27. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

28. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

29. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

30. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

31. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

32. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

34. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

35. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

36. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

37. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

39. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

41. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

42. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

43. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

44. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

45. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1156-0 **EXPIRATION DATE:** 02/28/2017

SECTION: NW 3 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (80-4, DIS #43010-82) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201 and 4301] Federally Enforceable Through Title V Permit
2. If the steam generator is fired on PUC-regulated natural gas, then the permittee shall maintain on file copies of all natural gas bills or fuel throughput records for a period of five years. [District Rule 2520] Federally Enforceable Through Title V Permit
3. If the steam generator is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the engine shall be determined using ASTM D 1072, D 3031, D 4084, D 3246, D 6228, double GC for H2S and mercaptans, or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District RuleS 2520 and 4320] Federally Enforceable Through Title V Permit
4. If the steam generator is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [District Rule 2520] Federally Enforceable Through Title V Permit
5. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520] Federally Enforceable Through Title V Permit
6. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
7. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

8. The requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520] Federally Enforceable Through Title V Permit
9. Emissions shall not exceed any of the following limits: PM10: 0.014 lb/MMBtu, or VOC: 0.003 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
10. Except during start-up and shutdown periods, emissions shall not exceed any of the following limits: NOx as NO2: 15 ppmvd @ 3% O2 or 0.0182 lb-NOx/MMBtu, or CO: 29 ppmvd @ 3% O2 or 0.021 lb-CO/MMBtu. [District Rules 2201 and 4306] Federally Enforceable Through Title V Permit
11. During start-up and shutdown periods, emissions shall not exceed: NOx as NO2: 0.1 lb/MMBtu, or CO: 0.084 lb/MMBtu. [District Rule 2201] Federally Enforceable Through Title V Permit
12. Maximum emissions from the steam generator, including start-up and shutdown, shall not exceed any of the following limits: NOx as NO2: 54.0 lb/day, or CO: 31.5 lb/day. [District Rule 2201] Federally Enforceable Through Title V Permit
13. Duration of start-up or shutdown shall not exceed two hours each per occurrence. During start-up or shutdown, the emissions control system shall be in operation, and emissions shall be minimized insofar as technologically possible. The operator shall maintain daily records of the duration of start-up and shutdown periods exceeding 2 hours. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
14. Start-up is defined as the period of time during which a unit is brought from a shutdown status to its operating temperature and pressure, including the time required by the unit's emission control system to reach full operation. Shutdown is defined as the period of time during which a unit is taken from an operational to a non-operational status by allowing it to cool down from its operating temperature to ambient temperature as the fuel supply to the unit is completely turned off. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
15. The combined sulfur content of all fuels supplied to this steam generator shall not exceed 5 grains S/100 scf. [District Rule 4320] Federally Enforceable Through Title V Permit
16. The permittee shall monitor and record the stack concentration of NOx, CO, and O2 at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
17. If either the NOx or CO concentrations corrected to 3% O2, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit
18. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the permit-to-operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

19. The permittee shall maintain records of: (1) the date and time of NOx, CO, and O2 measurements, (2) the O2 concentration in percent and the measured NOx and CO concentrations corrected to 3% O2, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

21. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520] Federally Enforceable Through Title V Permit

22. Source sampling to determine the compliance status of an emissions source shall be witnessed or authorized by District personnel. [District Rule 1081] Federally Enforceable Through Title V Permit

23. Source testing to measure NOx and CO emissions from this unit while fired on natural gas shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

24. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

25. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

26. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305, and 4306] Federally Enforceable Through Title V Permit

27. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas moisture content - EPA Method 4, and stack gas velocities - EPA Method 2. [District Rules 1081, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

28. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

29. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

31. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

32. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rules 2520, 4305, 4306, and 4351] Federally Enforceable Through Title V Permit

33. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

34. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

35. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

36. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

37. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

39. The permittee shall keep daily records of the sulfur content of the vapor recovery gas, amount of natural gas combusted, and the amount of vapor recovery gas combusted, for a period of 5 years, and shall make records available for inspection upon request. [District NSR Rule and District Rules 1070 and 2520] Federally Enforceable Through Title V Permit

40. All records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070, 4305, 4306, and 4320] Federally Enforceable Through Title V Permit

41. Pursuant to Rule 4320, beginning in 2010 the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit

42. Permittee shall maintain records of annual heat input (MMBtu) for this unit on a calendar year basis. Such records shall be maintained and retained on-site for a minimum of five (5) years, and shall be made available for District inspection upon request. [District Rules 1070 and 4320] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1157-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 04 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 79-4, DIS# 43009-82)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rule 2201] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected or prevented from entering this unit. [District NSR Rule and District Rule 2080] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

15. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

16. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

17. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

18. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

19. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

20. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

21. Emission rates shall not exceed PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, and CO: 0.021 lb/MMBtu. [District NSR Rule and District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

22. A source test to demonstrate compliance with the indicated emission limits shall be performed within 60 days of recommencing operation of this unit. [District NSR Rule] Federally Enforceable Through Title V Permit

23. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

24. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted within 60 days of startup, and not less than once every 12 months, except as provided below. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit

25. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit

26. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305, 6.3.1 and 4351, 6.3] Federally Enforceable Through Title V Permit

27. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

28. NOx and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

29. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

30. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis; and percentage O2, NOx concentration, and CO concentration on a monthly basis. [District Rules 1070, 4305, and 2520, 9.3.2] Federally Enforceable Through Title V Permit

32. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. This mean shall be multiplied by the appropriate factor. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit

33. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

34. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

35. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

36. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

37. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

38. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

39. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

40. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

41. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

42. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit

43. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

44. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1158-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 53-32, DIS# 43012-78)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Sulfur emissions shall not exceed 0.11 lb of sulfur per million BTU of heat input, averaged over 3 - one hour periods. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas; multiplying the reported sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by a combination of source testing for sulfur compounds and fuel analysis. Compliance may be demonstrated for this unit individually, or by showing that the total emissions of sulfur compounds from all steam generators located at the stationary source with ATC or PTO issued prior to September 12, 1979 does not exceed the emissions that would result if each unit was operating in compliance with the specified limit. [Kern County Rule 424 and District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

14. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit

15. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit

16. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit

17. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2 and 2520, 9.5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rule 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
19. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
20. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
21. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
22. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit
23. NOx and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis. [District Rule 1070 and 2520, 9.5.1] Federally Enforceable Through Title V Permit
27. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. All equipment, facilities, and systems installed or used to achieve compliance with the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003) shall at all times be maintained in good working order and be operated as efficiently as possible so as to minimize air pollutant emissions. [PSD SJ 80-14] Federally Enforceable Through Title V Permit
29. The Regional Administrator shall be notified in writing within (15) days following any failure of air pollution control equipment, process equipment, or of a process to operate in a normal manner which results in an increase in emissions above any allowable emissions limit stated in Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003). This notification shall include a description of the malfunctioning equipment or abnormal operation, the date of the initial failure, the period of time over which emissions were increased due to the failure, the cause of the failure, the estimated resultant emissions in excess of those allowed under Section VIII of Federal Permit SJ 80-14 (as amended August 15, 2003), and the methods utilized to restore normal operations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

30. The Regional Administrator, the head of the State Air Pollution Control Agency, the head of the responsible local air pollution control agency, and/or their authorized representatives, upon the presentation of credentials, shall be permitted: A) to enter upon the premises where the source is located or in which any records are required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and B) at reasonable times to have access to and copy any records required to be kept under the terms and conditions of Federal Permit SJ 80-14 (as amended August 15, 2003); and C) to inspect any equipment, operation, or method required in Federal Permit SJ 80-14 (as amended August 15, 2003); and D) to sample emissions from the source. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

31. In the event of any changes in control or ownership of facilities, Federal Permit SJ 80-14 (as amended August 15, 2003) shall be binding on all subsequent owners and operators. The applicant shall notify the succeeding owner and operator of the existence of Federal Permit SJ 80-14 (as amended August 15, 2003) and its conditions by letter, a copy of which shall be forwarded to the Regional Administrator and the State and local Air Pollution Control Agency. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

32. The provisions of Federal Permit SJ 80-14 (as amended August 15, 2003) are severable, and, if any provision of amended Federal Permit SJ 80-14 is held invalid, the remainder of amended Federal Permit SJ 80-14 shall not be affected thereby. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

33. The owner and operator of the proposed project shall construct and operate the proposed stationary source in compliance with all other applicable provisions of 40 CFR Parts 52, 60, and 61 and all other applicable Federal, State and local regulations. [PSD SJ 80-14] Federally Enforceable Through Title V Permit

34. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit

35. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit

36. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

37. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

38. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

39. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

40. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

41. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

42. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

43. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1159-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 32 **TOWNSHIP:** 28S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 77-32, DIS# 43011-82)

PERMIT UNIT REQUIREMENTS

1. No modification to this unit shall be performed without an Authority to Construct for such modification(s), except for changes specified in conditions below. [District Rules 2201, 4305 and 4306] Federally Enforceable Through Title V Permit
2. The fuel supply line shall be physically disconnected from this unit. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
3. This equipment shall not be operated for any reason until an Authority to Construct permit is issued approving all necessary retrofits required to comply with the applicable requirements of District Rule 4306 and all other applicable District regulations. [District Rules 4305 and 4306] Federally Enforceable Through Title V Permit
4. Copies of all gas purchase contracts, supplier certifications, and test results to determine compliance with the conditions of this permit shall be maintained. The operator shall record daily amount and type(s) of fuel(s) combusted, fuel source, and all dates on which unit is fired on any noncertified fuel and record specific type of noncertified fuel used. [District Rule 2520] Federally Enforceable Through Title V Permit
5. The operator shall maintain all records of required monitoring data and support information for inspection at any time for a period of five years. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
6. Particulate matter emissions shall not exceed 0.1 grain/dscf, 0.1 grain/dscf calculated to 12% CO2, nor 10 lb/hr. [District Rules 4201, 3.1 and 4301, 5.1 and 5.2.3] Federally Enforceable Through Title V Permit
7. Emissions of sulfur compounds from this unit shall not exceed 200 lb per hour, calculated as SO2. Compliance with this requirement may be demonstrated by firing the unit only on PUC or FERC regulated natural gas or by testing the sulfur content of each fuel and determining the maximum hourly emissions of sulfur compounds by multiplying the sulfur content of each fuel in lb/MMBtu by the maximum heat input rating of the unit; or by source testing in combination with fuel analysis. [District Rule 2520, 9.3.2 and District Rule 4301, 5.2.1] Federally Enforceable Through Title V Permit
8. When complying with sulfur emission limits by fuel analysis or by a combination of source testing and fuel analysis, each fuel source shall be tested weekly for sulfur content and higher heating value. If compliance with the fuel sulfur content limit and sulfur emission limits has been demonstrated for 8 consecutive weeks for a fuel source, then the fuel testing frequency shall be semi-annually. If a semi-annual fuel content source test fails to show compliance, weekly testing shall resume until compliance is demonstrated for 8 consecutive weeks. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. When complying with SOx emission limits by testing of stack emissions, testing shall be performed not less than once every 12 months using EPA Method 6 or 6B or 6C; or Method 8 or ARB Method 1-100; or, for units using gaseous fuel scrubbed for sulfur pre-combustion, the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 3246, D 4084 or a grab sample analysis by GC-FPD/TCD performed in the laboratory and EPA Method 19 to calculated emissions. Gaseous fuel fired units demonstrating compliance on two consecutive annual source tests shall be tested not less than once every thirty-six months, however annual source testing shall resume if any test fails to show compliance. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

10. If the unit is fired on noncertified gaseous fuel and compliance with SOx emission limits is achieved through fuel sulfur content limitations, then the sulfur content of the gaseous fuel being fired in the unit shall be determined using ASTM D 1072, D 3031, D 4084, D 3246 or grab sample analysis by GC-FPD/TCD performed in the laboratory. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

11. If fuel analysis is used to demonstrate compliance with conditions of this permit, the fuel higher heating value for each fuel shall be certified by a third party fuel supplier or determined by ASTM D 1826 or D 1945 in conjunction with ASTM D 3588 for gaseous fuels. [District Rule 2520, 9.3.2; 4305, 6.2.1; and 4351, 6.2.1] Federally Enforceable Through Title V Permit

12. The concentration of sulfur compounds in the exhaust from this unit shall not exceed 0.2% by volume as measured on a dry basis over a 15 minute period. To demonstrate compliance with this requirement the operator shall do one of the following: fire the unit only on PUC or FERC regulated natural gas; or test the sulfur content of each fuel source and demonstrate the sulfur content does not exceed 3.3% by weight for gaseous fuels; or determine that the concentration of sulfur compounds in the exhaust does not exceed the concentration limit by a combination of source testing and fuel analysis. [District Rule 2520, 9.3.2; County Rules 404 (Madera), 406 (Fresno), and 407 (Kern, Kings, Merced, San Joaquin, Stanislaus, and Tulare)] Federally Enforceable Through Title V Permit

13. Annual test results submitted to the District from unit(s) representing a group of units may be used to measure NOx and CO emissions of this permit for that group, provided the selection of the representative unit(s) is approved by the APCO prior to testing. Should any of the representative units exceed the required NOx and CO emission limits of this permit, each of the units in the group shall demonstrate compliance by emissions testing within 90 days of the failed test. (This requirement shall not supersede a more stringent NSR or PSD permit testing requirement). [District Rules 4305, 6.3.2 and 4351, 6.3] Federally Enforceable Through Title V Permit

14. The following conditions must be met for representative unit(s) to be used to test for NOx and CO limits for a group of units: 1) all units are initially source tested and emissions from each unit in group are less than 90% of the permitted value and vary 25% or less from the average of all runs, 2) all units in group are similar in terms of rated heat input (rating not to exceed 100 MMBtu/hr), make and series, operation conditions, and control method, and 3) the group is owned by a single owner and located at a single stationary source. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

15. All units in a group for which representative units are source tested for NOx and CO emissions shall have received the same maintenance and tune-up procedures as the representative unit(s). These tune-up procedures shall be completed according to District Rule 4304 (Adopted October 19, 1995) and tune-up test results shall show comparable results for each unit in the group. Records shall be maintained for the each unit of the group including all preventative and corrective maintenance work done. [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

16. All units in a group for which representative units are source tested to demonstrate compliance for NOx and CO emissions of this permit shall be fired on the same fuel type during the entire compliance period. If a unit switches for any time to an alternate fuel type (e.g. from natural gas to oil) then that unit shall not be considered part of the group and shall be required to undergo a source test for all fuel types used, within one year of the switch [District Rules 2520, 9.3.2 and 4305, 6.3.2] Federally Enforceable Through Title V Permit

17. The number of representative units source tested for NOx and CO emissions shall be at least 30% of the total number of units in the group. The units included in the 30% shall be rotated, so that in 3 years, all units in the entire group will have been tested at least once. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

18. Compliance with permit conditions in the Title V permit shall be deemed compliance with the following requirements: SJVUAPCD Rules 4201 (Last Amended December 17, 1992), 4301 (Last Amended December 17, 1992), 4305 sections 4.2, 5.1, 5.4.1, 5.4.2, 6.1.1, 6.2 (except 6.2.3), 6.3.1, 6.3.2, and 8.1 (Last Amended August 21, 2003), and 4351, sections 4.2, 5.2.2, 6.1.2, 6.2, and 8.1 (Last Amended August 21, 2003). A permit shield is granted from these requirements. [District Rule 2520] Federally Enforceable Through Title V Permit
19. This unit commenced construction, modification, or reconstruction prior to June 19, 1984. This unit has not been used to produce electricity for sale in 1985 or on or after November 15, 1990. Therefore, the requirements of 40 CFR 72.6(b) and 40 CFR 60.40c do not apply to this source. A permit shield is granted from this requirement. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
20. Emission rates shall not exceed any of the following PM10: 0.014 lb/MMBtu, SOx (as SO2): 0.094 lb/MMBtu, NOx (as NO2): 0.036 lb/MMBtu or 30 ppmv @ 3% O2, VOC: 0.003 lb/MMBtu, or CO: 0.021 lb/MMBtu. [District Rules 2201, 4305, and 4351] Federally Enforceable Through Title V Permit
21. Vapor recovery gas sulfur analysis and heating value determination shall be conducted by District-witnessed, or approved sample collection by an independent laboratory on an annual basis. [District Rules 1081, 7.2, and 2520, 9.5.1] Federally Enforceable Through Title V Permit
22. If the NOx and CO concentrations, as measured by the portable analyzer, exceed the allowable emission rate, the permittee shall notify the District and take corrective action within one (1) hour after detection. If the portable analyzer readings continue to exceed the allowable emission rate, the permittee shall conduct an emissions test within 60 days, utilizing District-approved test methods, to demonstrate compliance with the applicable emission limits. [District Rules 4305 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
23. NOx and CO emissions shall be measured with annual source testing conducted by an independent testing laboratory and shall be witnessed or authorized by the District [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
24. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified 30 days prior to any compliance source test, and a source test plan must be submitted for approval 15 days prior to testing. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
26. The permittee shall keep records of the following: sulfur content of the vapor recovery gas on an annual basis; amount of natural gas and amount of vapor recovery gas combusted on a daily basis. [District Rules 1070 and 2520, 9.4.2] Federally Enforceable Through Title V Permit
27. Emissions for this unit shall be calculated using the arithmetic mean, pursuant to District Rule 1081 (Amended December 16, 1993), of 3 thirty-minute test runs for NOx and CO. This mean shall be multiplied by the appropriate factor. [District Rules 1081 and 2520, 9.3.2] Federally Enforceable Through Title V Permit
28. The stack concentration of NOx (as NO2), CO, and O2 shall be measured at least on a monthly basis using District approved portable analyzers in any calendar month in which the unit operates. [District Rules 4305, 4351] Federally Enforceable Through Title V Permit
29. The permittee shall maintain records of the date and time of NOx, CO, and O2 measurements, the measured NO2 and CO concentrations corrected to 3% O2, and the O2 concentration. The records shall also include a description of any corrective action taken to maintain the emissions in the acceptable range and shall identify any unit that did not operate at any time during the calendar month. These records shall be retained at the facility for a period of no less than 5 years and shall be made readily available for District inspection upon request. [District Rules 1070, 4305, 4351] Federally Enforceable Through Title V Permit
30. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 12 months, except as provided below. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

31. Source testing to demonstrate compliance with NOx and CO emission limits shall be conducted not less than once every 36 months if compliance is demonstrated on two consecutive annual tests. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

32. If permittee fails any compliance demonstration for NOx and/or CO emission limits when testing not less than once every 36 months, compliance with NOx and CO emission limits shall be demonstrated not less than once every 12 months. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

33. Source test results from an individual unit that is identical to this unit, in terms of rated capacity, operational conditions, fuel used, and control method, as approved by the APCO, will satisfy the NOx and CO source testing requirement. [District Rules 4305 and 4351] Federally Enforceable Through Title V Permit

34. Compliance demonstration (source testing) shall be by District witnessed, or authorized, sample collection by ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

35. The following test methods shall be used: NOx (ppmv) - EPA Method 7E or ARB Method 100, NOx (lb/MMBtu) - EPA Method 19, CO (ppmv) - EPA Method 10 or 10B or ARB Method 100, stack gas oxygen - EPA Method 3 or 3A or ARB Method 100, stack gas velocities - EPA Method 2, stack gas moisture content - EPA Method 4, and fuel gas sulfur content - ASTM D3246 or double GC for H2S and mercaptans. [District Rules 1081, 4305, and 4351] Federally Enforceable Through Title V Permit

36. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for a period of 5 years and shall make such records readily available for District inspection upon request. [District Rule 4351] Federally Enforceable Through Title V Permit

37. Steam generator may be operated with ring or perforated type burner diffuser plate. Changes between ring or perforated type burner diffuser plates shall be recorded in a contemporaneous log. [District Rule 2520 section 6.4.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1160-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT A, DIS# 47003-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL

PERMIT UNIT REQUIREMENTS

1. Operation shall include GE LM-2500-PE gas fired 240 MMBtu/hr (nominal rating) gas turbine engine, 22.3 MW electrical generator, inlet air evaporative cooler, turbine combustor water injectors, gas-fired Coen duct burner rated at 70 MM Btu/hr (nominal rating), Nooter heat recovery steam generator, CO oxidizing catalyst, ammonia injection grid, selective catalytic reduction (SCR) bed, and in-stack continuous emissions monitors (CEMs) for NOx, CO, and O2. [District Rule 2010] Federally Enforceable Through Title V Permit
2. Unit shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(a) & (b); 60.332(a); Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
3. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
4. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Rule 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), Rule 110 (Madera), and Rule 108 (Kings); District Rule 1081] Federally Enforceable Through Title V Permit
5. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246 or grab bag analysis by GC-FPD/TCD performed in the laboratory. [40 CFR 60.335(d)] Federally Enforceable Through Title V Permit
6. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)] Federally Enforceable Through Title V Permit
7. The HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, OR ASTM 1945. [40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
8. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.332(a),(b) and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Unit shall demonstrate compliance annually with NOx and CO emissions limits with the duct burner in operation and not in operation. An annual demonstration of compliance with the duct burner in operation is not required in any year in which the duct burner is not operated at all in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of resumption of operation of the duct burner. An annual demonstration of compliance with the duct burner not in operation is not required in any year in which the duct burner operated continuously in conjunction with the turbine in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of shutdown of operation of the duct burner. [40 CFR 60.335(b) and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit
10. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
11. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.3 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
12. If the turbine is fired on PUC-regulated natural gas, then the operator shall maintain a log describing the source of natural gas and the quantity used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. Results of continuous emission monitoring must be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(a),(b),(c) and District Rule 4703, 5.0] Federally Enforceable Through Title V Permit
14. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(a),(b) and District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit
15. Operator shall operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 concentration . [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit
16. The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit
17. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
18. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
19. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Sulfur content of gas burned shall not exceed 1.0 gr/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit
21. Gas turbine engine shall be equipped with continuously recording fuel gas flowmeter. [District Rules 1070 and 4703] Federally Enforceable Through Title V Permit
22. Daily emissions shall not exceed any of the following: PM10: 89.3 lb/day, SOx (as SO2): 29.8 lb/day, NOx (as NO2): 133.9 lb/day, VOC: 245.5 lb/day, or CO: 223.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit
23. Ammonia (NH3) emissions shall not exceed 21 ppmvd @ 15% O2 over a 24-hour average period. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
24. Ammonia slip shall be calculated as: slip = (a-bxc/1,000,000) x 1,000,000/b, where a=ammonia injection rate(lb/hr)/17(lb/lb.mol), and b=dry exhaust gas flow rate (lb/hr)/29(lb/lb.mol); and c=change in measured NOx concentration in ppmvd at the actual stack oxygen (O2) concentration or by another method approved by the District. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit
25. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 4001] Federally Enforceable Through Title V Permit
26. Transitional operation period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit
27. Except during periods of gas turbine engine startup/shutdown, and transitional operation period, emission rates (three-hour average) shall not exceed any of the following: PM10: 0.012 lb/MMBtu, SOx (as SO2): 0.004 lb/MMBtu; or VOC: 0.033 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit
28. Maximum NOx emission rate (one hour average) shall not exceed the NSPS standard of 105 ppmv dry @ 15% O2. [District Rule 4001] Federally Enforceable Through Title V Permit
29. Except during periods of gas turbine engine startup/shutdown, and transitional operation period, emission rates (based on three-hour rolling average) shall not exceed either of the following: NOx (as NO2): 5 ppmv dry @ 15% oxygen (O2); or CO: 13.5 ppmv @ 15% oxygen (O2). [District Rule 4703, 5.1.2, 5.2 and District NSR Rule] Federally Enforceable Through Title V Permit
30. Permittee shall report the following emission exceedences to the District: NOx emission rate on a three-hour average, NSPS NOx emission rate on one hour average, and DEL of NOx during days of gas turbine engine startup/shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit
31. The three-hour average will be compiled from the three most recent one-hour periods, with each one-hour period commencing on the hour. [District Rule 1081] Federally Enforceable Through Title V Permit
32. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx daily emission limitation by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District NSR Rule] Federally Enforceable Through Title V Permit
33. Permittee shall comply in full with Rule 4001 (New Source Performance Standards) requirements, including notification, recordkeeping and monitoring requirements. [District Rule 4001] Federally Enforceable Through Title V Permit
34. Continuous emissions monitoring system shall conform to Rule 1080 specifications. [District Rule 1080] Federally Enforceable Through Title V Permit
35. Continuous emission monitoring systems shall be calibrated and operated according to EPA guidelines as specified in CFR, Part 60, Appendix B. CEM ppm and lb/hr shall be calculated as a three-hour and a 1 hour average. [District Rules 4001 and 4703] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. Annual relative accuracy audits of CEM's shall be conducted by independent laboratory in accordance with EPA guidelines. The District shall be notified of the audit in advance and reports shall be submitted to the District within 60 days of each test. [District Rule 4001] Federally Enforceable Through Title V Permit

37. Permittee shall keep accurate records of turbine daily NOx (as NO2) and oxygen (O2) monitors output for a period of five years, and shall make such records readily available for District inspection upon request. [District Rules 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit

38. Compliance source testing for NOx, CO, and O2 shall be conducted at least once every 12 months under conditions representative of normal operation. [District NSR Rule and District Rule 4703, 6.3.1] Federally Enforceable Through Title V Permit

39. Compliance source testing shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

40. Source test protocol shall be submitted for District approval at least 15 days prior to test date. [District Rule 1081] Federally Enforceable Through Title V Permit

41. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

42. The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front half and back half) or 201A and 202 or CARB Method 5 (front and back half); ammonia - BAAQMD ST-1B; and O2 - EPA Method 3, 3A, or 20 or CARB Method 100. [40 CFR 60.335(a) and District Rules 2520 and 4703] Federally Enforceable Through Title V Permit

43. Exhaust stack following last economizer shall be of circular cross-section and shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods, including flow straighteners, if necessary, to minimize turbulence. [District Rule 1081] Federally Enforceable Through Title V Permit

44. Permittee shall maintain records of all fuel sulfur content testing performed. [District NSR Rule] Federally Enforceable Through Title V Permit

45. Permittee shall maintain daily records of the following: time of start-up(s) and shutdown(s), length and reason for reduced load periods, total hours of operation, and source(s) of and quantity of fuel used. [District Rules 1070 and 4703, 6.2.6] Federally Enforceable Through Title V Permit

46. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1161-0 **EXPIRATION DATE:** 02/28/2017

SECTION: 03 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT B, DIS# 47004-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL

PERMIT UNIT REQUIREMENTS

1. Operation shall include GE LM-2500-PE gas fired 240 MMBtu/hr (nominal rating) gas turbine engine, 22.3 MW electrical generator, inlet air evaporative cooler, turbine combustor water injectors, gas-fired Coen duct burner rated at 70 MM Btu/hr (nominal rating), Nooter heat recovery steam generator, CO oxidizing catalyst, ammonia injection grid, selective catalytic reduction (SCR) bed, and in-stack continuous emissions monitors (CEMs) for NOx, CO, and O2. [District Rule 2010] Federally Enforceable Through Title V Permit
2. Unit shall be fired exclusively on PUC-quality natural gas which has a sulfur content of less than or equal to 0.017% by weight. [40 CFR 60.333(a) & (b); 60.332(a); Rule 404 (Madera), 406 (Fresno) and 407 (6 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
3. Operator shall not discharge into the atmosphere combustion contaminants (PM) exceeding in concentration at the point of discharge, 0.1 gr/dscf. [District Rule 4201; Rule 402 (Madera) and 404 (all 7 remaining counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit
4. Operator shall be required to conform to the compliance testing procedures described in District Rule 1081. [Rule 108.1 (Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus), Rule 110 (Madera), and Rule 108 (Kings); District Rule 1081] Federally Enforceable Through Title V Permit
5. If the turbine is not fired on PUC-regulated natural gas, then the sulfur content of the natural gas being fired in the turbine shall be determined using ASTM method D 1072, D 3031, D 4084 or D 3246 or grab bag analysis by GC-FPD/TCD performed in the laboratory. [40 CFR 60.335(d)] Federally Enforceable Through Title V Permit
6. If the turbine is not fired on PUC-regulated natural gas, the sulfur content of each fuel source shall be tested weekly except that if compliance with the fuel sulfur content limit has been demonstrated for 8 consecutive weeks for a fuel source, then the testing frequency shall be quarterly. If a test shows noncompliance with the sulfur content requirement, the source must return to weekly testing until eight consecutive weeks show compliance. [40 CFR 60.334(b)(2)] Federally Enforceable Through Title V Permit
7. The HHV and LHV of the fuel shall be determined using ASTM D3588, ASTM 1826, OR ASTM 1945. [40 CFR 60.332(a),(b)] Federally Enforceable Through Title V Permit
8. The operator shall provide source test information annually regarding the exhaust gas NOx concentration corrected to 15% O2 (dry). [40 CFR 60.332(a),(b) and District Rule 4703, 5.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

9. Unit shall demonstrate compliance annually with NOx and CO emissions limits with the duct burner in operation and not in operation. An annual demonstration of compliance with the duct burner in operation is not required in any year in which the duct burner is not operated at all in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of resumption of operation of the duct burner. An annual demonstration of compliance with the duct burner not in operation is not required in any year in which the duct burner operated continuously in conjunction with the turbine in the preceding 12 months, in such case, the unit shall be compliance source tested within 60 days of shutdown of operation of the duct burner. [40 CFR 60.335(b) and District Rule 4703, 6.3.3] Federally Enforceable Through Title V Permit
10. Results of continuous emissions monitoring must be reduced according to the procedure established in 40 CFR, Part 51, Appendix P, paragraphs 5.0 through 5.3.3, or by other methods deemed equivalent by mutual agreement with the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.2] Federally Enforceable Through Title V Permit
11. Records shall be maintained and shall contain: the occurrence and duration of any start-up, shutdown or malfunction, performance testing, evaluations, calibrations, checks, adjustments, maintenance of any CEM's that have been installed pursuant to District Rule 1080, and emission measurements. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera); District Rule 1080, 7.3 and 40 CFR 60.7(b)] Federally Enforceable Through Title V Permit
12. If the turbine is fired on PUC-regulated natural gas, then the operator shall maintain a log describing the source of natural gas and the quantity used. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
13. Results of continuous emission monitoring must be averaged in accordance with the requirements of 40 CFR 60.13. [40 CFR 60.334(a),(b),(c) and District Rule 4703, 5.0] Federally Enforceable Through Title V Permit
14. Operator shall maintain a stationary gas turbine operating log that includes, on a daily basis the actual local start-up and stop time, length and reason for reduced load periods, total hours of operation and quantity of fuel used. [40 CFR 60.332(a),(b) and District Rule 4703, 6.2.4] Federally Enforceable Through Title V Permit
15. Operator shall install, operate and maintain in calibration a system which continuously measures and records: control system operating parameters, elapsed time of operation, the exhaust gas NOx and O2 concentration . [40 CFR 60.334(a),(b)] Federally Enforceable Through Title V Permit
16. The continuous NOx monitoring system shall meet the performance specification requirements in 40 CFR 60, Appendix F, 40 CFR 51, Appendix P, and Part 60, Appendix B, or shall meet equivalent specifications established by mutual agreement of the District, the ARB, and the EPA. [Rule 108 (Kings, Fresno, Merced, San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 6.7] Federally Enforceable Through Title V Permit
17. A violation of NOx emission standards indicated by the NOx CEM shall be reported by the operator to the APCO within 96 hours. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 9.0] Federally Enforceable Through Title V Permit
18. The APCO shall be notified no later than eight hours after the detection of a breakdown of the CEM. The operator shall inform the APCO of the intent to shut down the CEM at least 24 hours prior to the event. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 10.0] Federally Enforceable Through Title V Permit
19. Operators of CEM's installed at the direction of the APCO shall submit a written report for each calendar quarter to the APCO. The report is due on the 30th day following the end of the calendar quarter and shall include: A. time intervals, data and magnitude of excess emissions, nature and cause of excess (if known), corrective actions taken and preventive measures adopted; B. averaging period used for data reporting corresponding to the averaging period specified in the emission test period used to determine compliance with an emission standard; C. applicable time and date of each period during which the CEM was inoperative (except for zero and span checks) and the nature of system repairs and adjustments; D. a negative declaration when no excess emissions occurred. [Rule 108 (Kings, Fresno, Merced San Joaquin, Tulare, Kern, and Stanislaus) and Rule 109 (Madera) and District Rule 1080, 8.0] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

20. Sulfur content of gas burned shall not exceed 1.0 gr/100 scf. [District NSR Rule] Federally Enforceable Through Title V Permit

21. Gas turbine engine shall be equipped with continuously recording fuel gas flowmeter. [District Rules 1070 and 4703] Federally Enforceable Through Title V Permit

22. Daily emissions shall not exceed any of the following: PM10: 89.3 lb/day, SOx (as SO2): 29.8 lb/day, NOx (as NO2): 133.9 lb/day, VOC: 245.5 lb/day, or CO: 223.2 lb/day. [District NSR Rule] Federally Enforceable Through Title V Permit

23. Ammonia (NH3) emissions shall not exceed 21 ppmvd @ 15% O2 over a 24-hour average period. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit

24. Ammonia slip shall be calculated as: slip = (a-bxc/1,000,000) x 1,000,000/b, where a=ammonia injection rate(lb/hr)/17(lb/lb.mol), and b=dry exhaust gas flow rate (lb/hr)/29(lb/lb.mol); and c=change in measured NOx concentration in ppmvd at the actual stack oxygen (O2) concentration or by another method approved by the District. [District Rule 4102 and District NSR Rule] Federally Enforceable Through Title V Permit

25. Startup and shutdown of gas turbine engine, as defined in 40 CFR Subpart A 60.2, shall not exceed a time period of two hours and two hours, respectively, per occurrence. [District Rule 4001] Federally Enforceable Through Title V Permit

26. Transitional operation period shall be defined as the start up or shut down time during which the exhaust gas is not within the normal operating temperature range, not to exceed two hours. [District Rule 4703, 3.25] Federally Enforceable Through Title V Permit

27. Except during periods of gas turbine engine startup/shutdown, and transitional operation period, emission rates (three-hour average) shall not exceed any of the following: PM10: 0.012 lb/MMBtu, SOx (as SO2): 0.004 lb/MMBtu; or VOC: 0.033 lb/MMBtu. [District NSR Rule] Federally Enforceable Through Title V Permit

28. Maximum NOx emission rate (one hour average) shall not exceed the NSPS standard of 105 ppmv dry @ 15% O2. [District Rule 4001] Federally Enforceable Through Title V Permit

29. Except during periods of gas turbine engine startup/shutdown, and transitional operation period, emission rates (based on three-hour rolling average) shall not exceed either of the following: NOx (as NO2): 5 ppmv dry @ 15% oxygen (O2); or CO: 13.5 ppmv @ 15% oxygen (O2). [District Rule 4703, 5.1.2, 5.2 and District NSR Rule] Federally Enforceable Through Title V Permit

30. Permittee shall report the following emission exceedences to the District: NOx emission rate on a three-hour average, NSPS NOx emission rate on one hour average, and DEL of NOx during days of gas turbine engine startup/shutdown. [District NSR Rule] Federally Enforceable Through Title V Permit

31. The three-hour average will be compiled from the three most recent one-hour periods, with each one-hour period commencing on the hour. [District Rule 1081] Federally Enforceable Through Title V Permit

32. On days of gas turbine engine startup/shutdown, permittee shall demonstrate compliance with NOx daily emission limitation by records of calculations using CEM data, fuel rate data, and daily hours of operation data. [District NSR Rule] Federally Enforceable Through Title V Permit

33. Permittee shall comply in full with Rule 4001 (New Source Performance Standards) requirements, including notification, recordkeeping and monitoring requirements. [District Rule 4001] Federally Enforceable Through Title V Permit

34. Continuous emissions monitoring system shall conform to Rule 1080 specifications. [District Rule 1080] Federally Enforceable Through Title V Permit

35. Continuous emission monitoring systems shall be calibrated and operated according to EPA guidelines as specified in CFR, Part 60, Appendix B. CEM ppm and lb/hr shall be calculated as a three-hour and a 1 hour average. [District Rules 4001 and 4703] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

36. Annual relative accuracy audits of CEM's shall be conducted by independent laboratory in accordance with EPA guidelines. The District shall be notified of the audit in advance and reports shall be submitted to the District within 60 days of each test. [District Rule 4001] Federally Enforceable Through Title V Permit

37. Permittee shall keep accurate records of turbine daily NOx (as NO2) and oxygen (O2) monitors output for a period of five years, and shall make such records readily available for District inspection upon request. [District Rules 1070 and 2520, 9.5.2] Federally Enforceable Through Title V Permit

38. Compliance source testing for NOx, CO, and O2 shall be conducted at least once every 12 months under conditions representative of normal operation. [District NSR Rule and District Rule 4703, 6.3.1] Federally Enforceable Through Title V Permit

39. Compliance source testing shall be witnessed or authorized by the District. Sample collection shall be done by an ARB certified testing laboratory. [District Rule 1081] Federally Enforceable Through Title V Permit

40. Source test protocol shall be submitted for District approval at least 15 days prior to test date. [District Rule 1081] Federally Enforceable Through Title V Permit

41. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit

42. The following test methods shall be used: NOx - EPA Method 7E or 20 or CARB Method 100; CO - EPA Method 10 or 10B or CARB Method 100; VOC - EPA Method 18 or 25; PM10 - EPA Method 5 (front half and back half) or 201A and 202 or CARB Method 5 (front and back half); ammonia - BAAQMD ST-1B; and O2 - EPA Method 3, 3A, or 20 or CARB Method 100. [40 CFR 60.335(a) and District Rules 2520 and 4703] Federally Enforceable Through Title V Permit

43. Exhaust stack following last economizer shall be of circular cross-section and shall be equipped with permanent provisions to allow collection of stack gas samples consistent with EPA test methods, including flow straighteners, if necessary, to minimize turbulence. [District Rule 1081] Federally Enforceable Through Title V Permit

44. Permittee shall maintain records of all fuel sulfur content testing performed. [District NSR Rule] Federally Enforceable Through Title V Permit

45. Permittee shall maintain daily records of the following: time of start-up(s) and shutdown(s), length and reason for reduced load periods, total hours of operation, and source(s) of and quantity of fuel used. [District Rules 1070 and 4703, 6.2.6] Federally Enforceable Through Title V Permit

46. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.5.2] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1183-0 **EXPIRATION DATE:** 02/28/2017

SECTION: SW39 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
12,012 GALLON FIXED ROOF STORAGE TANK (TANK ID GAUGE TK 2)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1184-0 **EXPIRATION DATE:** 02/28/2017

SECTION: NW09 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
41,580 GALLON FIXED ROOF STORAGE TANK (TANK ID T-24)

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold organic liquid with a true vapor pressure (TVP) of less than 0.5 psia under all storage conditions. [District Rule 4623, 4.4] Federally Enforceable Through Title V Permit
2. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank, or a representative tank as provided in Section 6.2.1.1. of District Rule 4623, at least once every 24 months during summer (July - September), and/or whenever there is a change in the source or type of petroleum stored in this tank. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
3. Instead of testing each uncontrolled fixed roof tank, the permittee may conduct a TVP test of the organic liquid stored in a representative tank provided the requirements of Sections 6.2.1.1.1. through 6.2.1.1.5 of Rule 4623 are met. [District Rule 4623, 6.2.2] Federally Enforceable Through Title V Permit
4. As used in this permit, the term "source or type of petroleum" shall mean petroleum liquids with similar characteristics. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit
5. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API Gravity of Crude Petroleum and Petroleum Products (Hydrometer Method). Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products." [District Rule 4623, 6.4.2] Federally Enforceable Through Title V Permit
6. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "test Method for Vapor pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rule 4623, 6.4.4] Federally Enforceable Through Title V Permit
7. The TVP testing shall be conducted at actual storage temperature of the organic liquid in the tank. The permittee shall also conduct an API gravity testing. [District Rule 4623, 6.2.1.2] Federally Enforceable Through Title V Permit
8. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rule 4623, 6.3.6] Federally Enforceable Through Title V Permit
9. The permittee shall keep accurate records of each organic liquid stored in the tank, including its storage temperature, TVP, and API gravity. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
10. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit

San Joaquin Valley
Air Pollution Control District

PERMIT UNIT: S-1131-1204-0 **EXPIRATION DATE:** 02/28/2017

SECTION: NW 10 **TOWNSHIP:** 29S **RANGE:** 28E

EQUIPMENT DESCRIPTION:
2922 HP EPA TIER 2 DIESEL-FIRED LIMITED-LIFE IC ENGINE

PERMIT UNIT REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. No air contaminant shall be discharged into the atmosphere for a period or periods aggregating more than three minutes in any one hour which is as dark as, or darker than, Ringelmann 1 or 20% opacity. [District Rule 4101] Federally Enforceable Through Title V Permit
3. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. [District Rule 4201] Federally Enforceable Through Title V Permit
4. This engine shall be equipped with an operational non-resettable elapsed time meter or other APCO-approved alternative. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit
5. The exhaust stack shall vent vertically upward. The vertical exhaust flow shall not be impeded by a rain cap (flapper ok), roof overhang, or any other obstruction. [District Rule 4102]
6. IC engine shall not be operated longer than 4.0 hr/day. [District Rule 2201] Federally Enforceable Through Title V Permit
7. Total operation of the IC engine associated with this permit unit shall not exceed 40 hours without prior District approval through issuance of an Authority to Construct. [District Rule 2201] Federally Enforceable Through Title V Permit
8. NOx emissions (referenced as NO2) shall not exceed 4.56 g/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
9. VOC emissions (referenced as methane) shall not exceed 0.24 g/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
10. CO emissions shall not exceed 2.6 g/bhp-hr. [District Rule 2201] Federally Enforceable Through Title V Permit
11. The PM10 emissions rate from the engine shall not exceed 0.15 g/hp-hr based on US EPA certification using ISO 8178 test procedure. [District Rules 2201 and 4102] Federally Enforceable Through Title V Permit
12. Only CARB certified diesel fuel containing not more than 0.0015% sulfur by weight is to be used. [District Rules 2201 and 4801] Federally Enforceable Through Title V Permit
13. During periods of operation, the permittee shall monitor the operational characteristics of the engine as recommended by the manufacturer or emission control system supplier (for example: check engine fluid levels, battery, cables and connections; change engine oil and filters; replace engine coolant; and/or other operational characteristics as recommended by the manufacturer or supplier). [District Rule 4702] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

14. The operator shall maintain records of the daily hours and cumulative hours of operation on a 12 month rolling average. These records shall be updated at least monthly. [District Rules 2201 and 4702] Federally Enforceable Through Title V Permit

15. The permittee shall maintain an engine operating log to demonstrate compliance. The engine operating log shall include, on a monthly basis, the following information: total hours of operation, type of fuel used, maintenance or modifications performed, monitoring data, compliance source test results, and any other information necessary to demonstrate compliance. [District Rule 4702] Federally Enforceable Through Title V Permit

16. All records shall be maintained and retained on-site for a period of at least 5 years and shall be made available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit

ATTACHMENT C

Detailed Facility List

Detailed Facility Report

For Facility=1131 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

CHEVRON USA INC
HEAVY OIL CENTRAL
KERN COUNTY, CA

FAC # S 1131
STATUS: A
TELEPHONE:

TYPE: TitleV
TOXIC ID: 50220

EXPIRE ON: 02/28/2017
AREA: 102 / 315
INSP. DATE: 05/18

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1131-62-29	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-38; DIS# 20630-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN MODEL GLE LOW-NOX BURNER, AND NORTH AMERICAN OPTIMIZER
S-1131-63-24	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG#60-39, DIS#20631-79) WITH NORTH AMERICAN GLE LOW-NOX BURNER, FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)
S-1131-64-24	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-40; DIS# 20632-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN GLE LOW-NOX BURNER AND NORTH AMERICAN OPTIMIZER
S-1131-65-30	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-41; DIS# 20633-79) WITH NORTH AMERICAN GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) (SAN JOAQUIN LOWER)
S-1131-66-23	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-42; DIS# 20634-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN GLE LOW-NOX BURNER AND NORTH AMERICAN OPTIMIZER. (SAN JOAQUIN LOWER)
S-1131-67-24	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR C.E. NATCO NATURAL GAS-FIRED STEAM GENERATOR (HSG# 60-43; DIS# 20635-79) WITH FLUE GAS RECIRCULATION AND A NORTH AMERICAN GLE LOW-NOX BURNER (SAN JOAQUIN LOWER)
S-1131-68-23	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR C.E. NATCO NATURAL GAS-FIRED STEAM GENERATOR (HSG# 60-44; DIS# 20636-79) WITH FLUE GAS RECIRCULATION AND A NORTH AMERICAN GLE LOW-NOX BURNER (SAN JOAQUIN LOWER)
S-1131-69-23	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-45; DIS# 20637-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN GLE LOW-NOX BURNER AND NORTH AMERICAN OPTIMIZER. (SAN JOAQUIN LOWER)
S-1131-70-23	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-46; DIS# 20638-79) WITH A NORTH AMERICAN MAGNA FLAME GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)
S-1131-73-23	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-49; DIS# 20641-79) WITH A NORTH AMERICAN MAGNA FLAME GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (SAN JOAQUIN LOWER)

Detailed Facility Report

For Facility=1131 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1131-77-23	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-67; DIS# 20611-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN, MODEL #5131-HGCR-62. 5, BURNER AND NORTH AMERICAN OPTIMIZER. (CANFIELD LEASE)
S-1131-78-29	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-69; DIS# 20610-79) WITH A NORTH AMERICAN MAGNA FLAME GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION ((MCNTE CRISTO 1 LEASE)
S-1131-82-26	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED C.E. NATCO STEAM GENERATOR (HSG# 60-68; DIS# 20643-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN MODEL GLE MAGNA-FLAME (OR DISTRICT APPROVED EQUIVALENT), AND NORTH AMERICAN OPTIMIZER - SJ LOWER
S-1131-94-27	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STRUTHERS STEAM GENERATOR (HSG# 70-08; DIS# 20627-81) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN, MODEL #5131-HGCR-62. 5, BURNER AND NORTH AMERICAN OPTIMIZER (CANFIELD LEASE)
S-1131-95-23	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS/GAS FIRED STRUTHERS STEAM GENERATOR (HSG# 70-31; DIS# 20642-79) WITH A NORTH AMERICAN MODEL GLE MAGNA-FLAME LOW NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM AND NORTH AMERICAN OPTIMIZER - SJ LOWER
S-1131-98-26	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (HSG# 70-44; DIS# 20608-82) WITH A NORTH AMERICAN MODEL #GLE-4231 LOW NOX BURNER AND FLUE GAS RECIRCULATION
S-1131-99-26	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (HSG# 70-45; DIS# 20609-82) WITH A NORTH AMERICAN MODEL #GLE-4231 LOW NOX BURNER AND FLUE GAS RECIRCULATION
S-1131-509-5	21,000 gallon	3020-05 C	1	149.00	149.00	A	500 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #TK3-7
S-1131-592-4	373,380 gallon	3020-05 E	1	270.00	270.00	A	8,890 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, S. PROCESS WASH TANK
S-1131-594-8	190,260 gallons	3020-05 E	1	270.00	270.00	A	4,530 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK. SETTLING #37
S-1131-598-45	1,806,000 gallons	3020-05 G	1	419.00	419.00	A	43,000 BBL FIXED ROOF SURGE TANK #5 (STATION 36) WITH GAS BLANKETING AND VAPOR CONTROL SYSTEM INCLUDING SULFUR REMOVAL SYSTEM AND DISCHARGING TO INCINERATING STEAM GENERATORS, STATION 36 TVR SYSTEM AND TEOR SYSTEM S-1131-1127, OR DOGGR APPROVED VAPOR DISPOSAL WELLS

Detailed Facility Report

For Facility=1131 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1131-599-8	227,200 gallons	3020-05 E	1	270.00	270.00	A	5,410 BBL FIXED-ROOF CRUDE OIL WASH TANK #1-A AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-600-4	248,640 gallons	3020-05 E	1	270.00	270.00	A	5,920 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #6600 S OT
S-1131-601-4	248,640 gallons	3020-05 E	1	270.00	270.00	A	5,920 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #6600 N OT
S-1131-602-4	373,380 gallons	3020-05 E	1	270.00	270.00	A	8,890 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, N. PROCESS WASH TANK
S-1131-603-8	187,740 gallons	3020-05 E	1	270.00	270.00	A	4,470 BBL FIXED-ROOF CRUDE OIL SETTLING TANK #43 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-606-8	187,740 gallons	3020-05 E	1	270.00	270.00	A	4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #42 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-608-23	420,000 gallons	3020-05 E	1	270.00	270.00	A	10,000 BBL 55' DIA X 24' HIGH FIXED ROOF CRUDE OIL PRODUCTION TANK, SHIPPING #41 (STATION 36) VENTED TO VAPOR CONTROL SYSTEM LISTED ON S-1131-598
S-1131-610-8	190,260 gallons	3020-05 E	1	270.00	270.00	A	4,530 BBL FIXED ROOF CRUDE OIL SETTLING TANK #20 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-613-21	420,000 gallons	3020-05 E	1	270.00	270.00	A	10,000 BBL 55' DIA X 24' HIGH FIXED ROOF CRUDE OIL PRODUCTION TANK, SHIPPING #40 (STATION 36) VENTED TO VAPOR CONTROL SYSTEM LISTED ON S-1131-598
S-1131-615-8	227,220 gallons	3020-05 E	1	270.00	270.00	A	5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #2-B AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-619-8	227,220 gallons	3020-05 E	1	270.00	270.00	A	5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #1-B AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-620-8	227,220 gallon	3020-05 E	1	270.00	270.00	A	5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #2 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-621-8	187,740 gallons	3020-05 E	1	270.00	270.00	A	4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #45 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

Detailed Facility Report

For Facility=1131 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1131-622-4	2,203,320 gallons	3020-05 G	1	419.00	419.00	A	52,460 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #60GK2
S-1131-623-8	187,740 gallons	3020-05 E	1	270.00	270.00	A	4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #44 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-625-8	187,740 gallons	3020-05 E	1	270.00	270.00	A	4,470 BBL FIXED ROOF CRUDE OIL SETTLING TANK #46 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-626-8	373,380 gallons	3020-05 E	1	270.00	270.00	A	8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-2 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-627-8	373,380 gallons	3020-05 E	1	270.00	270.00	A	8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-3 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-628-8	373,380 gallons	3020-05 E	1	270.00	270.00	A	8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-1 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-629-13	1,579,200 gallons	3020-05 G	1	419.00	419.00	A	37,600 BBL FIXED ROOF CRUDE SURGE TANK #6 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598
S-1131-630-13	1,579,200 gallons	3020-05 G	1	419.00	419.00	A	1,579,200 GALLON FIXED ROOF CRUDE SURGE TANK #7 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598
S-1131-631-8	227,220 gallons	3020-05 E	1	270.00	270.00	A	5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #1 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-632-8	373,380 gallons	3020-05 E	1	270.00	270.00	A	8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-5 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-633-8	373,380 gallons	3020-05 E	1	270.00	270.00	A	8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-6 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-634-8	373,380 gallons	3020-05 E	1	270.00	270.00	A	8,890 BBL FIXED ROOF CRUDE OIL WASH TANK #10-4 AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS

Detailed Facility Report

For Facility=1131 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1131-635-8	227,220 gallons	3020-05 E	1	270.00	270.00	A	5,410 BBL FIXED ROOF CRUDE OIL WASH TANK #2-A AUTHORIZED FOR RECEIPT OF FLUIDS FROM STATION 36 "SURGE" TANKS RECEIVING PRODUCTION FROM STEAM-ENHANCED WELLS WITH CLOSED WELL CASING VENTS
S-1131-636-4	443,940 gallons	3020-05 E	1	270.00	270.00	A	10,570 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK, #10000 SHIP
S-1131-638-13	1,579,200 gallons	3020-05 G	1	419.00	419.00	A	37,600 BBL FIXED ROOF CRUDE SURGE TANK #2 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598
S-1131-641-13	1,579,200 gallons	3020-05 G	1	419.00	419.00	A	37,600 BBL FIXED ROOF CRUDE SURGE TANK #1 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598
S-1131-650-13	1,579,200 gallons	3020-05 G	1	419.00	419.00	A	37,600 BBL FIXED ROOF CRUDE SURGE TANK #4 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598
S-1131-651-13	1,579,200 gallons	3020-05 G	1	419.00	419.00	A	37,600 BBL FIXED ROOF CRUDE SURGE TANK #3 (STATION 36) WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-598
S-1131-652-4	2,287,320 gallons	3020-05 G	1	419.00	419.00	A	54,460 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #60GK1
S-1131-663-4	10,500 gallons	3020-05 B	1	103.00	103.00	A	250 BBL FIXED ROOF CRUDE OIL PRODUCTION TANK #TK2-4
S-1131-716-25	11,047 Wells without vapor recovery	3020-09 B	1468	10.23	1,533.00	A	TEOR OPERATION WITH 12,547 STEAM ENHANCED OIL PRODUCTION WELLS WITH CLOSED CASING VENTS PRODUCING TO TANKS WITH VAPOR CONTROL
S-1131-724-4	3 nozzles x 1 grade per nozzle	3020-11 B	3	38.00	114.00	A	GASOLINE DISPENSING OPERATION WITH TWO 10,000 GALLON UNDERGROUND STORAGE TANKS SERVED BY OPW PHASE I ENHANCED VAPOR RECOVERY SYSTEM (VR-102-A), AND THREE FUELING POINTS WITH THREE GASOLINE DISPENSING NOZZLES SERVED BY HEALY PHASE II ENHANCED VAPOR RECOVERY SYSTEM WITHOUT ISD (VR-201-E) (KERN RIVER)
S-1131-833-3	240 bhp IC engine	3020-10 C	1	264.00	264.00	A	240 BHP DIESEL-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR
S-1131-858-12	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED NATIONAL STEAM GENERATOR (HSG# 50-43; DIS# 20628-79) WITH FLUE GAS RECIRCULATION, NORTH AMERICAN MODEL #5131-HGCR-62.5 BURNER, AND NORTH AMERICAN OPTIMIZER - (CANFIELD LEASE)
S-1131-859-13	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (HSG# 50-51; DIS# 19161- 75) WITH A NORTH AMERICAN MODEL GLE MAGNA-FLAME, LOW NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM AND NORTH AMERICAN OPTIMIZER (SAN JOAQUIN LOWER)
S-1131-877-23	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MM BTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS FIRED STRUTHERS STEAM GENERATOR #46 WITH FGR, NORTH AMERICAN MODEL GLE 4231 BURNER AND O2 CONTROLLER (MONTE CRISTO 1 LEASE)

Detailed Facility Report

For Facility=1131 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1131-879-24	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN GLE LOW-NOX BURNER WITH FGR AND AN O2 CONTROLLER (#70, CENTRAL PLANT)
S-1131-880-17	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR #140 WITH A NORTH AMERICAN MODEL #GLE-4231 LOW-NOX BURNER AND FLUE GAS RECIRCULATION (CENTRAL PLANT)
S-1131-881-18	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN GLE LOW-NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) AND AN O2 CONTROLLER (CENTRAL PLANT)
S-1131-883-18	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MM BTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS FIRED STRUTHERS STEAM GENERATOR (#143) WITH A NORTH AMERICAN MODEL GLE MAGNA-FLAME LOW NOX BURNER, FLUE GAS RECIRCULATION (FGR) SYSTEM AND O2 CONTROLLER (CENTRAL PLANT)
S-1131-884-20	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MM BTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STRUTHERS STEAM GENERATOR #144 EQUIPPED WITH NORTH AMERICAN MAGNA-FLAME GLE ULTRA LOW NOX BURNER AND FLUE GAS RECIRCULATION. (CENTRAL PLANT)
S-1131-885-30	210,000 gallons	3020-05 E	1	270.00	270.00	A	5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK #3K-L75 WITH VAPOR CONTROL SYSTEM
S-1131-886-22	210,000 gallons	3020-05 E	1	270.00	270.00	A	5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK #3K-S76 WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-885
S-1131-891-21	210,000 gallons	3020-05 E	1	270.00	270.00	A	5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-885
S-1131-892-21	210,000 gallons	3020-05 E	1	270.00	270.00	A	5,000 BBL FIXED ROOF PETROLEUM STORAGE TANK WITH VAPOR CONTROL SYSTEM LISTED ON S-1131-885
S-1131-908-21	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MM BTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS FIRED STRUTHERS STEAM GENERATOR (#71) WITH A NORTH AMERICAN GLE LOW-NOX BURNER, A FLUE GAS RECIRCULATION SYSTEM (FGR), AND O2 CONTROLLER
S-1131-912-7	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS FIRED STEAM GENERATOR WITH A NORTH AMERICAN GLE LOW-NOX BURNER AND A FLUE GAS RECIRCULATION (FGR) SYSTEM (RASMUSSEN LEASE)
S-1131-943-19	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR GAS-FIRED STEAM GENERATOR (FEE A 2), WITH NORTH AMERICAN GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR)
S-1131-966-13	27.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT EMISSIONS UNIT: 27.5 MMBTU/HR THERMOTICS VAPOR CONTROL/NATURAL GAS-FIRED STEAM GENERATOR #24 WITH FLUE GAS RECIRCULATION AMETEK THERMOX O2 CONTROLLER (FEE C LEASE)

Detailed Facility Report

For Facility=1131 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1131-976-10	23 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 23 MMBTU/HR STRUTHERS GAS-FIRED STEAM GENERATOR WITH FLUE GAS RECIRCULATION AND OXYGEN CONTROLLER/ANALYZER (#13, DIS # 27537-66)
S-1131-987-13	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR THERMOTICS GAS/CASING GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL GLE MAGNA-FLAME LOW NOX BURNER, OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (FGR) SYSTEM (R-3, DIS# 27474-81)
S-1131-992-15	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR THERMOTICS GAS/CASING GAS-FIRED STEAM GENERATOR WITH OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (PRICEWELL, #P-9, DIS# 27472-81)
S-1131-993-14	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH OXYGEN CONTROLLER/ANALYZER, FLUE GAS RECIRCULATION (PRICEWELL, P-3, DIS# 28773-85)
S-1131-994-10	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH LO-NOX BURNER, OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (MCMANUS, PL-8, DIS# 4322-78)
S-1131-997-12	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR THERMOTICS NATURAL GAS/CASING GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL GLE MAGNA-FLAME BURNER WITH FLUE GAS RECIRCULATION (FGR) AND AN OXYGEN CONTROLLER/ANALYZER (ANGUS 2, DIS# 4509-81)
S-1131-998-14	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN GLE LOW-NOX BURNERS, OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (HOPCO, H-2, DIS# 39454-87)
S-1131-999-9	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN MODEL GLE MAGNA-FLAME (OR DISTRICT APPROVED EQUIVALENT), OXYGEN CONTROLLER/ANALYZER, FLUE GAS RECIRCULATION (RAMBLER, R-7, DIS# 12466-82)
S-1131-1000-14	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN GLE LOW-NOX BURNERS, OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (RAMBLER, R-8, DIS# 12468-82)
S-1131-1001-15	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR W/OXYGEN CONTROLLER/ANALYZER, FLUE GAS RECIRCULATION (CHINA 3, DIS#12467-82
S-1131-1002-15	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH A NORTH AMERICAN MODEL GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (HOPCO, H-3, DIS# 39455-87)
S-1131-1003-14	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN GLE LOW-NOX BURNERS, OXYGEN CONTROLLER/ANALYZER AND FLUE GAS RECIRCULATION (HOPCO, H-3, DIS# 39455-87)

Detailed Facility Report

For Facility=1131 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1131-1004-14	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR W/ OXYGEN CONTROLLER/ANALYZER, FLUE GAS RECIRCULATION (PRICEWELL, H-4)
S-1131-1016-15	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR C.E. NATCO GAS/CASING GAS-FIRED STEAM GENERATOR NORTH AMERICAN BURNER (MODEL NA 5131GCR-62.5) AND FLUE GAS RECIRCULATION (ANGUS)
S-1131-1036-12	885 TEOR wells without vapor recovery	3020-09 B	885	10.23	1,533.00	A	TEOR OPERATION WITH 885 THERMALLY ENHANCED WELLS WITH CLOSED CASING VENTS
S-1131-1037-9	20,000 kW electric generation	3020-08A F	1	8,941.00	8,941.00	A	249.0 MMBTU/HR (NOMINAL RATING) 20 MW GENERAL ELECTRIC GAS-FIRED TURBINE ENGINE COGENERATION SYSTEM WITH SCR, AMMONIA STORAGE AND DISTRIBUTION SYSTEM, CO CATALYTIC CONVERTER AND CEM SYSTEM FOR NOX, CO AND O2
S-1131-1038-8	4 MW	3020-08A C	1	1,678.00	1,678.00	A	DORMANT 58.2 MMBTU/HR (NOMINAL RATING), 4.0 MW ALLISON MODEL 501-KB5 GAS-FIRED TURBINE ENGINE COGENERATION SYSTEM WITH WATER INJECTION, HEAT RECOVERY STEAM GENERATOR, AND CEM SYSTEMS FOR NOX, CO, AND O2
S-1131-1039-8	4 MW	3020-08A C	1	1,678.00	1,678.00	A	DORMANT 58.2 MMBTU/HR (NOMINAL RATING), 4.0 MW ALLISON MODEL 501-KB5 GAS-FIRED TURBINE ENGINE COGENERATION SYSTEM WITH WATER INJECTION, HEAT RECOVERY STEAM GENERATOR, AND CEM SYSTEMS FOR NOX, CO, AND O2
S-1131-1084-3	83 bhp	3020-10 A	1	88.00	88.00	A	83 BHP FORD MODEL CGS-649 4.9 LITER 6-CYLINDER NATURAL GAS-FIRED EMERGENCY STANDBY IC ENGINE POWERING AN ELECTRICAL GENERATOR
S-1131-1085-8	83.3 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	83.3 MMBTU/HR AIR-ASSISTED STANDBY FLARE WITH AUTOMATIC ELECTRONIC IGNITOR, NATURAL GAS AUXILIARY FUEL, AND NATURAL GAS OR PROPANE PILOT ASSEMBLY (RAMBLER LEASE)
S-1131-1086-3	83.3 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	83.3 MMBTU/HR AIR-ASSISTED STANDBY FLARE WITH AUTOMATIC ELECTRONIC IGNITOR, AND NATURAL GAS OR PROPANE PILOT ASSEMBLY, OPERATED AT VARIOUS UNSPECIFIED LOCATIONS WITHIN THE KERN RIVER OIL FIELD
S-1131-1087-2	83.3 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	83.3 MMBTU/HR AIR-ASSISTED STANDBY FLARE WITH AUTOMATIC ELECTRONIC IGNITOR, AND NATURAL GAS OR PROPANE PILOT ASSEMBLY OPERATED AT VARIOUS SPECIFIED LOCATIONS WITHIN THE KERN RIVER OIL FIELD.
S-1131-1091-3	1,650 gallons	3020-05 A	1	83.00	83.00	A	1,650 GALLON TRANSPORTABLE CHEMICAL STORAGE TANK
S-1131-1097-9	1,806,000 gallons	3020-05 G	1	419.00	419.00	A	43,000 BBL FIXED ROOF CRUDE OIL SURGE TANK #8 SERVED BY VAPOR RECOVERY SYSTEM LISTED ON S-1131-598
S-1131-1106-18	140 wells with vapor control	3020-09 A	140	10.23	1,432.20	A	TEOR OPERATION CONSISTING OF 140 STEAM-ENHANCED CRUDE OIL PRODUCTION WELLS WITH VAPOR CONTROL SYSTEM INCLUDING ELECTRIC COMPRESSOR(S) AND HIGH POINT SEPARATOR(S) CONNECTED TO STATION 36 PRODUCTION LINE (S-1131-598), FLARE S-1131-1086, FLARE S-1131-1087 OR FLARE S-1131-1108

Detailed Facility Report

For Facility=1131 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1131-1108-2	83.0 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	83.0 MMBTU/HR AIR ASSISTED LOW USE FLARE WITH AUTOMATIC IGNITION AND NATURAL GAS PILOT ASSEMBLY OPERATED AT MULTIPLE SPECIFIED LOCATIONS WITHIN CHEVRON USA'S HEAVY OIL CENTRAL STATIONARY SOURCE
S-1131-1117-2	480 bhp	3020-10 D	1	525.00	525.00	A	480 HP CATERPILLAR MODEL C9 DIESEL-FIRED EMERGENCY IC ENGINE POWERING AN ELECTRICAL GENERATOR
S-1131-1119-5	532 bhp	3020-10 D	1	525.00	525.00	A	EPA-TIER 3 CERTIFIED DIESEL-FIRED TRANSPORTABLE IC ENGINE UPTO 532 HP POWERING MECHANICAL PUMP, COMPRESSOR, OR ELECTRICAL GENERATOR
S-1131-1120-1	1000 GAL	3020-05 A	1	83.00	83.00	A	1000 GALLON OIL TREATMENT CHEMICAL TANK
S-1131-1127-2	60 steam enhanced wells	3020-09 A	60	10.23	613.80	A	THERMALLY ENHANCED OIL RECOVERY OPERATION (TEOR) SERVING UP TO 60 STEAM ENHANCED WELLS WITH WELL VENT COLLECTION AND CONTROL SYSTEM VENTED TO STATION 36 TVR SYSTEM S-1131-598 (MCWORTER LEASE)
S-1131-1134-0	85 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	85 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN MODEL 4231-85-GLE LOW-NOX BURNER ASSEMBLY, OR EQUIVALENT LOW-NOX BURNER, WITH FLUE GAS RECIRCULATION, APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS
S-1131-1135-0	85 MMBTU/hr	3020-02 H	1	1,128.00	1,128.00	A	85 MMBTU/HR NATURAL GAS-FIRED STEAM GENERATOR WITH NORTH AMERICAN MODEL 4231-85-GLE LOW-NOX BURNER ASSEMBLY, OR EQUIVALENT LOW-NOX BURNER, WITH FLUE GAS RECIRCULATION, APPROVED TO OPERATE AT VARIOUS SPECIFIED LOCATIONS
S-1131-1140-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (34-3, DIS #43006-74) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1131-1141-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 40-32, DIS# 43001-75)
S-1131-1142-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (43-9, DIS# 43010-75) WITH NORTH AMERICAN MODEL #GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1131-1143-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR 44-9, DIS #43007-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1131-1144-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (45-9, DIS #43008-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM

Detailed Facility Report

For Facility=1131 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1131-1145-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (46-9, DIS #43009-75) WITH NORTH AMERICAN MODEL GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1131-1146-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (49-5, DIS# 43003-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1131-1147-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (50-5, DIS# 4005-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1131-1148-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (51-5, DIS #43004-76) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1131-1149-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (35-3, DIS# 43007-74) A NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1131-1150-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID #36-3, DIS# 43008-74)
S-1131-1151-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 42-3, DIS# 43003-75)
S-1131-1152-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 65-3, DIS# 43006-80)
S-1131-1153-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (67-3, DIS# 43008-80) WITH NORTH AMERICAN GLE 1 LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1131-1154-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (64-9, DIS# 43005-80) WITH NORTH AMERICAN GLE LOW NOX BURNER WITH FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1131-1155-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (81-4, DIS# 43013-82) WITH NORTH AMERICAN GLE LOW-NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM (MONTE CRISTO 1 LEASE)
S-1131-1156-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	62.5 MMBTU/HR STRUTHERS NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR (80-4, DIS #43010-82) WITH NORTH AMERICAN GLE LOW NOX BURNER AND FLUE GAS RECIRCULATION (FGR) SYSTEM
S-1131-1157-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS FIRED STEAM GENERATOR (CUSA ID# 79-4, DIS# 43009-82)

Detailed Facility Report

For Facility=1131 and excluding Deleted Permits
Sorted by Facility Name and Permit Number

PERMIT NUMBER	FEE DESCRIPTION	FEE RULE	QTY	FEE AMOUNT	FEE TOTAL	PERMIT STATUS	EQUIPMENT DESCRIPTION
S-1131-1158-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 53-32, DIS# 43012-78)
S-1131-1159-0	62.5 MMBtu/hr	3020-02 H	1	1,128.00	1,128.00	A	NON-COMPLIANT DORMANT 62.5 MMBTU/HR NATURAL GAS/VAPOR RECOVERY GAS-FIRED STEAM GENERATOR WITH LOW PRESSURE FUEL INDUCED RECIRCULATION (CUSA ID# 77-32, DIS# 43011-82)
S-1131-1160-0	22,300 kW turbine	3020-08A F	1	8,941.00	8,941.00	A	22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT A, DIS# 47003-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL
S-1131-1161-0	22,300 kW turbine	3020-08A F	1	8,941.00	8,941.00	A	22.3 MW NOMINAL RATING COMBINED CYCLE COGENERATION UNIT B, DIS# 47004-88, INCLUDING GAS-FIRED GE LM-2500-PE TURBINE WITH NOMINAL RATING INPUT OF 240 MMBTU/HR AND SCR FOR NOX CONTROL
S-1131-1183-0	12,012 GALLONS	3020-05 B	1	103.00	103.00	A	12,012 GALLON FIXED ROOF STORAGE TANK (TANK ID GAUGE TK 2)
S-1131-1184-0	41,580 GALLONS	3020-05 C	1	149.00	149.00	A	41,580 GALLON FIXED ROOF STORAGE TANK (TANK ID T-24)
S-1131-1204-0	2922 hp	3020-10 F	1	820.00	820.00	A	2922 HP EPA TIER 2 DIESEL-FIRED LIMITED-LIFE IC ENGINE

Number of Facilities Reported: 1