



June 25, 2020

Ms. Valerie Muller
San Pablo Bay Pipeline Company, LLC.
3760 Kilroy Airport Way, Suite 300
Long Beach, CA 90806

Re: Notice of Final Action - Title V Permit Renewal
Facility Number: S-1413
Project Number: S-1193936

Dear Ms. Muller:

The District has issued the Final Renewed Title V Permit for San Pablo Bay Pipeline Company, LLC. (see enclosure). The preliminary decision for this project was made on April 14, 2020. No comments were received subsequent to the District preliminary decision.

The public notice for issuance of the Final Title V Permit will be posted on the District's website (www.valleyair.org).

Thank you for your cooperation in this matter. If you have any questions, please contact Mr. Leonard Scandura, Permit Services Manager, at (661) 392-5500.

Sincerely,


Arnaud Marjollet
Director of Permit Services

Enclosures

cc: Courtney Graham, CARB (w/enclosure) via email
cc: Gerardo C. Rios, EPA (w/enclosure) via EPS

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585



Facility # S-1413
SAN PABLO BAY PIPELINE COMPANY LLC
3760 KILROY AIRPORT WAY, SUITE 300
LONG BEACH, CA 90806

Notice of Permit Issuance

The enclosed permit unit requirements authorize the operation of the equipment as described. These permit unit requirements supersede any and all previous permits for the specified equipment.* Please insert these documents into the Facility Permit to Operate, and post copies on or near the equipment as required by District Rule 2010.

Please contact any of our Small Business Assistance (SBA) staff at the numbers below if you have any questions:

Modesto: (209) 557-6446
Fresno: (559) 230-5888
Bakersfield: (661) 392-5665

*Failure to comply with the permit unit requirements may result in enforcement action.

Samir Sheikh
Executive Director/Air Pollution Control Officer

Northern Region
4800 Enterprise Way
Modesto, CA 95356-8718
Tel: (209) 557-6400 FAX: (209) 557-6475

Central Region (Main Office)
1990 E. Gettysburg Avenue
Fresno, CA 93726-0244
Tel: (559) 230-6000 FAX: (559) 230-6061

Southern Region
34946 Flyover Court
Bakersfield, CA 93308-9725
Tel: (661) 392-5500 FAX: (661) 392-5585

Permit to Operate

FACILITY: S-1413

EXPIRATION DATE: 04/30/2025

LEGAL OWNER OR OPERATOR:

SAN PABLO BAY PIPELINE COMPANY LLC

MAILING ADDRESS:

3760 KILROY AIRPORT WAY, SUITE 300
LONG BEACH, CA 90806

FACILITY LOCATION:

BAKERSFIELD PUMP STATION
1801 PETROL RD
BAKERSFIELD, CA 93308-9793

FACILITY DESCRIPTION:

PIPELINE PUMP STATION

The Facility's Permit to Operate may include Facility-wide Requirements as well as requirements that apply to specific permit units.

This Permit to Operate remains valid through the permit expiration date listed above, subject to payment of annual permit fees and compliance with permit conditions and all applicable local, state, and federal regulations. This permit is valid only at the location specified above, and becomes void upon any transfer of ownership or location. Any modification of the equipment or operation, as defined in District Rule 2201, will require prior District approval. This permit shall be posted as prescribed in District Rule 2010.

Samir Sheikh
Executive Director / APCO

Arnaud Marjollet
Director of Permit Services

San Joaquin Valley

Air Pollution Control District

FACILITY: S-1413-0-4

EXPIRATION DATE: 04/30/2025

FACILITY-WIDE REQUIREMENTS

1. No air contaminant shall be released into the atmosphere which causes a public nuisance. [District Rule 4102]
2. The owner or operator shall notify the District of any breakdown condition as soon as reasonably possible, but no later than one hour after its detection, unless the owner or operator demonstrates to the District's satisfaction that the longer reporting period was necessary. [District Rule 1100, 6.1; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
3. The District shall be notified in writing within ten days following the correction of any breakdown condition. The breakdown notification shall include a description of the equipment malfunction or failure, the date and cause of the initial failure, the estimated emissions in excess of those allowed, and the methods utilized to restore normal operations. [District Rule 1100, 7.0; County Rules 110 (Fresno, Stanislaus, San Joaquin); 109 (Merced); 113 (Madera); and 111 (Kern, Tulare, Kings)] Federally Enforceable Through Title V Permit
4. The owner or operator of any stationary source operation that emits more than 25 tons per year of nitrogen oxides or reactive organic compounds, shall provide the District annually with a written statement in such form and at such time as the District prescribes, showing actual emissions of nitrogen oxides and reactive organic compounds from that source. [District Rule 1160, 5.0] Federally Enforceable Through Title V Permit
5. Any person building, altering or replacing any operation, article, machine, equipment, or other contrivance, the use of which may cause the issuance of air contaminants or the use of which may eliminate, reduce, or control the issuance of air contaminants, shall first obtain an Authority to Construct (ATC) from the District unless exempted by District Rule 2020 (12/20/07). [District Rule 2010, 3.0 and 4.0; and 2020] Federally Enforceable Through Title V Permit
6. The permittee must comply with all conditions of the permit including permit revisions originated by the District. All terms and conditions of a permit that are required pursuant to the Clean Air Act (CAA), including provisions to limit potential to emit, are enforceable by the EPA and Citizens under the CAA. Any permit noncompliance constitutes a violation of the CAA and the District Rules and Regulations, and is grounds for enforcement action, for permit termination, revocation, reopening and reissuance, or modification; or for denial of a permit renewal application. [District Rules 2070, 7.0; 2080; and 2520, 9.8.1 and 9.13.1] Federally Enforceable Through Title V Permit
7. A Permit to Operate or an Authority to Construct shall not be transferred unless a new application is filed with and approved by the District. [District Rule 2031] Federally Enforceable Through Title V Permit
8. Every application for a permit required under Rule 2010 (12/17/92) shall be filed in a manner and form prescribed by the District. [District Rule 2040] Federally Enforceable Through Title V Permit
9. The operator shall maintain records of required monitoring that include: 1) the date, place, and time of sampling or measurement; 2) the date(s) analyses were performed; 3) the company or entity that performed the analysis; 4) the analytical techniques or methods used; 5) the results of such analysis; and 6) the operating conditions at the time of sampling or measurement. [District Rule 2520, 9.4.1] Federally Enforceable Through Title V Permit
10. The operator shall retain records of all required monitoring data and support information for a period of at least 5 years from the date of the monitoring sample, measurement, or report. Support information includes copies of all reports required by the permit and, for continuous monitoring instrumentation, all calibration and maintenance records and all original strip-chart recordings. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate. Any amendments to these Facility-wide Requirements that affect specific Permit Units may constitute modification of those Permit Units.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-0-4 : Jun 22 2020 1:24PM -- PROCOPIIS

11. The operator shall submit reports of any required monitoring at least every six months unless a different frequency is required by an applicable requirement. All instances of deviations from permit requirements must be clearly identified in such reports. [District Rule 2520, 9.5.1] Federally Enforceable Through Title V Permit
12. Deviations from permit conditions must be promptly reported, including deviations attributable to upset conditions, as defined in the permit. For the purpose of this condition, promptly means as soon as reasonably possible, but no later than 10 days after detection. The report shall include the probable cause of such deviations, and any corrective actions or preventive measures taken. All required reports must be certified by a responsible official consistent with section 10.0 of District Rule 2520 (6/21/01). [District Rules 2520, 9.5.2 and 1100, 7.0] Federally Enforceable Through Title V Permit
13. If for any reason a permit requirement or condition is being challenged for its constitutionality or validity by a court of competent jurisdiction, the outcome of such challenge shall not affect or invalidate the remainder of the conditions or requirements in that permit. [District Rule 2520, 9.7] Federally Enforceable Through Title V Permit
14. It shall not be a defense for a permittee in an enforcement action that it would have been necessary to halt or reduce the permitted activity in order to maintain compliance with the conditions of the permit. [District Rule 2520, 9.8.2] Federally Enforceable Through Title V Permit
15. The permit may be modified, revoked, reopened and reissued, or terminated for cause. The filing of a request by the permittee for a permit modification, revocation and reissuance, or termination, or a notification of planned changes or anticipated noncompliance does not stay any permit condition. [District Rule 2520, 9.8.3] Federally Enforceable Through Title V Permit
16. The permit does not convey any property rights of any sort, or any exclusive privilege. [District Rule 2520, 9.8.4] Federally Enforceable Through Title V Permit
17. The Permittee shall furnish to the District, within a reasonable time, any information that the District may request in writing to determine whether cause exists for modifying, revoking and reissuing, or terminating the permit or to determine compliance with the permit. Upon request, the permittee shall also furnish to the District copies of records required to be kept by the permit or, for information claimed to be confidential, the permittee may furnish such records directly to EPA along with a claim of confidentiality. [District Rule 2520, 9.8.5] Federally Enforceable Through Title V Permit
18. The permittee shall pay annual permit fees and other applicable fees as prescribed in Regulation III of the District Rules and Regulations. [District Rule 2520, 9.9] Federally Enforceable Through Title V Permit
19. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to enter the permittee's premises where a permitted source is located or emissions related activity is conducted, or where records must be kept under condition of the permit. [District Rule 2520, 9.13.2.1] Federally Enforceable Through Title V Permit
20. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to have access to and copy, at reasonable times, any records that must be kept under the conditions of the permit. [District Rule 2520, 9.13.2.2] Federally Enforceable Through Title V Permit
21. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to inspect at reasonable times any facilities, equipment, practices, or operations regulated or required under the permit. [District Rule 2520, 9.13.2.3] Federally Enforceable Through Title V Permit
22. Upon presentation of appropriate credentials, a permittee shall allow an authorized representative of the District to sample or monitor, at reasonable times, substances or parameters for the purpose of assuring compliance with the permit or applicable requirements. [District Rule 2520, 9.13.2.4] Federally Enforceable Through Title V Permit
23. No air contaminants shall be discharged into the atmosphere for a period or periods aggregating more than 3 minutes in any one hour which is as dark or darker than Ringelmann #1 or equivalent to 20% opacity and greater, unless specifically exempted by District Rule 4101 (02/17/05). If the equipment or operation is subject to a more stringent visible emission standard as prescribed in a permit condition, the more stringent visible emission limit shall supersede this condition. [District Rule 4101, and County Rules 401 (in all eight counties in the San Joaquin Valley)] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

24. No person shall manufacture, blend, repackage, supply, sell, solicit or apply any architectural coating with a VOC content in excess of the corresponding limit specified in Table of Standards 1 effective until 12/30/10 or Table of Standards 2 effective on and after 1/1/11 of District Rule 4601 (12/17/09) for use or sale within the District. [District Rule 4601, 5.1] Federally Enforceable Through Title V Permit
25. All VOC-containing materials subject to Rule 4601 (12/17/09) shall be stored in closed containers when not in use. [District Rule 4601, 5.4] Federally Enforceable Through Title V Permit
26. The permittee shall comply with all the Labeling and Test Methods requirements outlined in Rule 4601 sections 6.1 and 6.3 (12/17/09). [District Rule 4601, 6.1 and 6.3] Federally Enforceable Through Title V Permit
27. With each report or document submitted under a permit requirement or a request for information by the District or EPA, the permittee shall include a certification of truth, accuracy, and completeness by a responsible official. [District Rule 2520, 9.13.1 and 10.0] Federally Enforceable Through Title V Permit
28. If the permittee performs maintenance on, or services, repairs, or disposes of appliances, the permittee shall comply with the standards for Recycling and Emissions Reduction pursuant to 40 CFR Part 82, Subpart F. [40 CFR 82 Subpart F] Federally Enforceable Through Title V Permit
29. If the permittee performs service on motor vehicles when this service involves the ozone-depleting refrigerant in the motor vehicle air conditioner (MVAC), the permittee shall comply with the standards for Servicing of Motor Vehicle Air Conditioners pursuant to all the applicable requirements as specified in 40 CFR Part 82, Subpart B. [40 CFR Part 82, Subpart B] Federally Enforceable Through Title V Permit
30. Disturbances of soil related to any construction, demolition, excavation, extraction, or other earthmoving activities shall comply with the requirements for fugitive dust control in District Rule 8021 unless specifically exempted under Section 4.0 of Rule 8021 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8021] Federally Enforceable Through Title V Permit
31. Outdoor handling, storage and transport of any bulk material which emits dust shall comply with the requirements of District Rule 8031, unless specifically exempted under Section 4.0 of Rule 8031 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8031] Federally Enforceable Through Title V Permit
32. An owner/operator shall prevent or cleanup any carryout or trackout in accordance with the requirements of District Rule 8041 Section 5.0, unless specifically exempted under Section 4.0 of Rule 8041 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8041] Federally Enforceable Through Title V Permit
33. Whenever open areas are disturbed, or vehicles are used in open areas, the facility shall comply with the requirements of Section 5.0 of District Rule 8051, unless specifically exempted under Section 4.0 of Rule 8051 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8051] Federally Enforceable Through Title V Permit
34. Any paved road or unpaved road shall comply with the requirements of District Rule 8061 unless specifically exempted under Section 4.0 of Rule 8061 (8/19/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8061] Federally Enforceable Through Title V Permit
35. Any unpaved vehicle/equipment area that anticipates more than 50 Average annual daily Trips (AADT) shall comply with the requirements of Section 5.1.1 of District Rule 8071. Any unpaved vehicle/equipment area that anticipates more than 150 vehicle trips per day (VDT) shall comply with the requirements of Section 5.1.2 of District Rule 8071. On each day that 25 or more VDT with 3 or more axles will occur on an unpaved vehicle/equipment traffic area, the owner/operator shall comply with the requirements of Section 5.1.3 of District Rule 8071. On each day when a special event will result in 1,000 or more vehicles that will travel/park on an unpaved area, the owner/operator shall comply with the requirements of Section 5.1.4 of District Rule 8071. All sources shall comply with the requirements of Section 5.0 of District Rule 8071 unless specifically exempted under Section 4.0 of Rule 8071 (9/16/2004) or Rule 8011 (8/19/2004). [District Rules 8011 and 8071] Federally Enforceable Through Title V Permit
36. Any owner or operator of a demolition or renovation activity, as defined in 40 CFR 61.141, shall comply with the applicable inspection, notification, removal, and disposal procedures for asbestos containing materials as specified in 40 CFR 61.145 (Standard for Demolition and Renovation). [40 CFR 61 Subpart M] Federally Enforceable Through Title V Permit

FACILITY-WIDE REQUIREMENTS CONTINUE ON NEXT PAGE
These terms and conditions are part of the Facility-wide Permit to Operate.

37. The permittee shall submit certifications of compliance with the terms and standards contained in Title V permits, including emission limits, standards and work practices, to the District and the EPA annually (or more frequently as specified in an applicable requirement or as specified by the District). The certification shall include the identification of each permit term or condition, the compliance status, whether compliance was continuous or intermittent, the methods used for determining the compliance status, and any other facts required by the District to determine the compliance status of the source. [District Rule 2520, 9.16] Federally Enforceable Through Title V Permit
38. The permittee shall submit an application for Title V permit renewal to the District at least six months, but not greater than 18 months, prior to the permit expiration date. [District Rule 2520, 5.2] Federally Enforceable Through Title V Permit
39. When a term is not defined in a Title V permit condition, the definition in the rule cited as the origin and authority for the condition in a Title V permits shall apply. [District Rule 2520, 9.1.1] Federally Enforceable Through Title V Permit
40. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following outdated SIP requirements: Rule 401 (Madera, Fresno, Kern, Kings, San Joaquin, Stanislaus, Tulare and Merced), Rule 110 (Fresno, Stanislaus, San Joaquin), Rule 109 (Merced), Rule 113 (Madera), Rule 111 (Kern, Tulare, Kings), and Rule 202 (Fresno, Kern, Tulare, Kings, Madera, Stanislaus, Merced, San Joaquin). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
41. Compliance with permit conditions in the Title V permit shall be deemed in compliance with the following applicable requirements: SJVUAPCD Rules 1100, sections 6.1 and 7.0 (12/17/92); 2010, sections 3.0 and 4.0 (12/17/92); 2031 (12/17/92); 2040 (12/17/92); 2070, section 7.0 (12/17/92); 2080 (12/17/92); 4101 (2/17/05); 4601 (12/17/09); 8021 (8/19/2004); 8031 (8/19/2004); 8041 (8/19/2004); 8051 (8/19/2004); 8061 (8/19/2004); and 8071 (9/16/2004). A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. On June 30, 2005, the initial Title V permit was issued. The reporting periods for the Report of Required Monitoring and the Compliance Certification Report begin July 1 of every year, unless alternative dates are approved by the District Compliance Division. These reports are due within 30 days after the end of the reporting period. [District Rule 2520] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1413-4-13

EXPIRATION DATE: 04/30/2025

SECTION: SW35 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

CRUDE OIL STORAGE AND TRANSFER OPERATION CONSISTING OF A 67,000 BBL (2,814,000 GALLON) RIVETED EXTERNAL FLOATING ROOF CRUDE OIL STORAGE TANK #105 WITH A MECHANICAL SHOE PRIMARY SEAL, WIPER TYPE SECONDARY SEAL, AND SLOTTED GUIDEPOLE (BAKERSFIELD PUMP STATION)

PERMIT UNIT REQUIREMENTS

1. Tank throughput shall not exceed 67,000 bbl/day. [District Rule 2201] Federally Enforceable Through Title V Permit
2. Tank shall be equipped with Weather Guard mechanical shoe primary seal and wiper type secondary seal. [District Rules 2201 and 4623, 5.3.2.4.1] Federally Enforceable Through Title V Permit
3. The operation shall include four centrifugal loading pumps, three centrifugal recirculation pumps, two heat exchangers, piping network, and an underground steel sump tank. [District Rule 2201] Federally Enforceable Through Title V Permit
4. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred as the secondary seal. [District Rule 4623, 5.3.1.2] Federally Enforceable Through Title V Permit
5. The external floating roof shall float on the surface of the stored liquid at all times (i.e., off the roof leg supports) except during the initial fill until the roof is lifted off the leg supports and when the tank is completely emptied and subsequently refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five calendar days prior to performing the work. The tank must be in compliance with this rule before it may land on its legs. [District Rules 4623, 5.3.1.3] Federally Enforceable Through Title V Permit
6. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
7. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
8. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank.. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
9. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.2.1] Federally Enforceable Through Title V Permit
10. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit
11. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.2.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-4-13 : Jun 22 2020 1:24PM -- PROCOPIIS

12. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 24 inches above the stored liquid surface. [District Rule 4623, 5.3.2.2.3] Federally Enforceable Through Title V Permit
13. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 5 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3.2.2.3] Federally Enforceable Through Title V Permit
14. True vapor pressure of crude oil stored, transferred, or heated shall not exceed 8.0 psia. [District Rule 2201] Federally Enforceable Through Title V Permit
15. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.3.2.2.4] Federally Enforceable Through Title V Permit
16. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.2.5] Federally Enforceable Through Title V Permit
17. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.3.2.2.6] Federally Enforceable Through Title V Permit
18. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be leak-free, except when the device or appurtenance is in use. [District Rule 4623, 5.5.1] Federally Enforceable Through Title V Permit
19. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak or reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
20. Except for automatic bleeder vents, rim vents, and pressure relief vents, each opening in a non-contact external floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.2.1] Federally Enforceable Through Title V Permit
21. Except for automatic bleeder vents and rim vents, roof drains, and leg sleeves, each opening in the roof shall be equipped with a gasketed cover, seal, or lid that shall be maintained in a closed position at all times (i.e., no visible gap) except when in actual use. [District Rule 4623, 5.5.2.2.2] Federally Enforceable Through Title V Permit
22. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.2.3] Federally Enforceable Through Title V Permit
23. Rim vents shall be equipped with a gasket and shall be set to open when the roof is being floated off the roof leg supports or at the manufacturer's recommended setting. [District Rules 4623, 5.5.2.2.4] Federally Enforceable Through Title V Permit
24. Each emergency roof drain shall be provided with a slotted membrane fabric cover that covers at least 90 percent of the area of the opening. The fabric cover must be impermeable if the liquid is drained into the contents of the tanks. [District Rule 4623, 5.5.2.2.5] Federally Enforceable Through Title V Permit
25. External floating roof legs shall be equipped with vapor socks or vapor barriers in order to maintain a leak-free condition so as to prevent VOC emissions from escaping through the roof leg opening. [District Rule 4623, 5.5.2.2.6] Federally Enforceable Through Title V Permit
26. All wells and similar fixed projections through the floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

27. The slotted guidepole well on a external floating roof shall be equipped with the following: a sliding cover, a well gasket, a pole sleeve, a pole wiper, and an internal float and float wiper designed to minimize the gap between the float and the well, and provided the gap shall not exceed 1/8 inch; or shall be equipped with a well gasket, a zero gap pole wiper seal and a pole sleeve that projects below the liquid surface. [District Rule 4623, 5.5.2.4.2] Federally Enforceable Through Title V Permit
28. The gap between the pole wiper and the slotted guidepole shall be added to the gaps measured to determine compliance with the secondary seal requirement, and in no case shall exceed 1/8 inch. [District Rule 4623, 5.5.2.4.3] Federally Enforceable Through Title V Permit
29. Oil throughput of sump shall not exceed 5,200 gal/day. [District Rule 2201] Federally Enforceable Through Title V Permit
30. Permittee shall notify the District in writing upon each occasion when the crude oil received, stored, handled, transferred, or loaded into railcars is heated in the heat exchangers. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Permittee shall notify District at least 7 days prior to the date when unobstructed primary and secondary seal/gap measurements will occur. [District Rule 1070] Federally Enforceable Through Title V Permit
32. Combustion contaminant emissions from fired equipment shall not increase due to increased throughput at heat exchangers. [District Rule 2201] Federally Enforceable Through Title V Permit
33. Fugitive volatile organic compound (VOC) emissions shall not exceed 17.7 lb/day (combined fugitive emissions from permits S-1413-4 and S-1413-6). [District Rule 2201] Federally Enforceable Through Title V Permit
34. The permittee of external floating roof tanks shall make the primary seal envelope available for unobstructed inspection by the APCO on an annual basis at locations selected along its circumference at random by the APCO. A minimum of four locations shall be made available. If the APCO suspects a violation may exist the APCO may require such further unobstructed inspection of the primary seal as may be necessary to determine the seal condition for its entire circumference. [District Rule 4623, 6.1.1] Federally Enforceable Through Title V Permit
35. The permittee shall inspect all floating tanks at least once every 12 months to determine compliance with the requirements of this rule. The actual gap measurements of the floating roof primary and secondary seals shall be recorded. The inspection results shall be submitted to the APCO as specified in Section 6.3.5. [District Rule 4623, 6.1.3.1.1] Federally Enforceable Through Title V Permit
36. The permittee shall inspect the primary and secondary seals for compliance with the requirements of this rule every time a tank is emptied or degassed. Actual gap measurements shall be performed when the liquid level is static but not more than 48 hours after the tank roof is re-floated. [District Rule 4623, 6.1.3.1.2] Federally Enforceable Through Title V Permit
37. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5] Federally Enforceable Through Title V Permit
38. Permittee shall maintain record of liquids stored, daily throughput, storage temperature, storage period, maximum RVP & TVP of liquid during respective storage period, and shall make such records readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
39. Permittee shall maintain the records of the external floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-4-13 : Jun 22 2020 1:24PM -- PROCOPIIS

40. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
41. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. Permittee shall conduct API gravity and True Vapor Pressure (TVP) testing of the organic liquid stored in this tank at actual storage temperature of the organic liquid in the tank within 30 days of tank filling and every 24 months thereafter during summer (July - September), and/or whenever there is a change in the source or type of organic liquid stored in this tank. [District Rule 4623, 6.2, 6.3, 6.4] Federally Enforceable Through Title V Permit
43. As used in this permit, the term "source or type" shall mean liquids with similar characteristics. The operator shall maintain records of API gravity of petroleum liquids stored in this unit to determine which are from common source. [District Rule 2201] Federally Enforceable Through Title V Permit
44. The API gravity of crude oil or petroleum distillate shall be determined by using ASTM Method D 287 e1 "Standard Test Method for API gravity of Crude Petroleum and Petroleum Products (Hydrometer Method)". Sampling for API gravity shall be performed in accordance with ASTM Method D 4057 "Standard Practices for Manual Sampling of Petroleum and Petroleum Products". [District Rules 2201 and 4623, 6.4] Federally Enforceable Through Title V Permit
45. For crude oil with an API gravity of 26 degrees or less, the TVP shall be determined using the latest version of the Lawrence Berkeley National Laboratory "Test Method for Vapor Pressure of Reactive Organic Compounds in Heavy Crude Oil Using Gas Chromatograph", as approved by ARB and EPA. [District Rules 2201 and 4623, 6.4] Federally Enforceable Through Title V Permit
46. For any organic liquid, except crude oil with an API gravity of 26 degrees or less, the true vapor pressure (TVP) shall be determined by measuring Reid Vapor Pressure (RVP) with ASTM Method D 323 and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the oil and gas section of "California Air Resources Boards (ARB) Technical Guidance Document to the Criteria and Guidelines Regulation for AB 2588", dated August 1989. As an alternative to using ASTM D 323, the TVP of crude oil with an API gravity range of greater than 26 degrees up to 30 degrees may be determined by using other equivalent test methods approved by APCO, ARB and EPA. [District Rules 2201 and 4623, 6.4] Federally Enforceable Through Title V Permit
47. Permittee shall submit the records of TVP and API gravity testing to the APCO within 45 days after the date of testing. The records shall include the tank identification number, Permit to Operate number, type of stored organic liquid, TVP and API gravity of the organic liquid, test methods used, and a copy of the test results. [District Rules 1070 and 2201] Federally Enforceable Through Title V Permit
48. Operators of floating roof tanks shall submit a tank inspection plan to the APCO for approval. The plan shall include an inventory of the tanks subject to this rule and a tank inspection schedule. A copy of the operator's tank safety procedures shall be made available to the APCO upon request. The tank inventory shall include tank's identification number, PTO number, maximum tank capacity, dimensions of tank (height and diameter), organic liquid stored, type of primary and secondary seal, type of floating roof (internal or external floating roof), construction date of tank, and location of tank. Any revision to a previously approved tank inspection schedule shall be submitted to the APCO for approval prior to conducting an inspection. [District Rule 4623, 6.1.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1413-6-9

EXPIRATION DATE: 04/30/2025

SECTION: SW35 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

CRUDE OIL STORAGE AND TRANSFER OPERATION INCLUDING A 67,000 BARREL (2,814,000 GALLON) RIVETED EXTERNAL FLOATING ROOF CRUDE OIL STORAGE TANK #106 WITH MECHANICAL SHOE PRIMARY SEAL AND WIPER TYPE SECONDARY SEAL (BAKERSFIELD PUMP STATION)

PERMIT UNIT REQUIREMENTS

1. Tank shall be equipped with Weather Guard mechanical shoe primary seal and wiper type secondary seal. [District Rules 2201 and 4623, 5.3, 5.3.2.4.1] Federally Enforceable Through Title V Permit
2. The operation shall include four centrifugal loading pumps, three centrifugal recirculation pumps, two heat exchangers, piping network, and an underground steel sump tank. [District Rule 2201] Federally Enforceable Through Title V Permit
3. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred to as the secondary seal. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
4. The external floating roof shall float on the surface of the stored liquid at all times (i.e., off the roof leg supports) except during the initial fill until the roof is lifted off the leg supports and when the tank is completely emptied and subsequently refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on its legs, the permittee shall notify the APCO in writing at least five calendar days prior to performing the work. The tank must be in compliance with this rule before it may land on its legs. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
5. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
6. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
7. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
8. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
9. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
10. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
11. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 24 inches above the stored liquid surface. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-6-9 : Jun 22 2020 1:25PM -- PROCOPIIS

12. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 5 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
13. The true vapor pressure (TVP) of crude oil stored, transferred, or heated shall not exceed 8.0 psia. [District Rule 2201] Federally Enforceable Through Title V Permit
14. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
15. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
16. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.3] Federally Enforceable Through Title V Permit
17. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be leak-free, except when the device or appurtenance is in use. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
18. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak or reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
19. Except for automatic bleeder vents, rim vents, and pressure relief vents, each opening in a non-contact external floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
20. Except for automatic bleeder vents and rim vents, roof drains, and leg sleeves, each opening in the roof shall be equipped with a gasketed cover, seal, or lid that shall be maintained in a closed position at all times (i.e., no visible gap) except when in actual use. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
21. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
22. Rim vents shall be equipped with a gasket and shall be set to open when the roof is being floated off the roof leg supports or at the manufacturer's recommended setting. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
23. Each emergency roof drain shall be provided with a slotted membrane fabric cover that covers at least 90 percent of the area of the opening. The fabric cover must be impermeable if the liquid is drained into the contents of the tanks. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
24. External floating roof legs shall be equipped with vapor socks or vapor barriers in order to maintain a leak-free condition so as to prevent VOC emissions from escaping through the roof leg opening. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
25. All wells and similar fixed projections through the floating roof shall provide a projection below the liquid surface. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-6-9 : Jun 22 2020 1:25PM -- PROCOPIIS

26. The slotted guidepole well on a external floating roof shall be equipped with the following: a sliding cover, a well gasket, a pole sleeve, a pole wiper, and an internal float and float wiper designed to minimize the gap between the float and the well, and provided the gap shall not exceed 1/8 inch; or shall be equipped with a well gasket, a zero gap pole wiper seal and a pole sleeve that projects below the liquid surface. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
27. The gap between the pole wiper and the slotted guidepole shall be added to the gaps measured to determine compliance with the secondary seal requirement, and in no case shall exceed 1/8 inch. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
28. Oil throughput of sump shall not exceed 5,200 gal/day. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Upon commencement of 88,000 bbl/day throughput, the District shall be provided with the previous years of combustion data, and monthly after 88,000 bbl/day throughput, the District shall be provided with previous months combustion data. [District Rule 2201] Federally Enforceable Through Title V Permit
30. Permittee shall notify the District in writing upon each occasion when the crude oil received, stored, handled, transferred, or loaded into railcars is heated in the heat exchangers. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Permittee shall notify District at least 7 days prior to the date when unobstructed primary and secondary seal/gap measurements will occur. [District Rule 1070] Federally Enforceable Through Title V Permit
32. Combustion contaminant emissions from fired equipment shall not increase due to increased throughput at heat exchangers. [District Rule 2201] Federally Enforceable Through Title V Permit
33. Volatile organic compound (VOC) emission rate shall not exceed 45.1 lb/day and 17.7 lb/day fugitive (combined fugitive emissions from permits S-1413-4 and -6). [District Rule 2201] Federally Enforceable Through Title V Permit
34. The permittee of external floating roof tanks shall make the primary seal envelope available for unobstructed inspection by the APCO on an annual basis at locations selected along its circumference at random by the APCO. In the case of riveted tanks with toroid-type seals, a minimum of eight locations shall be made available; in all other cases, a minimum of four locations shall be made available. If the APCO suspects a violation may exist the APCO may require such further unobstructed inspection of the primary seal as may be necessary to determine the seal condition for its entire circumference. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
35. The permittee shall inspect all floating tanks at least once every 12 months to determine compliance with the requirements of this rule. The actual gap measurements of the floating roof primary and secondary seals shall be recorded. The inspection results shall be submitted to the APCO as specified in Section 6.3.5. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
36. The permittee shall inspect the primary and secondary seals for compliance with the requirements of this rule every time a tank is emptied or degassed. Actual gap measurements shall be performed when the liquid level is static but not more than 48 hours after the tank roof is re-floated. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
37. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
38. Permittee shall maintain record of liquids stored, daily throughput, storage temperature, storage period, maximum RVP & TVP of liquid during respective storage period, and shall make such records readily available for District inspection upon request. [District Rules 2201 and 4623, 6.3] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-6-9 : Jun 22 2020 1:25PM -- PROCOPIIS

39. Permittee shall maintain the records of the external floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 5.1, 6.3] Federally Enforceable Through Title V Permit
40. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
41. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
42. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rules 2520, 9.3.2 and 4623, 6.2, 6.3, 6.4] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1413-7-8

EXPIRATION DATE: 04/30/2025

SECTION: SW35 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

67,000 BBL (2,814,000 GALLON) INTERNAL FLOATING ROOF CRUDE OIL STORAGE TANK T 670-S-102 WITH ALTECH ALCLAD ALUMINUM PONTOON INTERNAL FLOATING ROOF WITH PRIMARY LIQUID MOUNTED FOAM LOG SEAL AND SECONDARY WIPER SEAL (BAKERSFIELD PUMP STATION)

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on it's legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.3.1.3, 5.4.3] Federally Enforceable Through Title V Permit
2. The primary resilient toroid seal shall be mounted on the perimeter of the roof such that it is in contact with the tank's liquid contents at all times while the roof is floating. [District Rule 4623, 5.3.2.3.1, 5.4.1] Federally Enforceable Through Title V Permit
3. No gap between the tank shell and the primary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.3.2, 5.4.1] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.3.2, 5.4.1] Federally Enforceable Through Title V Permit
5. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.3.2, 5.4.1] Federally Enforceable Through Title V Permit
6. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rules 4623, 5.3.2.3.3, 5.4.1] Federally Enforceable Through Title V Permit
7. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.3.3, 5.4.1] Federally Enforceable Through Title V Permit
8. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.3.2.3.4, 5.4.1] Federally Enforceable Through Title V Permit
9. The secondary seal shall allow easy insertion of probes up to 1/2 inch in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.3.5, 5.4.1] Federally Enforceable Through Title V Permit
10. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.3.2.3.6, 5.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-7-8 : Jun 22 2020 1:25PM -- PROCOPIIS

11. The tank pressure-vacuum (PV) relief valve shall be set to within 10% of the maximum allowable working pressure of the tank. The PV relief valve shall be permanently labeled with the operating pressure settings. The PV relief valve shall be properly installed and maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623, 5.2] Federally Enforceable Through Title V Permit
12. Stored petroleum liquid true vapor pressure shall not exceed 8.0 psia. [District Rule 2201] Federally Enforceable Through Title V Permit
13. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.5.1] Federally Enforceable Through Title V Permit
14. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak or reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.1.1] Federally Enforceable Through Title V Permit
16. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5.2.1.2] Federally Enforceable Through Title V Permit
17. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.1.3] Federally Enforceable Through Title V Permit
18. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.1.4] Federally Enforceable Through Title V Permit
19. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5.2.1.5] Federally Enforceable Through Title V Permit
20. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5.2.1.6] Federally Enforceable Through Title V Permit
21. Daily tank liquid throughput shall not exceed 30,000 bbl. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Permittee shall notify District at least 7 days prior to the date when unobstructed primary and secondary seal/gap testing will occur. [District Rule 1070] Federally Enforceable Through Title V Permit
23. Volatile organic compound (VOC) emission rate shall not exceed 22.2 lb day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-7-8 : Jun 22 2020 1:25PM -- PROCOPIIS

24. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repair, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1.3.2.1] Federally Enforceable Through Title V Permit
25. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1.3.2.2] Federally Enforceable Through Title V Permit
26. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1.3.2.3] Federally Enforceable Through Title V Permit
27. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5] Federally Enforceable Through Title V Permit
28. Permittee shall maintain record of liquids stored, daily throughput, storage temperature, storage period, maximum RVP & TVP of liquid during respective storage period, and shall make such records readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
31. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
32. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rules 2520, 9.3.2 and 4623, 6.2, 6.3, 6.4] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1413-8-8

EXPIRATION DATE: 04/30/2025

SECTION: SW35 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

67,000 BBL (2,814,000 GALLONS) RIVETED FIXED ROOF CRUDE OIL STORAGE TANK T 670-S-101 WITH PAN INTERNAL FLOATING ROOF WITH ALTECH DOUBLE WIPER SEAL (BAKERSFIELD PUMP STATION)

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on it's legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.3.1.3, 5.4.3] Federally Enforceable Through Title V Permit
2. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.3.2.2.1, 5.4.2] Federally Enforceable Through Title V Permit
3. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1, 5.4.2] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3.2.2.1, 5.4.2] Federally Enforceable Through Title V Permit
5. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.2.1, 5.4.2] Federally Enforceable Through Title V Permit
6. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.2.2, 5.4.2] Federally Enforceable Through Title V Permit
7. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.2.2, 5.4.2] Federally Enforceable Through Title V Permit
8. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.3.2.2.4, 5.4.2] Federally Enforceable Through Title V Permit
9. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.2.5, 5.4.2] Federally Enforceable Through Title V Permit
10. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.3.2.2.6, 5.4.2] Federally Enforceable Through Title V Permit
11. The tank pressure-vacuum (PV) relief valve shall be set to within 10% of the maximum allowable working pressure of the tank. The PV relief valve shall be permanently labeled with the operating pressure settings. The PV relief valve shall be properly installed and maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623, 5.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-8-8 : Jun 22 2020 1:25PM -- PROCOPIIS

12. Stored petroleum liquid true vapor pressure shall not exceed 8.0 psia. [District Rule 2201] Federally Enforceable Through Title V Permit
13. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.5.1] Federally Enforceable Through Title V Permit
14. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak or reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.1.1] Federally Enforceable Through Title V Permit
16. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5.2.1.2] Federally Enforceable Through Title V Permit
17. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.1.3] Federally Enforceable Through Title V Permit
18. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.1.4] Federally Enforceable Through Title V Permit
19. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5.2.1.5] Federally Enforceable Through Title V Permit
20. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5.2.1.6] Federally Enforceable Through Title V Permit
21. Daily tank liquid throughput shall not exceed 30,000 bbl. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Permittee shall notify District at least 7 days prior to the date when unobstructed primary and secondary seal/gap testing will occur. [District Rule 1070] Federally Enforceable Through Title V Permit
23. Volatile organic compound (VOC) emission rate shall not exceed 22.2 lb day. [District Rule 2201] Federally Enforceable Through Title V Permit
24. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repair, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1.3.2.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-8-8 : Jun 22 2020 1:25PM -- PROCOPIIS

25. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1.3.2.2] Federally Enforceable Through Title V Permit
26. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1.3.2.3] Federally Enforceable Through Title V Permit
27. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5] Federally Enforceable Through Title V Permit
28. Permittee shall maintain record of liquids stored, daily throughput, storage temperature, storage period, maximum RVP & TVP of liquid during respective storage period, and shall make such records readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
31. This tank shall be equipped with a closure device between the tank shell and roof edge consisting of two seals mounted one above the other; the one below shall be referred to as the primary seal, and the one above shall be referred as the secondary seal. [District Rule 4623, 5.3.1.2, 5.4.1] Federally Enforceable Through Title V Permit
32. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
33. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rules 2520, 9.3.2 and 4623, 6.2, 6.3, 6.4] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1413-9-9

EXPIRATION DATE: 04/30/2025

SECTION: SW35 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

67,000 BBL (2,814,000 GALLON) INTERNAL FLOATING ROOF CRUDE OIL STORAGE TANK # 103 WITH TOROID PRIMARY SEAL AND SECONDARY WIPER SEAL (BAKERSFIELD PUMP STATION)

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on it's legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.3.1.3, 5.4.3] Federally Enforceable Through Title V Permit
2. The primary resilient toroid seal shall be mounted on the perimeter of the roof such that it is in contact with the tank's liquid contents at all times while the roof is floating. [District Rule 4623, 5.3.2.3.1, 5.4.1] Federally Enforceable Through Title V Permit
3. No gap between the tank shell and the primary seal shall exceed 1/2 inch. [District Rule 4623, 5.3.2.3.2, 5.4.1] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.3.2, 5.4.1] Federally Enforceable Through Title V Permit
5. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3.2.3.2, 5.4.1] Federally Enforceable Through Title V Permit
6. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rules 4623, 5.3.2.3.3, 5.4.1] Federally Enforceable Through Title V Permit
7. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3.2.3.3, 5.4.1] Federally Enforceable Through Title V Permit
8. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.3.2.3.4, 5.4.1] Federally Enforceable Through Title V Permit
9. The secondary seal shall allow easy insertion of probes up to 1/2 inch in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3.2.3.5, 5.4.1] Federally Enforceable Through Title V Permit
10. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.3.2.3.6, 5.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-9-9 : Jun 22 2020 1:25PM -- PROCOPIIS

11. The tank pressure-vacuum (PV) relief valve shall be set to within 10% of the maximum allowable working pressure of the tank. The PV relief valve shall be permanently labeled with the operating pressure settings. The PV relief valve shall be properly installed and maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623, 5.2] Federally Enforceable Through Title V Permit
12. Stored petroleum liquid true vapor pressure shall not exceed 8.0 psia. [District Rule 2201] Federally Enforceable Through Title V Permit
13. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.5.1] Federally Enforceable Through Title V Permit
14. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak or reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
15. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5.2.1.1] Federally Enforceable Through Title V Permit
16. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5.2.1.2] Federally Enforceable Through Title V Permit
17. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5.2.1.3] Federally Enforceable Through Title V Permit
18. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5.2.1.4] Federally Enforceable Through Title V Permit
19. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5.2.1.5] Federally Enforceable Through Title V Permit
20. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5.2.1.6] Federally Enforceable Through Title V Permit
21. Daily tank liquid throughput shall not exceed 40,000 bbl. [District Rule 2201] Federally Enforceable Through Title V Permit
22. Permittee shall notify District at least 7 days prior to the date when unobstructed primary and secondary seal/gap testing will occur. [District Rule 1070] Federally Enforceable Through Title V Permit
23. Volatile organic compound (VOC) emission rate shall not exceed 35.0 lb day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-9-9 : Jun 22 2020 1:25PM -- PROCOPIIS

24. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repair, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1.3.2.1] Federally Enforceable Through Title V Permit
25. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1.3.2.2] Federally Enforceable Through Title V Permit
26. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1.3.2.3] Federally Enforceable Through Title V Permit
27. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3.5] Federally Enforceable Through Title V Permit
28. Permittee shall maintain record of liquids stored, daily throughput, storage temperature, storage period, maximum RVP & TVP of liquid during respective storage period, and shall make such records readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
29. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3.7] Federally Enforceable Through Title V Permit
30. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
31. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
32. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rules 2520, 9.3.2 and 4623, 6.2, 6.3, 6.4] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley

Air Pollution Control District

PERMIT UNIT: S-1413-10-11

EXPIRATION DATE: 04/30/2025

SECTION: SW35 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

CRUDE OIL STORAGE AND TRANSFER OPERATION INCLUDING A 67,000 BBL (2,814,000 GALLON) RIVETED INTERNAL FLOATING ROOF CRUDE OIL STORAGE TANK #104 WITH MECHANICAL SHOE PRIMARY SEAL AND WIPER TYPE SECONDARY SEAL (BAKERSFIELD PUMP STATION)

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on it's legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.4.3] Federally Enforceable Through Title V Permit
2. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
3. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
5. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
6. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
7. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
8. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 18 inches above the stored liquid surface. [District Rule 4623, 5.4, 5.4.1] Federally Enforceable Through Title V Permit
9. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 5 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.4, 5.4.1] Federally Enforceable Through Title V Permit
10. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
11. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-10-11 : Jun 22 2020 1:25PM -- PROCOPIIS

12. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
13. The tank pressure-vacuum (PV) relief valve shall be set to within 10% of the maximum allowable working pressure of the tank. The PV relief valve shall be permanently labeled with the operating pressure settings. The PV relief valve shall be properly installed and maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623, 5.2] Federally Enforceable Through Title V Permit
14. The true vapor pressure (TVP) of the organic liquid stored shall not exceed 8.0 psia. [District Rule 2201] Federally Enforceable Through Title V Permit
15. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
16. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak or reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
17. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
18. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
19. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
20. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
21. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
22. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
23. Daily tank liquid throughput shall not exceed 40,000 bbl. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Permittee shall notify District at least 7 days prior to the date when unobstructed primary and secondary seal/gap testing will occur. [District Rule 1070] Federally Enforceable Through Title V Permit
25. Volatile organic compound (VOC) emission rate shall not exceed 35.0 lb day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

26. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repair, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
27. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
28. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
29. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
30. Permittee shall maintain record of liquids stored, daily throughput, storage temperature, storage period, maximum RVP & TVP of liquid during respective storage period, and shall make such records readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
32. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
33. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
34. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rule 2520, 9.3.2; 4623, 6.2.2, 6.3, 6.4] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley

Air Pollution Control District

PERMIT UNIT: S-1413-11-10

EXPIRATION DATE: 04/30/2025

SECTION: SW35 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

CRUDE OIL STORAGE AND TRANSFER OPERATION INCLUDING A 67,000 BARREL (2,814,000 GALLON) RIVETED INTERNAL FLOATING ROOF CRUDE OIL STORAGE TANK #107 (TK670S107) WITH MECHANICAL SHOE PRIMARY SEAL AND WIPER TYPE SECONDARY SEAL (BAKERSFIELD PUMP STATION)

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on it's legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.4.3] Federally Enforceable Through Title V Permit
2. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
3. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
5. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
6. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
7. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
8. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 18 inches above the stored liquid surface. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
9. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 5 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
10. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
11. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-11-10 : Jun 22 2020 1:25PM -- PROCOPIIS

12. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
13. The tank pressure-vacuum (PV) relief valve shall be set to within 10% of the maximum allowable working pressure of the tank. The PV relief valve shall be permanently labeled with the operating pressure settings. The PV relief valve shall be properly installed and maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623, 5.2] Federally Enforceable Through Title V Permit
14. The true vapor pressure (TVP) of the organic liquid stored shall not exceed 8.0 psia. [District Rule 2201] Federally Enforceable Through Title V Permit
15. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
16. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak or reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
17. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
18. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
19. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
20. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
21. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
22. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
23. Daily tank liquid throughput shall not exceed 40,000 bbl. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Permittee shall notify District at least 7 days prior to the date when unobstructed primary and secondary seal/gap testing will occur. [District Rule 1070] Federally Enforceable Through Title V Permit
25. Volatile organic compound (VOC) emission rate shall not exceed 35.0 lb day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-11-10 : Jun 22 2020 1:25PM -- PROCOPIIS

26. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repair, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
27. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
28. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
29. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
30. Permittee shall maintain record of liquids stored, daily throughput, storage temperature, storage period, maximum RVP & TVP of liquid during respective storage period, and shall make such records readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
32. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
33. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
34. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rules 2520, 9.3.2 and 4623, 6.2, 6.3, 6.4] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley

Air Pollution Control District

PERMIT UNIT: S-1413-12-11

EXPIRATION DATE: 04/30/2025

SECTION: SW35 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

CRUDE OIL STORAGE AND TRANSFER OPERATION INCLUDING A 67,000 BBL (2,814,000 GALLON) RIVETED INTERNAL FLOATING ROOF CRUDE OIL STORAGE TANK #108 (TK670S108) WITH MECHANICAL SHOE PRIMARY SEAL AND WIPER TYPE SECONDARY SEAL (BAKERSFIELD PUMP STATION)

PERMIT UNIT REQUIREMENTS

1. The internal floating roof shall rest or float on the liquid surface (but not necessarily in complete contact with it) inside a storage vessel that has a fixed roof. The internal roof shall be floating on the liquid surface except during initial fill and when the storage vessel is completely emptied or subsequently emptied and refilled. When the roof is resting on the leg supports, the process of filling, emptying, or refilling shall be continuous and shall be accomplished as rapidly as possible. Whenever the permittee intends to land the roof on it's legs, the permittee shall notify the APCO in writing at least five days prior to performing the work. [District Rule 4623, 5.4.3] Federally Enforceable Through Title V Permit
2. Gaps between the tank shell and the primary seal shall not exceed 2 1/2 inches. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
3. The cumulative length of all primary seal gaps greater than 1 1/2 inches shall not exceed 10% of the circumference of the tank. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
4. The cumulative length of all primary seal gaps greater than 1/8 inch shall not exceed 30% of the circumference of the tank. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
5. No continuous gap in the primary seal greater than 1/8 inch wide shall exceed 10% of the tank circumference. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
6. No gap between the tank shell and the secondary seal shall exceed 1/2 inch. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
7. The cumulative length of all gaps between the tank shell and the secondary seal, greater than 1/8 inch shall not exceed 5% of the tank circumference. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
8. The metallic shoe-type seal shall be installed so that one end of the shoe extends into the stored liquid and the other end extends a minimum vertical distance of 18 inches above the stored liquid surface. [District Rule 4623, 5.3, 5.4.1] Federally Enforceable Through Title V Permit
9. The geometry of the metallic-shoe type seal shall be such that the maximum gap between the shoe and the tank shell shall be no greater than 5 inches for a length of at least 18 inches in the vertical plane above the liquid. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
10. There shall be no holes, tears, or openings in the secondary seal or in the primary seal envelope that surrounds the annular vapor space enclosed by the roof edge, seal fabric, and secondary seal. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
11. The secondary seal shall allow easy insertion of probes up to 2 1/2 inches in width in order to measure gaps in the primary seal. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-12-11 : Jun 22 2020 1:25PM -- PROCOPIIS

12. The secondary seal shall extend from the roof to the tank shell and shall not be attached to the primary seal. [District Rule 4623, 5.4.1] Federally Enforceable Through Title V Permit
13. The tank pressure-vacuum (PV) relief valve shall be set to within 10% of the maximum allowable working pressure of the tank. The PV relief valve shall be permanently labeled with the operating pressure settings. The PV relief valve shall be properly installed and maintained in good operating order in accordance with the manufacturer's instructions, and shall remain in leak-free condition except when the operating pressure exceeds the valve's set pressure. [District Rule 4623, 5.2] Federally Enforceable Through Title V Permit
14. The true vapor pressure (TVP) of the organic liquid stored shall not exceed 8.0 psia. [District Rule 2201] Federally Enforceable Through Title V Permit
15. All openings in the roof used for sampling and gauging, except pressure-vacuum valves which shall be set to within 10% of the maximum allowable working pressure of the roof, shall provide a projection below the liquid surface to prevent belching of liquid and to prevent entrained or formed organic vapor from escaping from the liquid contents of the tank and shall be equipped with a cover, seal or lid that shall be in a closed position at all times, with no visible gaps and be gas tight, except when the device or appurtenance is in use. [District Rule 4623 5.5] Federally Enforceable Through Title V Permit
16. A leak-free condition is defined as a condition without a gas leak or a liquid leak. A liquid leak is defined as the dripping of organic liquid at a rate of more than 3 drops per minute. A gas leak is defined as a reading in excess of 10,000 ppmv, above background, as measured by a portable hydrocarbon detection instrument in accordance with the procedures specified in EPA Test Method 21. A liquid leak or reading in excess of 10,000 ppmv above background is a violation of this permit and Rule 4623 and shall be reported as a deviation. [District Rule 4623, 6.4] Federally Enforceable Through Title V Permit
17. Each opening in a non-contact internal floating roof, except for automatic bleeder vents (vacuum breaker vents) and rim space vents, shall provide a projection below the liquid surface. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
18. Each opening in the internal floating roof except for leg sleeves, automatic bleeder vents, rim space vents, column wells, ladder wells, sample wells, and stub drains is to be equipped with a cover or lid which is to be maintained in a closed position at all times (i.e., no visible gap) except when the device is in actual use. The cover or lid shall be equipped with a gasket. Covers on each access hatch and automatic gauge float well shall be bolted except when they are in use. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
19. Automatic bleeder vents shall be equipped with a gasket and shall be closed at all times when the roof is floating except when the roof is being floated off or is being landed on the roof leg supports. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
20. Rim vents shall be equipped with a gasket and are to be set to open only when the internal floating roof is not floating or at the manufacturer's recommended setting. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
21. Each penetration of the internal floating roof for the purpose of sampling shall be a sample well. The well shall have a slit fabric cover that covers at least 90% of the opening. The fabric cover must be impermeable. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
22. Each penetration of the internal floating roof that allows for passage of a column supporting the fixed roof shall have a flexible fabric sleeve seal or a gasketed sliding cover. The fabric sleeve must be impermeable. [District Rule 4623, 5.5] Federally Enforceable Through Title V Permit
23. Daily tank liquid throughput shall not exceed 40,000 bbl. [District Rule 2201] Federally Enforceable Through Title V Permit
24. Permittee shall notify District at least 7 days prior to the date when unobstructed primary and secondary seal/gap testing will occur. [District Rule 1070] Federally Enforceable Through Title V Permit
25. Volatile organic compound (VOC) emission rate shall not exceed 36.7 lb day. [District Rule 2201] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-12-11 : Jun 22 2020 1:25PM -- PROCOPIIS

26. The permittee shall visually inspect the internal floating roof, and its appurtenant parts, fittings, etc. and measure the gaps of the primary seal and/or secondary seal prior to filling the tank for newly constructed, repair, or rebuilt internal floating roof tanks. If holes, tears, or openings in the primary seal, the secondary seal, the seal fabric or defects in the internal floating roof or its appurtenant parts, components, fittings, etc., are found, they shall be repaired prior to filling the tank. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
27. The permittee shall visually inspect, through the manholes, roof hatches, or other openings on the fixed roof, the internal floating roof and its appurtenant parts, fittings, etc., and the primary seal and/or secondary seal at least once every 12 months after the tank is initially filled with an organic liquid. There should be no visible organic liquid on the roof, tank walls, or anywhere. Other than the gap criteria specified by this rule, no holes, tears, or other openings are allowed that would permit the escape of vapors. Any defects found are violations of this rule. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
28. The permittee shall conduct actual gap measurements of the primary seal and/or secondary seal at least once every 60 months. [District Rule 4623, 6.1] Federally Enforceable Through Title V Permit
29. Permittee shall submit the reports of the floating roof tank inspections to the APCO within five calendar days after the completion of the inspection only for those tanks that failed to meet the applicable requirements of Rule 4623, Sections 5.2 through 5.5. The inspection report for tanks that have been determined to be in compliance with the requirements of Sections 5.2 through 5.5 need not be submitted to the APCO, but the inspection report shall be kept on-site and made available upon request by the APCO. The inspection report shall contain all necessary information to demonstrate compliance with the provisions of Rule 4623. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
30. Permittee shall maintain record of liquids stored, daily throughput, storage temperature, storage period, maximum RVP & TVP of liquid during respective storage period, and shall make such records readily available for District inspection upon request. [District Rule 2201] Federally Enforceable Through Title V Permit
31. Permittee shall maintain the records of the internal floating roof landing activities that are performed pursuant to Rule 4623, Sections 5.3.1.3 and 5.4.3. The records shall include information on the true vapor pressure (TVP), API gravity, storage temperature, type of organic liquid stored in the tank, the purpose of landing the roof on its legs, the date of roof landing, duration the roof was on its legs, the level or height at which the tank roof was set to land on its legs, and the lowest liquid level in the tank. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
32. All records required to be maintained by this permit shall be maintained for a period of at least five years and shall be made readily available for District inspection upon request. [District Rule 4623, 6.3] Federally Enforceable Through Title V Permit
33. This unit was constructed prior to 1973 and has not been modified (as defined in 40 CFR 60.14) or reconstructed (as defined in 40 CFR 60.15) since 1973. Therefore, the requirements of 40 CFR 60 are not applicable to this unit. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
34. Permittee shall conduct true vapor pressure (TVP) testing of the organic liquid stored in this tank at least once every 24 months and/or whenever there is a change in the source or type of organic liquid stored in the tank. The TVP of any organic liquid shall be determined by measuring the Reid Vapor Pressure (RVP) using ASTM D 323 (Test Method for Vapor Pressure for Petroleum Products), and converting the RVP to TVP at the tank's maximum organic liquid storage temperature. The conversion of RVP to TVP shall be done in accordance with the procedures in appendix B of District Rule 4623. Records of TVP testing shall be maintained. [District Rules 2520, 9.3.2 and 4623, 6.2, 6.3, 6.4] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

San Joaquin Valley Air Pollution Control District

PERMIT UNIT: S-1413-13-15

EXPIRATION DATE: 04/30/2025

SECTION: SW35 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

20 MMBTU/HR BROACH NATURAL DRAFT HEATER WITH TWO NORTH AMERICAN MODEL 4211-12-LE-10 ULTRA LOW NOX BURNERS AND A FLUE GAS RECIRCULATION (FGR) SYSTEM

PERMIT UNIT REQUIREMENTS

1. Pursuant to Rule 4320, the operator shall pay an annual emission fee to the District for NOx emissions from this unit for the previous calendar year. Payments are due by July 1 of each year. Payments shall continue annually until either the unit is permanently removed from service in the District or the operator demonstrates compliance with the applicable NOx emission limit listed in Rule 4320. [District Rule 4320] Federally Enforceable Through Title V Permit
2. Permittee shall maintain records of fuel hhv and cumulative annual fuel use for each heater. [District Rule 4320] Federally Enforceable Through Title V Permit
3. Compliance with permit conditions in the Title V permit shall be deemed compliance with the subsumed requirements of Kern County Rule 407 and District Rule 4301. A permit shield is granted from these requirements. [District Rule 2520, 13.2] Federally Enforceable Through Title V Permit
4. All equipment shall be maintained in good operating condition and shall be operated in a manner to minimize emissions of air contaminants into the atmosphere. [District Rule 2201] Federally Enforceable Through Title V Permit
5. Particulate matter emissions shall not exceed 0.1 grains/dscf in concentration. No combustion contaminants exceeding in concentration at the point of discharge 0.1 grain per cubic foot of gas calculated to 12% of carbon dioxide at dry standard conditions shall be discharged into the atmosphere. [District Rules 4201, 3.0 and 4301, 5.1] Federally Enforceable Through Title V Permit
6. PUC-regulated natural gas with a sulfur content of less than or equal to 0.017% by weight shall only be used. [District Rule 2201, District Rule 4301, and County Rule 407 (Kern)] Federally Enforceable Through Title V Permit
7. Natural gas fuel consumption shall not exceed 415.2 MMBtu/day. [District Rule 2201] Federally Enforceable Through Title V Permit
8. During standard operation, emissions rates from the natural gas-fired unit shall not exceed any of the following limits: 15 ppmv NOx @ 3% O2 or 0.018 lb-NOx/MMBtu, 0.00285 lb-SOx/MMBtu, 0.005 lb-PM10/MMBtu, 400 ppmv CO @ 3% O2 or 0.30 lb-CO/MMBtu, or 0.003 lb-VOC/MMBtu. [District Rules 2201, 4305, and 4306] Federally Enforceable Through Title V Permit
9. During startup and shutdown, emissions from the natural gas-fired unit shall not exceed any of the following: 2.0 lb-NOx/hr, 0.06 lb-SOx/hr, 0.1 lb-PM10/hr, 6.0 lb-CO/hr, or 0.06 lb-VOC/hr. [District Rules 2201] Federally Enforceable Through Title V Permit
10. The total duration of startup time shall not exceed 2.0 hour per day. The total duration of shutdown time shall not exceed 2.0 hour per day. [District Rules 2201, 4305, and 4306, 5.3, 5.5] Federally Enforceable Through Title V Permit
11. The emission control systems shall be in operation and emissions shall be minimized insofar as technologically feasible during startup and shutdown. [District Rules 2201, 4305, and 4306, 5.3, 5.5] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-13-15 : Jun 22 2020 1:25PM -- PROCOPIIS

12. The permittee shall record the daily startup and shutdown duration times of the heater. [District Rules 2201, 4305, and 4306, 5.3, 5.5] Federally Enforceable Through Title V Permit
13. The permittee shall monitor and record the stack concentration of NO_x, CO, and O₂ at least once every month (in which a source test is not performed) using a portable emission monitor that meets District specifications. Monitoring shall not be required if the unit is not in operation, i.e. the unit need not be started solely to perform monitoring. Monitoring shall be performed within 5 days of restarting the unit unless monitoring has been performed within the last month. [District Rules 4305 and 4306, 5.4] Federally Enforceable Through Title V Permit
14. If either the NO_x or CO concentrations corrected to 3% O₂, as measured by the portable analyzer, exceed the allowable emissions concentration, the permittee shall return the emissions to within the acceptable range as soon as possible, but no longer than 1 hour of operation after detection. If the portable analyzer readings continue to exceed the allowable emissions concentration after 1 hour of operation after detection, the permittee shall notify the District within the following 1 hour and conduct a certified source test within 60 days of the first exceedance. In lieu of conducting a source test, the permittee may stipulate a violation has occurred, subject to enforcement action. The permittee must then correct the violation, show compliance has been re-established, and resume monitoring procedures. If the deviations are the result of a qualifying breakdown condition pursuant to Rule 1100, the permittee may fully comply with Rule 1100 in lieu of the performing the notification and testing required by this condition. [District Rules 4305 and 4306, 5.4] Federally Enforceable Through Title V Permit
15. All alternate monitoring parameter emission readings shall be taken with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. The analyzer shall be calibrated, maintained, and operated in accordance with the manufacturer's specifications and recommendations or a protocol approved by the APCO. Emission readings taken shall be averaged over a 15 consecutive-minute period by either taking a cumulative 15 consecutive-minute sample reading or by taking at least five (5) readings, evenly spaced out over the 15 consecutive-minute period. [District Rules 4305 and 4306, 5.4] Federally Enforceable Through Title V Permit
16. The permittee shall maintain records of: (1) the date and time of NO_x, CO, and O₂ measurements, (2) the O₂ concentration in percent and the measured NO_x and CO concentrations corrected to 3% O₂, (3) make and model of exhaust gas analyzer, (4) exhaust gas analyzer calibration records, and (5) a description of any corrective action taken to maintain the emissions within the acceptable range. [District Rules 4305 and 4306, 6.1] Federally Enforceable Through Title V Permit
17. All emissions measurements shall be made with the unit operating either at conditions representative of normal operations or conditions specified in the Permit to Operate. No determination of compliance shall be established within two hours after a continuous period in which fuel flow to the unit is shut off for 30 minutes or longer, or within 30 minutes after a re-ignition as defined in Section 3.0 of District Rule 4306 (Amended 9/18/03). [District Rules 4305 and 4306, 5.5] Federally Enforceable Through Title V Permit
18. Source testing to measure natural gas-combustion NO_x and CO emissions from this unit shall be conducted at least once every twelve (12) months. After demonstrating compliance on two (2) consecutive annual source tests, the unit shall be tested not less than once every thirty-six (36) months. If the result of the 36-month source test demonstrates that the unit does not meet the applicable emission limits, the source testing frequency shall revert to at least once every twelve (12) months. [District Rules 4305 and 4306, 6.3] Federally Enforceable Through Title V Permit
19. The source test plan shall identify which basis (ppmv or lb/MMBtu) will be used to demonstrate compliance. [District Rules 4305 and 4306, 5.5] Federally Enforceable Through Title V Permit
20. Source testing shall be conducted using the methods and procedures approved by the District. The District must be notified at least 30 days prior to any compliance source test, and a source test plan must be submitted for approval at least 15 days prior to testing. [District Rule 1081] Federally Enforceable Through Title V Permit
21. NO_x emissions for source test purposes shall be determined using EPA Method 7E or ARB Method 100 on a ppmv basis, or EPA Method 19 on a heat input basis. [District Rules 4305 and 4306, 6.2] Federally Enforceable Through Title V Permit
22. CO emissions for source test purposes shall be determined using EPA Method 10 or ARB Method 100. [District Rules 4305 and 4306, 6.2] Federally Enforceable Through Title V Permit

PERMIT UNIT REQUIREMENTS CONTINUE ON NEXT PAGE

These terms and conditions are part of the Facility-wide Permit to Operate.

23. Stack gas oxygen (O₂) shall be determined using EPA Method 3 or 3A or ARB Method 100. [District Rules 4305 and 4306, 6.2] Federally Enforceable Through Title V Permit
24. For emissions source testing, the arithmetic average of three 30-consecutive-minute test runs shall apply. If two of three runs are above an applicable limit the test cannot be used to demonstrate compliance with an applicable limit. [District Rules 4305 and 4306, 5.5] Federally Enforceable Through Title V Permit
25. The results of each source test shall be submitted to the District within 60 days thereafter. [District Rule 1081] Federally Enforceable Through Title V Permit
26. A non-resettable, totalizing mass or volumetric fuel flow meter to measure the amount of fuel combusted in the unit shall be installed, utilized and maintained. [District Rule 2201] Federally Enforceable Through Title V Permit
27. Operator shall maintain copies of natural gas invoices. [District Rule 2520, 9.4.2] Federally Enforceable Through Title V Permit
28. Source testing shall be District witnessed or authorized. [District Rule 1081] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

***San Joaquin Valley
Air Pollution Control District***

PERMIT UNIT: S-1413-14-4

EXPIRATION DATE: 04/30/2025

SECTION: SW35 **TOWNSHIP:** 28S **RANGE:** 27E

EQUIPMENT DESCRIPTION:

400 GALLON FIXED ROOF SOLVENT STORAGE TANK

PERMIT UNIT REQUIREMENTS

1. This tank shall only store, place, or hold solvent liquids with a true vapor pressure (TVP) of less than 0.2 psia under all storage conditions. [Rule 2201] Federally Enforceable Through Title V Permit
2. The permittee shall keep accurate records of each solvent stored in the tank, including its storage temperature and TVP. [District Rule 1070] Federally Enforceable Through Title V Permit
3. All records required to be maintained by this permit shall be maintained for a period of at least 5 years and shall be made readily available for District inspection upon request. [District Rule 1070] Federally Enforceable Through Title V Permit
4. Permittee shall maintain on-site Manufacturer Safety Data Sheets (MSDS) or other documents supplied by the manufacturer to verify the TVP of liquid stored in this tank. [District Rule 2520, 9.3.2] Federally Enforceable Through Title V Permit

These terms and conditions are part of the Facility-wide Permit to Operate.

Facility Name: SAN PABLO BAY PIPELINE COMPANY LLC

Location: BAKERSFIELD PUMP STATION, 1801 PETROL RD, BAKERSFIELD, CA 93308-9793

S-1413-14-4 : Jun 22 2020 1:25PM -- PROCOPIS